

DENHAM, Australia

WMO: 944020

Lat: 25.9261S

Lon: 113.5319E

Elev: 10

StdP: 101.21

Time Zone: 8.00 (E08)

Period: 86-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	11.6	1.4	4.2	19.6	3.3	4.8	18.6	11.5	19.0	10.2	18.0	2.9	110	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.8	36.3	22.2	33.6	22.4	31.5	23.2	26.1	30.8	25.3	30.0	24.7	29.2	4.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	19.7	29.3	24.0	18.9	28.3	23.4	18.2	27.7	81.0	31.2	77.7	29.9	75.1	29.3	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	12.2	11.3	DB	8.4	41.8	0.9	2.1	7.7	43.3	7.2	44.5	6.7	45.7	6.0	47.2	(4)
(5)			WB	6.3	27.6	1.1	0.8	5.5	28.2	4.8	28.7	4.2	29.2	3.5	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	25.4	27.1	26.0	23.8	20.5	17.8	17.0	17.2	18.9	20.2	22.5	24.1	(6)	
	DBStd	4.02	2.21	2.80	2.42	2.12	2.11	1.71	1.67	1.91	1.81	1.92	2.25	2.19	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	147	0	0	0	0	5	29	48	46	14	5	1	0	(9)	
	CDD10.0	4262	478	480	496	413	327	236	216	223	267	315	375	437	(10)	
	CDD18.3	1367	219	247	238	163	73	14	6	9	32	62	125	179	(11)	
	CDH23.3	8782	1596	2352	1956	872	195	18	9	27	60	170	534	993	(12)	
	CDH26.7	2698	458	939	629	195	21	0	1	2	12	29	151	261	(13)	
(14) Wind	WSAvg	5.9	8.0	7.0	6.6	5.5	3.9	3.6	3.5	4.5	5.6	6.7	7.6	8.0	(14)	
(15) Precipitation	PrecAvg	221	5	14	16	18	39	47	43	22	8	5	5	1	(15)	
	PrecMax	427	64	144	208	92	136	161	149	73	22	46	51	31	(16)	
	PrecMin	103	0	0	0	0	0	4	0	0	0	0	0	0	(17)	
	PrecStd	86	13	28	36	22	34	33	39	17	6	9	12	5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.3	40.7	37.9	33.7	29.1	25.4	24.6	26.1	28.7	29.7	35.5	36.2	(19)	
		MCWB	21.3	22.3	21.5	20.5	19.3	16.5	16.2	15.1	15.9	17.6	19.4	21.2	(20)	
	2%	DB	33.1	36.9	34.6	30.9	26.9	23.5	22.6	23.4	24.9	26.9	31.0	31.7	(21)	
		MCWB	23.2	23.4	22.1	20.0	18.7	16.6	16.7	15.6	17.7	19.1	20.5	22.7	(22)	
	5%	DB	30.6	33.7	31.6	28.8	25.4	22.2	21.4	21.8	23.3	25.0	27.9	29.1	(23)	
		MCWB	24.3	24.0	23.1	21.7	19.4	17.1	16.6	16.4	17.9	19.3	21.1	22.8	(24)	
	10%	DB	29.1	31.5	29.9	27.3	24.3	21.1	20.4	20.8	22.2	23.8	26.1	27.5	(25)	
		MCWB	23.6	24.6	23.5	21.9	19.4	16.7	16.2	16.3	17.5	18.6	20.8	22.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	27.6	26.6	25.2	23.5	20.2	20.6	19.8	20.7	21.7	23.8	25.4	(27)	
		MCDB	31.0	32.7	31.3	28.5	25.6	21.8	21.9	21.6	23.8	25.5	28.8	31.3	(28)	
	2%	WB	25.2	26.5	25.6	24.2	22.2	19.4	18.9	18.6	19.6	20.7	22.7	24.1	(29)	
		MCDB	30.0	31.3	29.9	27.0	24.5	21.2	21.0	20.8	22.7	24.5	27.5	29.2	(30)	
	5%	WB	24.5	25.7	24.8	23.5	21.3	18.6	17.8	17.8	18.8	20.1	21.8	23.3	(31)	
		MCDB	29.2	30.5	28.9	26.3	23.8	20.6	20.0	20.3	21.9	23.9	26.4	27.8	(32)	
	10%	WB	23.8	25.0	24.3	22.8	20.5	17.8	17.1	17.1	18.1	19.3	21.1	22.6	(33)	
		MCDB	28.2	29.9	28.1	25.7	23.2	20.0	19.5	19.8	21.3	22.8	25.2	26.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	7.8	7.1	7.2	7.5	7.0	7.4	7.7	7.4	7.5	7.0	6.7	(35)	
		MCDBR	9.6	12.4	11.1	10.0	9.5	8.5	8.8	9.6	9.1	9.6	11.0	10.2	(36)	
	5% WB	MCWBR	5.0	5.3	5.4	5.3	5.2	4.4	4.8	5.2	5.0	5.3	5.6	5.2	(37)	
		MCWBR	7.9	8.5	7.6	7.1	7.3	6.3	6.6	7.2	7.3	8.0	8.6	8.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.365	0.370	0.353	0.332	0.312	0.306	0.298	0.303	0.320	0.329	0.337	0.345	(40)	
		taud	2.571	2.583	2.612	2.653	2.675	2.670	2.687	2.651	2.575	2.560	2.561	2.581	(41)	
	Ebn at Noon		977	957	946	923	902	887	909	940	964	986	999	999	(42)	
		Edh at Noon	108	104	96	84	75	72	73	83	98	105	108	107	(43)	
(44) All-Sky Solar Radiation	RadAvg		8.16	7.61	6.50	5.20	4.18	3.57	3.79	4.82	6.17	7.33	8.12	8.49	(44)	
	RadStd		0.34	0.24	0.41	0.27	0.24	0.18	0.22	0.18	0.18	0.20	0.19	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	-1.75	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page