

PAYNES FIND, Australia

WMO: 944040

Lat: 29.271S

Lon: 117.684E

Elev: 1115

StdP: 14.11

Time Zone: 8.00 (E08)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.7	38.2	23.6	18.6	76.1	26.9	21.7	72.6	18.6	66.0	15.2	62.3	0.0	N/A	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	105.1	67.4	102.5	66.9	99.7	66.5	73.8	88.8	71.8	88.9	70.0	89.6	5.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	115.5	78.7	67.0	103.4	77.7	64.3	93.9	76.3	38.2	88.7	36.3	88.8	34.7	89.6	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.6	13.7	11.3	DB	31.4	110.1	1.6	1.9	30.2	111.5	29.3	112.6	28.4	113.6	27.2	115.0
			WB	29.9	77.2	1.8	2.2	28.7	78.7	27.6	80.0	26.6	81.2	25.3	82.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.4	84.4	82.6	76.4	70.1	61.9	55.8	53.7	54.8	59.7	67.6	74.7	79.9
	DBStd	12.17	5.94	6.10	6.59	5.74	6.35	4.86	4.44	4.42	5.43	6.43	6.52	6.66
	HDD50	32	0	0	0	0	0	7	16	8	1	0	0	0
	HDD65	1330	0	0	2	20	137	277	352	316	174	48	4	0
	CDD50	6744	1065	912	817	604	370	182	130	158	293	544	741	928
	CDD65	2567	600	492	355	173	42	2	1	1	16	127	295	463
	CDH74	33223	8674	6737	4349	1509	370	14	4	42	271	1542	3635	6076
	CDH80	18213	5432	4005	2251	508	87	0	0	6	52	598	1834	3440
(14) Wind	WSAvg	3.7	4.5	4.3	3.8	2.7	2.6	2.9	2.8	2.8	3.6	4.4	5.0	5.0
(15) Precipitation	PrecAvg	11.0	0.7	0.9	0.9	1.0	1.5	1.7	1.3	1.1	0.6	0.4	0.4	0.5
	PrecMax	17.2	4.5	5.8	5.6	5.1	6.3	3.8	3.5	4.4	2.1	2.0	1.8	3.4
	PrecMin	3.9	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.9	1.1	1.3	1.3	1.1	1.3	1.1	0.9	0.9	0.4	0.5	0.6	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.4	108.1	103.3	93.3	87.1	75.9	73.5	79.0	87.0	95.7	103.0	106.4
		MCWB	68.0	67.5	66.6	63.6	61.5	58.4	57.0	58.0	60.0	63.3	64.7	67.2
	2%	DB	105.3	104.7	99.0	89.5	81.8	71.5	69.0	73.5	81.5	90.9	98.3	102.7
		MCWB	67.8	67.4	65.9	63.4	59.9	56.4	55.5	56.4	58.6	61.1	63.9	66.4
	5%	DB	102.7	101.0	95.1	86.0	77.8	68.3	65.9	69.6	77.3	87.0	94.2	99.4
		MCWB	67.5	67.3	66.0	63.4	59.6	55.6	55.0	54.5	57.2	60.0	62.7	66.1
	10%	DB	99.7	97.4	91.5	82.4	74.0	65.5	63.5	66.2	73.8	82.9	90.2	95.3
		MCWB	67.0	67.0	65.2	62.7	58.9	54.9	54.0	53.2	56.2	58.9	61.9	65.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	76.8	73.7	69.4	66.3	63.1	63.4	61.5	63.0	66.1	69.3	72.0
		MCDB	87.1	86.4	84.2	81.2	76.6	69.6	66.7	71.7	77.8	84.5	89.3	88.5
	2%	WB	73.0	74.6	70.9	67.5	64.1	60.3	59.1	59.0	61.0	63.7	66.5	69.9
		MCDB	93.0	86.4	83.8	79.6	72.6	66.8	63.7	67.3	75.7	83.3	87.4	91.7
	5%	WB	71.0	72.7	69.2	66.1	62.6	58.2	56.8	56.9	59.2	61.9	64.6	68.4
		MCDB	94.1	88.3	85.1	78.5	71.5	64.5	62.5	66.1	72.8	81.3	87.0	91.7
	10%	WB	69.2	70.5	67.7	64.8	61.1	56.4	55.2	55.2	57.7	60.1	63.0	66.9
		MCDB	93.5	87.4	84.0	76.9	70.2	63.1	61.2	62.8	70.2	79.1	85.3	90.9
(35) Mean Daily Temperature Range	5% DB	MDBR	27.1	25.0	24.4	23.0	22.4	20.9	20.9	22.8	25.8	26.1	25.6	25.3
		MCDBR	29.6	30.4	30.1	27.8	26.8	25.6	25.2	29.9	31.3	32.0	30.5	28.9
		MCWBR	9.3	8.9	9.9	10.3	11.3	13.5	14.1	14.8	13.0	11.3	10.8	10.0
	5% WB	MCDBR	25.3	19.9	22.9	21.7	20.0	19.2	18.8	24.3	26.0	27.1	27.2	23.4
		MCWBR	9.7	8.8	9.9	9.7	10.3	12.5	13.0	14.1	12.6	11.8	12.0	9.8
(40) Clear-Sky Solar Irradiance	taub		0.332	0.338	0.320	0.306	0.289	0.279	0.276	0.281	0.300	0.308	0.316	0.320
	taud		2.599	2.606	2.634	2.645	2.658	2.673	2.679	2.654	2.557	2.558	2.566	2.592
	Ebn at Noon		320	312	309	298	290	286	292	303	310	318	323	325
	Edh at Noon		33	32	29	26	23	22	22	25	31	33	34	33
(44) All-Sky Solar Radiation	RadAvg		2557	2303	1986	1560	1224	1035	1111	1420	1868	2260	2537	2670
	RadStd		154	141	134	70	81	71	58	53	78	108	109	129

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page