

PAYNES FIND, Australia

WMO: 944040

Lat: 29.271S

Lon: 117.684E

Elev: 340

StdP: 97.31

Time Zone: 8.00 (E08)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.1	3.4	-4.7	2.7	24.5	-2.8	3.1	22.5	8.3	18.9	6.8	16.8	0.0	N/A	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.0	40.6	19.6	39.2	19.4	37.6	19.2	23.2	31.6	22.1	31.6	21.1	32.0	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.5	26.0	19.4	14.8	25.4	17.9	13.4	24.6	71.1	31.5	66.5	31.5	62.8	32.0	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
7.4	6.1	5.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-0.3	43.4	0.9	1.0	-1.0	44.2	-1.5	44.8	-2.0	45.4	-2.7	46.1		
			-1.1	25.1	1.0	1.2	-1.9	26.0	-2.4	26.7	-3.0	27.3	-3.7	28.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	29.1	28.1	24.6	21.2	16.6	13.2	12.0	12.7	15.4	19.8	23.7	26.6
	DBStd	6.76	3.30	3.39	3.66	3.19	3.53	2.70	2.47	2.45	3.02	3.57	3.62	3.70
	HDD10.0	18	0	0	0	0	0	4	9	4	1	0	0	0
	HDD18.3	739	0	0	1	11	76	154	196	176	97	27	2	0
	CDD10.0	3747	592	507	454	336	206	101	72	88	163	302	412	516
	CDD18.3	1426	333	273	197	96	23	1	1	1	9	71	164	257
	CDH23.3	18457	4819	3743	2416	838	206	8	2	23	151	857	2019	3376
	CDH26.7	10118	3018	2225	1251	282	48	0	0	3	29	332	1019	1911
(14) Wind	WSAvg	1.7	2.0	1.9	1.7	1.2	1.2	1.3	1.2	1.3	1.6	2.0	2.2	2.3
(15) Precipitation	PrecAvg	279	17	23	23	26	38	44	34	29	14	10	11	13
	PrecMax	437	114	147	142	129	161	97	89	113	54	52	46	86
	PrecMin	99	0	0	0	0	0	2	0	0	0	0	0	0
	PrecStd	73	27	33	34	29	33	28	23	23	11	12	14	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	42.3	39.6	34.0	30.6	24.4	23.0	26.1	30.6	35.4	39.4	41.3
		MCWB	20.0	19.7	19.2	17.6	16.4	14.7	13.9	14.4	15.5	17.4	18.2	19.5
	2%	DB	40.7	40.4	37.2	31.9	27.7	21.9	20.6	23.1	27.5	32.7	36.8	39.3
		MCWB	19.9	19.7	18.8	17.5	15.5	13.5	13.0	13.6	14.8	16.2	17.7	19.1
	5%	DB	39.3	38.3	35.0	30.0	25.4	20.2	18.9	20.9	25.2	30.6	34.6	37.4
		MCWB	19.7	19.6	18.9	17.4	15.3	13.1	12.8	12.5	14.0	15.5	17.1	18.9
	10%	DB	37.6	36.3	33.1	28.0	23.3	18.6	17.5	19.0	23.2	28.3	32.3	35.2
		MCWB	19.4	19.4	18.5	17.0	15.0	12.7	12.2	11.8	13.4	15.0	16.6	18.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.9	23.2	20.8	19.1	17.3	17.5	16.4	17.2	19.0	20.7	22.2
		MCDB	30.6	30.2	29.0	27.3	24.8	20.9	19.3	22.1	25.4	29.1	31.8	31.4
	2%	WB	22.8	23.6	21.6	19.7	17.8	15.7	15.0	15.0	16.1	17.6	19.2	21.1
		MCDB	33.9	30.2	28.8	26.5	22.6	19.3	17.6	19.6	24.3	28.5	30.8	33.2
	5%	WB	21.6	22.6	20.7	18.9	17.0	14.6	13.8	13.9	15.1	16.6	18.1	20.2
		MCDB	34.5	31.3	29.5	25.8	21.9	18.1	17.0	18.9	22.6	27.4	30.6	33.2
	10%	WB	20.7	21.4	19.8	18.2	16.1	13.6	12.9	12.9	14.3	15.6	17.2	19.4
		MCDB	34.2	30.8	28.9	24.9	21.2	17.3	16.2	17.1	21.2	26.2	29.6	32.7
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	13.9	13.6	12.8	12.5	11.6	11.6	12.7	14.3	14.5	14.2	14.1
		MCDBR	16.5	16.9	16.7	15.5	14.9	14.2	14.0	16.6	17.4	17.8	16.9	16.1
	5% WB	MCWBR	5.2	4.9	5.5	5.7	6.3	7.5	7.8	8.2	7.2	6.3	6.0	5.6
		MCWBR	14.1	11.1	12.7	12.0	11.1	10.7	10.5	13.5	14.4	15.1	15.1	13.0
(40) Clear-Sky Solar Irradiance	taub	0.332	0.338	0.320	0.306	0.289	0.279	0.276	0.281	0.300	0.308	0.316	0.320	0.320
		taud	2.599	2.606	2.634	2.645	2.658	2.673	2.679	2.654	2.557	2.558	2.566	2.592
	Ebn at Noon	1008	985	973	939	913	901	919	954	977	1004	1019	1023	1023
		Edh at Noon	104	100	92	82	73	68	70	80	98	104	107	105
(44) All-Sky Solar Radiation	RadAvg	8.06	7.26	6.26	4.92	3.86	3.26	3.50	4.48	5.89	7.13	8.00	8.42	8.42
	RadStd	0.48	0.45	0.42	0.22	0.26	0.22	0.18	0.17	0.25	0.34	0.34	0.41	0.41

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page