

MOUNT MAGNET, AustraliaWMO: **944290**Lat: **28.1156S**Lon: **117.8425E**Elev: **409**StdP: **96.51**Time Zone: **8.00 (E08)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	5.6	-8.2	2.0	21.5	-6.7	2.3	20.9	10.7	17.8	9.8	18.1	1.7	120	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	41.3	19.5	39.9	19.3	38.6	19.0	23.7	30.6	22.9	31.0	22.0	31.3	5.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.1	17.6	26.5	20.6	16.1	26.4	19.2	14.7	26.0	73.4	30.1	69.9	30.7	66.5	31.2	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.1	8.3	DB	1.9	43.9	0.7	1.6	1.4	45.0	1.0	46.0	0.6	46.9	0.1	48.0	(4)
(5)			WB	0.1	24.3	0.9	1.3	-0.5	25.2	-1.1	26.0	-1.6	26.8	-2.3	27.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	30.4	29.6	26.6	22.4	17.6	14.1	13.1	14.7	17.4	21.9	25.4	28.2	(6)
(7)		DBStd	6.91	3.73	3.46	3.71	3.33	3.08	2.65	2.49	2.89	3.36	3.65	3.96	3.78	(7)
(8)		HDD10.0	6	0	0	0	0	0	2	3	1	0	0	0	0	(8)
(9)		HDD18.3	538	0	0	1	7	51	129	164	119	57	9	2	0	(9)
(10)		CDD10.0	4288	634	549	513	371	237	124	98	146	221	368	462	566	(10)
(11)		CDD18.3	1779	376	316	256	128	29	2	1	6	28	118	213	307	(11)
(12)		CDH23.3	24079	5658	4492	3147	1243	259	19	11	106	419	1472	2836	4418	(12)
(13)	CDH26.7	13691	3658	2737	1682	502	51	1	0	17	139	676	1555	2673	(13)	
(14)	Wind	WSAvg	4.4	5.1	4.9	4.8	3.9	3.7	3.6	3.9	4.4	4.7	5.1	5.1	(14)	
(15)	Precipitation	PrecAvg	262	23	36	22	25	28	36	34	18	10	12	15	(15)	
(16)		PrecMax	602	158	209	183	213	101	126	104	77	45	68	68	86	(16)
(17)		PrecMin	102	0	0	0	0	0	4	2	1	0	0	0	0	(17)
(18)		PrecStd	116	35	53	37	35	28	30	29	14	10	15	15	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	42.8	39.4	35.6	30.3	25.5	24.7	28.9	32.8	36.7	40.0	41.5	(19)
(20)			MCWB	20.0	19.3	18.8	18.1	16.1	13.9	13.4	13.4	14.8	16.6	17.7	19.1	(20)
(21)		2%	DB	41.9	40.7	37.9	33.6	28.1	23.3	22.6	26.3	30.4	34.7	38.1	40.0	(21)
(22)			MCWB	19.7	19.8	18.6	17.2	15.4	12.7	12.2	13.1	14.1	16.1	17.3	18.8	(22)
(23)		5%	DB	40.3	38.9	36.2	31.7	26.2	21.7	20.8	24.0	28.0	32.8	36.3	38.5	(23)
(24)			MCWB	19.6	19.5	18.8	16.6	14.6	12.2	11.6	12.2	13.6	15.5	17.0	18.6	(24)
(25)		10%	DB	38.7	37.2	34.4	29.7	24.4	20.1	19.1	21.8	25.5	30.7	34.3	36.8	(25)
(26)			MCWB	19.6	19.6	18.6	16.3	14.1	11.8	11.4	11.8	12.8	15.0	16.6	18.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	25.1	23.0	20.7	18.6	17.1	16.2	16.2	16.8	18.5	20.0	22.6	(27)
(28)			MCDWB	32.0	30.3	29.5	27.9	23.8	20.3	19.6	21.0	24.0	29.8	33.0	32.5	(28)
(29)		2%	WB	23.7	24.0	22.0	19.7	17.4	15.6	14.7	14.8	15.6	17.5	18.9	21.2	(29)
(30)			MCDWB	31.7	29.1	28.3	27.1	23.1	19.2	18.5	20.9	25.8	29.2	32.0	33.1	(30)
(31)		5%	WB	23.0	23.1	21.1	18.9	16.4	14.6	13.5	13.8	14.8	16.8	18.2	20.4	(31)
(32)			MCDWB	31.8	30.2	28.7	26.1	22.8	18.4	17.5	20.5	24.8	28.3	31.6	32.5	(32)
(33)		10%	WB	22.1	22.2	20.3	17.9	15.5	13.4	12.5	12.9	13.9	16.0	17.5	19.6	(33)
(34)			MCDWB	32.0	31.2	29.2	26.0	22.2	17.8	17.2	19.9	23.6	27.8	30.8	32.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.3	12.3	11.7	11.8	11.7	10.9	11.1	12.4	13.4	13.9	13.7	13.6	(35)
(36)			MCDBR	15.0	14.5	13.8	14.4	13.8	13.3	13.7	16.0	17.0	16.5	15.7	14.8	(36)
(37)			MCWBR	4.7	4.2	4.5	5.4	5.6	6.4	6.6	6.9	6.6	6.1	5.4	4.9	(37)
(38)		5% WB	MCDWR	12.1	11.2	11.1	10.9	10.6	9.1	9.9	11.6	13.9	13.7	14.1	13.0	(38)
(39)			MCWBR	4.0	3.9	4.2	4.5	4.8	5.3	5.8	5.9	5.6	5.3	4.8	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.339	0.323	0.308	0.289	0.278	0.275	0.281	0.297	0.308	0.316	0.322	(40)	
(41)		taud	2.581	2.591	2.606	2.622	2.632	2.655	2.652	2.617	2.541	2.530	2.543	2.569	(41)	
(42)		Ebn at Noon	1007	986	972	941	917	907	924	957	983	1005	1019	1022	(42)	
(43)		Edh at Noon	106	102	95	85	76	70	73	84	100	107	110	108	(43)	
(44)	All-Sky Solar Radiation	RadAvg	8.05	7.29	6.31	5.05	4.04	3.45	3.72	4.76	6.16	7.26	8.08	8.41	(44)	
(45)		RadStd	0.47	0.42	0.47	0.22	0.25	0.20	0.20	0.18	0.20	0.36	0.32	0.40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page