

MEEKATHARRA, Australia

WMO: 944300

Lat: 26.6136S

Lon: 118.5372E

Elev: 519

StdP: 95.24

Time Zone: 8.00 (E08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	6.5	-14.2	1.2	27.4	-11.6	1.5	24.9	9.2	16.5	8.3	16.3	2.7	90	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	41.4	18.5	40.1	18.3	38.8	17.9	23.6	29.4	22.8	29.3	22.0	29.5	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	18.0	25.8	21.1	16.8	25.8	19.8	15.4	25.9	73.6	29.1	70.3	29.3	67.1	29.0	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.3	7.6	DB	2.6	43.4	1.1	1.3	1.8	44.3	1.2	45.1	0.6	45.9	-0.1	46.8	(4)
(5)			WB	0.6	26.7	0.8	3.5	0.0	29.3	-0.5	31.3	-0.9	33.3	-1.5	35.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	31.4	29.8	26.8	23.0	18.5	14.5	13.6	15.7	18.9	23.2	26.2	29.2	(6)	
	DBStd	6.81	3.51	3.47	3.67	3.20	3.24	2.60	2.49	2.98	3.35	3.50	3.71	3.46	(7)	
	HDD10.0	2	0	0	0	0	0	1	2	0	0	0	0	0	(8)	
	HDD18.3	438	0	0	1	3	39	117	147	94	33	3	1	0	(9)	
	CDD10.0	4577	662	555	522	389	262	137	114	176	268	411	487	594	(10)	
	CDD18.3	1971	404	322	263	143	43	3	1	12	51	156	237	336	(11)	
	CDH23.3	26381	6237	4566	3242	1352	336	19	13	156	643	1864	3107	4847	(12)	
(13)	CDH26.7	15058	4104	2779	1739	556	78	1	1	28	215	880	1711	2967	(13)	
(14)	Wind	WSAvg	4.1	4.7	4.6	4.4	3.7	3.6	3.5	3.4	3.6	4.1	4.4	4.6	4.6	(14)
(15) Precipitation	PrecAvg	246	30	37	29	22	23	29	23	11	4	6	12	17	(15)	
	PrecMax	567	138	172	257	159	96	187	166	56	41	62	113	111	(16)	
	PrecMin	71	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	110	37	42	48	28	25	36	27	11	8	12	22	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	43.0	39.1	35.1	31.1	25.4	25.1	29.3	32.7	37.5	39.7	41.7	(19)	
		MCWB	18.9	17.9	18.0	17.2	15.4	13.4	11.6	13.0	13.9	15.8	16.8	18.2	(20)	
	2%	DB	41.7	41.0	37.6	33.3	28.8	23.5	23.1	27.3	31.1	35.2	38.1	40.4	(21)	
		MCWB	18.8	18.4	17.6	16.3	14.6	12.5	11.0	12.4	13.5	15.1	16.6	17.9	(22)	
	5%	DB	40.5	39.3	36.3	31.8	27.0	22.0	21.5	25.0	29.3	33.6	36.4	38.8	(23)	
		MCWB	18.6	18.3	17.7	16.0	14.3	11.8	10.9	11.9	13.1	14.8	16.3	17.5	(24)	
	10%	DB	39.1	37.4	34.4	30.1	25.1	20.4	19.8	23.0	27.3	31.7	34.6	37.2	(25)	
		MCWB	18.4	18.4	17.7	15.8	13.7	11.5	10.6	11.1	12.6	14.4	16.0	17.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	24.7	23.2	20.8	18.7	17.1	16.3	15.9	16.6	18.9	20.7	23.1	(27)	
		MCDB	31.0	29.4	27.9	26.6	23.3	19.9	20.0	21.9	24.6	29.5	29.8	30.3	(28)	
	2%	WB	23.4	23.7	21.8	19.7	17.4	15.7	14.3	14.6	15.3	17.5	18.7	21.7	(29)	
		MCDB	30.1	28.9	26.8	25.6	22.6	19.3	17.7	21.0	25.5	27.0	29.7	29.0	(30)	
	5%	WB	22.6	23.0	20.9	18.9	16.5	14.5	13.2	13.4	14.4	16.4	17.9	20.7	(31)	
		MCDB	30.3	28.9	27.5	25.6	22.4	18.5	17.1	21.3	25.4	28.1	30.8	29.9	(32)	
	10%	WB	21.7	22.3	19.9	18.0	15.5	13.4	12.2	12.3	13.6	15.5	17.2	19.6	(33)	
		MCDB	31.4	29.0	28.9	25.1	22.0	17.7	17.0	20.7	24.9	28.5	30.4	31.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	11.6	11.3	11.3	11.1	10.8	11.3	12.7	13.8	13.6	13.2	13.0	(35)	
		MCDBR	14.0	13.9	13.5	13.6	12.8	12.7	13.6	15.1	16.3	15.9	14.6	14.4	(36)	
		MCWBR	4.5	4.3	4.2	4.8	4.9	5.4	6.0	6.4	6.1	5.6	4.8	4.8	(37)	
	5% WB	MCDBR	11.7	9.8	10.0	10.0	9.8	8.9	9.4	12.3	13.6	13.1	13.5	12.5	(38)	
		MCWBR	4.1	3.3	3.8	4.2	4.3	4.8	5.3	6.1	5.5	5.0	4.8	4.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.341	0.327	0.311	0.289	0.276	0.275	0.278	0.297	0.313	0.321	0.325	(40)	
	taud		2.565	2.591	2.595	2.611	2.621	2.647	2.629	2.604	2.521	2.502	2.517	2.559	(41)	
	Ebn at Noon		1001	986	970	942	922	917	930	965	986	1002	1015	1019	(42)	
	Edh at Noon		108	103	97	87	78	72	76	86	102	111	113	109	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.88	7.25	6.27	5.15	4.24	3.68	4.00	5.12	6.48	7.37	8.08	8.36	(44)	
	RadStd		0.53	0.40	0.43	0.21	0.27	0.21	0.27	0.22	0.17	0.40	0.35	0.45	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page