

LEONORA, Australia

WMO: 944480

Lat: 28.884S

Lon: 121.330E

Elev: 380

StdP: 96.84

Time Zone: 8.00 (E08)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	4.8	-3.6	2.9	18.5	-2.3	3.2	18.3	12.2	16.6	10.2	18.1	0.6	90	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	41.0	20.3	39.4	20.1	37.8	19.8	24.9	31.4	23.6	31.1	22.5	30.7	2.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.3	18.9	28.3	21.8	17.3	26.6	20.1	15.5	26.1	78.3	31.2	72.8	31.0	68.1	29.9	35.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.4	7.8	1.0	43.6	0.8	1.3	0.4	44.5	-0.1	45.3	-0.5	46.1	-1.1	47.0		
(5)			0.4	27.8	0.9	3.3	-0.3	30.1	-0.8	32.1	-1.3	33.9	-2.0	36.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	29.2	27.5	23.9	20.6	16.7	13.0	12.5	13.7	17.8	20.8	24.3	27.4	(6)	(7)
	DBStd	6.74	3.95	4.16	4.32	3.08	3.63	2.71	2.72	3.34	3.56	3.58	4.03	4.14	(7)	(8)
	HDD10.0	13	0	0	0	0	0	4	7	2	0	0	0	0	(8)	(9)
	HDD18.3	660	0	0	4	13	77	162	182	150	53	16	2	1	(9)	(10)
	CDD10.0	3874	596	491	430	318	208	93	85	118	233	333	430	538	(10)	(11)
	CDD18.3	1478	337	258	176	82	27	1	1	8	36	91	182	281	(11)	(12)
	CDH23.3	18733	4880	3441	1989	696	206	8	9	84	455	1057	2162	3746	(12)	(13)
	CDH26.7	10216	3056	2013	1006	222	44	1	1	18	137	438	1094	2187	(13)	(14)
(14) Wind	WSAvg	2.1	2.4	2.3	2.2	1.5	1.5	1.6	1.7	1.9	2.3	2.7	2.8	2.7	(14)	(15)
(15) Precipitation	PrecAvg	249	19	42	27	21	27	26	23	16	10	13	14	19	(15)	(16)
	PrecMax	552	128	285	179	101	110	100	102	79	47	56	52	94	(16)	(17)
	PrecMin	94	0	0	0	0	0	0	0	0	0	0	0	0	(17)	(18)
	PrecStd	109	28	59	39	23	28	24	26	18	11	16	13	22	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	44.0	39.9	33.6	30.0	24.1	24.4	29.2	32.8	36.8	39.2	41.8	(19)	(20)
		MCWB	20.9	20.9	20.6	17.7	16.2	14.7	13.2	15.0	16.0	17.1	18.9	19.8	(20)	(21)
	2%	DB	41.2	40.7	37.3	31.2	27.6	22.0	22.4	25.6	30.1	34.2	36.7	39.6	(21)	(22)
		MCWB	20.5	20.4	19.8	17.4	15.8	13.4	12.4	13.7	15.1	17.6	18.6	19.4	(22)	(23)
	5%	DB	39.6	38.5	34.9	29.4	25.6	20.4	20.5	23.0	28.1	31.8	34.9	37.9	(23)	(24)
		MCWB	20.3	20.6	19.6	17.6	15.7	12.7	12.3	12.9	14.7	16.7	18.3	19.4	(24)	(25)
	10%	DB	37.8	36.1	32.3	27.5	23.4	18.8	18.7	20.8	25.9	29.3	32.7	36.0	(25)	(26)
		MCWB	20.1	20.4	19.5	17.1	15.0	12.6	11.8	12.0	14.1	15.5	17.6	19.3	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	26.5	25.3	22.5	19.2	17.5	16.3	16.1	17.6	28.5	22.2	26.9	(27)	(28)
		MCDB	34.9	33.0	30.5	26.9	24.6	20.2	19.3	24.3	26.2	29.3	31.4	33.4	(28)	(29)
	2%	WB	23.3	25.1	23.1	20.6	18.0	15.7	14.6	14.9	16.4	18.7	20.2	23.5	(29)	(30)
		MCDB	34.8	31.5	28.3	25.9	24.4	19.2	19.0	22.5	26.8	28.8	31.7	30.3	(30)	(31)
	5%	WB	22.4	24.1	21.7	19.4	17.0	14.6	13.4	13.6	15.5	17.1	19.3	21.5	(31)	(32)
		MCDB	33.8	31.0	28.3	24.9	22.2	18.2	18.2	21.5	25.8	28.5	31.4	32.2	(32)	(33)
	10%	WB	21.4	22.9	20.6	18.5	16.1	13.3	12.6	12.5	14.7	16.1	18.4	20.2	(33)	(34)
		MCDB	33.5	29.5	29.4	23.9	21.2	17.3	17.2	19.8	24.5	27.8	30.0	32.8	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	12.3	11.5	11.5	11.1	10.9	11.4	12.6	14.1	13.5	12.6	12.7	(35)	(36)
		MCDBR	15.3	16.1	15.0	14.4	13.5	12.9	14.2	15.2	16.9	17.3	14.8	14.8	(36)	(37)
	5% WB	MCWBR	4.7	5.1	5.3	5.6	5.7	6.3	7.1	7.3	6.7	7.0	5.2	5.4	(37)	(38)
		MCWBR	13.5	11.5	11.7	10.9	10.3	9.8	10.8	13.0	14.8	14.3	13.5	13.3	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.341	0.344	0.324	0.311	0.289	0.278	0.276	0.283	0.300	0.321	0.328	0.330	(39)	(40)
		taud	2.580	2.591	2.622	2.630	2.654	2.666	2.661	2.619	2.557	2.514	2.530	2.568	(40)	(41)
	Ebn at Noon		1000	980	969	935	914	904	921	953	978	992	1006	1013	(41)	(42)
		Edh at Noon	106	102	93	84	74	69	72	83	98	109	111	108	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		7.79	6.93	6.01	4.87	3.92	3.31	3.65	4.71	6.08	7.07	7.82	8.19	(43)	(44)
	RadStd		0.62	0.57	0.43	0.26	0.25	0.21	0.24	0.26	0.24	0.44	0.34	0.46	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page