

WARBURTON, Australia

WMO: 944570

Lat: 26.132S

Lon: 126.584E

Elev: 460

StdP: 95.93

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.4	3.9	-12.6	1.3	22.5	-10.9	1.6	21.3	9.3	18.8	8.6	18.3	1.2	130	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	42.1	19.0	40.7	18.7	39.3	18.5	24.3	29.3	23.5	29.5	22.6	30.0	5.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.0	26.0	21.9	17.6	25.9	20.5	16.1	26.1	76.2	29.4	72.8	29.1	69.2	29.9	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	9.5	8.5	DB	-0.2	43.9	1.6	1.2	-1.4	44.8	-2.3	45.5	-3.2	46.2	-4.3	47.1
			WB	-2.4	24.9	1.7	1.4	-3.6	25.9	-4.6	26.7	-5.5	27.5	-6.8	28.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	31.0	29.8	27.3	23.2	17.6	13.6	13.6	15.6	20.2	25.6	27.4	29.6
	DBStd	7.23	3.85	4.07	3.84	3.47	3.48	2.81	3.11	3.49	4.01	4.17	3.82	3.67
	HDD10.0	8	0	0	0	0	0	3	4	1	0	0	0	0
	HDD18.3	485	0	1	1	4	56	144	151	100	26	3	0	0
	CDD10.0	4693	652	554	535	397	237	111	115	176	306	482	522	607
	CDD18.3	2129	393	321	277	151	34	2	4	16	82	227	272	349
	CDH23.3	28694	5868	4595	3494	1545	364	26	74	268	1077	2880	3583	4919
	CDH26.7	16666	3802	2871	1951	681	103	1	9	58	474	1597	2079	3040
(14) Wind	WSAvg	4.6	5.5	5.4	5.1	4.3	3.8	3.8	3.5	3.9	4.3	4.9	5.0	5.1
(15) Precipitation	PrecAvg	328	32	49	39	23	16	13	12	7	7	21	40	63
	PrecMax	631	127	155	154	84	93	76	49	49	57	81	116	232
	PrecMin	134	0	0	0	3	2	0	1	3	0	0	1	4
	PrecStd	129	34	47	48	22	23	18	13	11	14	25	30	57
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.5	42.5	40.6	36.4	32.4	25.7	28.0	30.6	35.5	39.6	40.9	43.8
		MCWB	20.4	18.7	18.7	17.9	15.5	13.2	13.6	13.7	15.4	16.6	17.8	19.5
	2%	DB	42.2	41.2	38.5	34.6	29.5	23.9	25.3	28.3	33.6	37.9	39.3	41.4
		MCWB	19.4	18.6	18.4	17.2	14.7	12.7	12.3	13.0	14.7	16.4	17.5	18.8
	5%	DB	40.7	39.8	37.0	32.7	27.2	22.1	23.4	26.4	31.7	36.4	37.7	39.6
		MCWB	19.1	18.7	18.4	16.6	14.0	11.5	11.6	12.3	14.2	16.1	17.5	18.6
	10%	DB	39.0	38.0	35.2	30.7	25.1	20.4	21.4	24.4	29.6	34.5	35.8	37.7
		MCWB	19.1	19.1	18.3	16.3	13.4	11.1	10.9	11.6	13.6	15.7	17.1	18.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	25.2	24.1	21.1	18.4	17.6	16.2	15.7	17.5	20.0	21.6	24.1
		MCDB	29.3	31.1	27.4	27.5	21.9	20.2	20.5	24.7	26.1	27.8	31.3	26.9
	2%	WB	24.5	24.2	23.2	19.7	17.0	15.5	14.3	14.3	16.3	18.9	20.7	23.1
		MCDB	29.3	30.5	28.8	26.6	21.9	18.2	21.4	24.9	29.1	28.6	30.2	29.4
	5%	WB	23.4	23.5	22.1	18.9	16.0	13.7	13.0	13.2	15.2	18.1	19.9	22.2
		MCDB	30.0	29.8	28.9	26.3	23.1	18.6	21.2	24.2	28.6	28.6	29.3	29.8
	10%	WB	22.3	22.4	21.0	18.1	14.9	12.4	11.8	12.1	14.2	17.2	19.1	21.4
		MCDB	31.7	30.0	29.7	26.0	22.8	18.1	20.1	22.7	27.8	30.0	29.2	30.1
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.3	12.4	13.0	13.2	13.1	14.6	15.8	15.4	14.0	13.4	12.9
		MCDBR	14.1	14.0	14.3	14.8	15.3	15.3	17.0	17.8	17.7	15.9	15.0	14.9
	5% WB	MCWBR	4.1	4.4	4.6	5.0	6.2	7.3	8.0	7.9	7.3	5.8	4.7	4.7
		MCDWR	10.4	10.9	10.7	10.9	10.9	10.2	14.7	15.4	14.9	12.9	13.4	11.9
(40) Clear-Sky Solar Irradiance	taub		0.354	0.355	0.346	0.334	0.308	0.293	0.298	0.303	0.333	0.348	0.354	0.353
		taud	2.548	2.564	2.559	2.547	2.559	2.591	2.542	2.507	2.442	2.428	2.470	2.531
	Ebn at Noon		989	972	952	917	901	897	903	937	949	967	982	992
		Edh at Noon	110	106	101	93	84	77	84	95	111	120	118	112
(44) All-Sky Solar Radiation	RadAvg		7.67	7.03	6.23	5.12	4.30	3.79	4.10	5.23	6.40	7.12	7.54	7.64
	RadStd		0.59	0.60	0.38	0.27	0.32	0.28	0.25	0.26	0.29	0.42	0.33	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page