

GILES, Australia

WMO: 944610

Lat: 25.0342S

Lon: 128.3011E

Elev: 1965

StdP: 13.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	40.0	42.4	-6.9	4.1	80.7	0.4	6.0	77.9	20.4	62.8	18.6	61.4	7.8	110	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	104.4	63.9	102.3	63.7	100.3	63.6	73.8	83.4	72.7	83.4	71.5	83.5	11.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	126.1	77.2	69.9	118.5	77.5	67.9	110.2	77.8	39.0	83.1	37.8	82.8	36.7	83.2	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	19.8	18.1	DB	35.1	108.1	2.2	1.9	33.5	109.4	32.2	110.5	31.0	111.6	29.5	113.0	(4)
(5)			WB	30.8	75.7	1.9	1.9	29.4	77.1	28.3	78.2	27.3	79.2	25.9	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	86.6	85.0	81.0	73.9	63.7	57.3	57.6	61.2	70.0	77.0	80.6	83.7	(6)
(7)		DBStd	12.19	5.60	6.30	6.31	6.07	6.21	5.52	5.65	6.41	7.28	7.33	6.86	6.22	(7)
(8)		HDD50	8	0	0	0	0	0	3	4	1	0	0	0	0	(8)
(9)		HDD65	790	0	0	1	7	102	241	240	154	36	7	2	0	(9)
(10)		CDD50	8430	1136	981	960	718	425	222	239	349	600	837	917	1046	(10)
(11)		CDD65	3735	671	561	496	275	62	10	9	37	186	378	469	581	(11)
(12)		CDH74	49209	9839	7884	6237	2855	535	55	85	408	2227	4835	6214	8035	(12)
(13)		CDH80	27203	6128	4729	3366	1172	111	4	4	70	909	2492	3478	4740	(13)
(14)	Wind	WSAvg	9.9	10.6	10.7	10.3	9.4	8.6	8.5	8.4	9.3	10.1	10.9	10.8	11.0	(14)
(15)	Precipitation	PrecAvg	10.9	1.2	1.5	1.5	0.6	0.8	0.7	0.4	0.4	0.4	0.6	1.1	1.9	(15)
(16)		PrecMax	35.1	4.8	11.7	13.0	4.8	3.7	4.5	2.2	3.0	2.6	3.0	5.4	13.3	(16)
(17)		PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.7	1.2	2.1	2.4	1.1	1.1	0.9	0.6	0.6	0.6	0.8	1.2	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.3	105.5	102.9	96.1	86.4	79.7	80.0	85.4	94.0	100.6	103.5	107.4	(19)
MCWB			64.5	64.0	63.3	60.9	56.9	55.7	53.2	54.8	57.1	59.6	62.4	64.6	(20)	
2%		DB	104.6	103.1	99.3	92.8	83.3	74.9	76.4	81.9	91.2	97.8	100.6	103.3	(21)	
		MCWB	64.8	63.6	63.5	60.6	56.1	54.7	52.4	53.6	56.7	59.3	61.8	63.1	(22)	
5%		DB	102.2	101.0	96.6	89.9	79.8	71.6	73.0	78.6	88.7	95.3	98.0	100.4	(23)	
		MCWB	64.9	63.9	63.3	60.2	55.4	52.7	51.1	52.4	55.9	58.9	61.1	63.1	(24)	
10%		DB	99.7	98.3	94.0	86.8	76.6	68.6	70.0	75.4	85.5	92.2	95.0	97.3	(25)	
		MCWB	65.0	64.3	62.7	59.3	54.2	51.0	49.7	51.1	55.1	58.2	61.0	63.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.5	75.3	74.2	68.8	63.7	63.0	60.5	59.5	63.0	66.5	69.9	73.7	(27)
MCD B			83.9	83.4	82.2	78.9	69.9	68.6	68.9	75.1	78.1	81.8	82.9	82.7	(28)	
2%		WB	73.8	73.8	72.3	66.4	61.1	59.5	57.1	56.8	60.6	64.7	67.7	72.0	(29)	
		MCD B	84.4	83.3	80.8	77.7	69.7	68.5	67.5	73.6	80.3	80.3	83.0	82.0	(30)	
5%		WB	72.4	72.7	70.5	64.2	59.3	56.7	54.3	54.7	58.7	63.3	66.0	70.5	(31)	
		MCD B	84.9	83.5	81.0	79.1	71.0	66.0	66.6	73.6	80.4	79.9	83.7	83.3	(32)	
10%		WB	71.0	71.5	68.8	62.4	57.2	54.0	52.1	52.7	56.8	61.7	64.6	69.0	(33)	
		MCD B	85.7	83.8	81.9	79.0	72.3	64.6	66.7	71.5	81.4	81.3	84.4	84.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.2	21.1	21.2	21.5	21.5	20.7	21.8	23.7	25.0	24.1	23.4	22.2	(35)
MCDBR			24.1	23.8	23.4	23.4	23.2	22.0	23.9	25.5	26.7	25.8	25.2	24.9	(36)	
MCWBR			7.7	7.3	7.9	7.8	9.1	10.0	10.4	10.7	9.8	8.8	8.0	7.8	(37)	
5% WB		MCDBR	19.4	17.5	17.7	19.4	17.9	16.1	19.4	22.6	24.0	22.1	22.8	20.2	(38)	
		MCWBR	6.5	6.1	6.6	7.1	8.4	8.5	9.7	10.6	9.6	8.0	7.7	7.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.350	0.341	0.327	0.302	0.287	0.292	0.301	0.334	0.347	0.354	0.353	(40)	
taud		2.540	2.557	2.557	2.546	2.560	2.590	2.547	2.489	2.422	2.421	2.462	2.523	(41)		
Ebn at Noon		314	310	304	294	289	288	290	298	301	308	312	314	(42)		
Edh at Noon		35	34	32	30	27	25	27	31	36	38	38	36	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2439	2265	1990	1695	1409	1249	1348	1702	2048	2291	2384	2383	(44)	
(45)		RadStd	159	180	131	120	109	104	93	78	94	133	100	153	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.57	N/A	N/A	N/A	N/A	N/A	+308
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page