

GILES, Australia

WMO: 944610

Lat: 25.0342S

Lon: 128.3011E

Elev: 599

StdP: 94.33

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	4.4	5.8	-21.6	0.6	27.1	-17.6	0.9	25.5	9.1	17.1	8.3	16.4	3.5	110	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	40.2	17.7	39.1	17.6	37.9	17.5	23.2	28.6	22.6	28.5	21.9	28.6	4.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	18.0	25.1	21.1	16.9	25.3	19.9	15.7	25.5	72.8	28.4	70.1	28.2	67.4	28.5	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.8	8.1	1.7	42.3	1.2	1.0	0.8	43.0	0.1	43.6	-0.5	44.2	-1.4	45.0		
			-0.7	24.3	1.0	1.0	-1.4	25.0	-2.0	25.6	-2.6	26.2	-3.4	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	30.4	29.5	27.2	23.3	17.6	14.1	14.2	16.2	21.1	25.0	27.0	28.7
	DBStd	6.77	3.11	3.50	3.51	3.37	3.45	3.07	3.14	3.56	4.05	4.07	3.81	3.45
	HDD10.0	4	0	0	0	0	0	2	2	1	0	0	0	0
	HDD18.3	439	0	0	1	4	57	134	133	86	20	4	1	0
	CDD10.0	4683	631	545	533	399	236	123	133	194	333	465	509	581
	CDD18.3	2075	373	312	276	153	34	6	5	21	103	210	261	323
	CDH23.3	27338	5466	4380	3465	1586	297	31	47	227	1237	2686	3452	4464
	CDH26.7	15113	3404	2627	1870	651	62	2	2	39	505	1384	1932	2633
Wind	WSAvg	4.4	4.8	4.8	4.6	4.2	3.8	3.8	3.8	4.2	4.5	4.9	4.8	4.9
Precipitation	PrecAvg	276	31	39	37	16	20	17	10	9	11	14	29	47
	PrecMax	892	122	297	331	121	93	115	55	77	65	75	136	338
	PrecMin	38	0	0	0	0	0	0	0	0	0	0	0	1
	PrecStd	145	31	54	60	27	27	24	15	15	16	20	30	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	40.8	39.4	35.6	30.2	26.5	26.7	29.7	34.5	38.1	39.7	41.9
		MCWB	18.1	17.8	17.4	16.1	13.9	13.2	11.8	12.7	13.9	15.3	16.9	18.1
	2%	DB	40.4	39.5	37.4	33.8	28.5	23.8	24.7	27.7	32.9	36.5	38.1	39.6
		MCWB	18.2	17.5	17.5	15.9	13.4	12.6	11.3	12.0	13.7	15.1	16.6	17.3
	5%	DB	39.0	38.3	35.9	32.1	26.6	22.0	22.8	25.9	31.5	35.2	36.7	38.0
		MCWB	18.3	17.7	17.4	15.7	13.0	11.5	10.6	11.3	13.3	14.9	16.2	17.3
	10%	DB	37.6	36.9	34.5	30.5	24.8	20.3	21.1	24.1	29.7	33.5	35.0	36.3
		MCWB	18.3	17.9	17.1	15.2	12.3	10.5	9.9	10.6	12.9	14.6	16.1	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.1	23.5	20.4	17.6	17.2	15.8	15.3	17.2	19.2	21.0	23.2
		MCDB	28.8	28.6	27.9	26.0	21.1	20.4	20.5	24.0	25.6	27.7	28.3	28.1
	2%	WB	23.2	23.2	22.4	19.1	16.2	15.3	13.9	13.8	15.9	18.1	19.8	22.2
		MCDB	29.1	28.5	27.1	25.4	21.0	20.3	19.7	23.1	26.9	26.9	28.3	27.8
	5%	WB	22.5	22.6	21.4	17.9	15.1	13.7	12.4	12.6	14.8	17.4	18.9	21.4
		MCDB	29.4	28.6	27.2	26.2	21.7	18.9	19.2	23.1	26.9	26.6	28.7	28.5
	10%	WB	21.6	21.9	20.5	16.9	14.0	12.2	11.1	11.5	13.8	16.5	18.1	20.6
		MCDB	29.8	28.8	27.7	26.1	22.4	18.1	19.3	22.0	27.5	27.4	29.1	29.0
Mean Daily Temperature Range	5% DB	MDBR	12.3	11.7	11.8	11.9	12.0	11.5	12.1	13.2	13.9	13.4	13.0	12.3
		MCDBR	13.4	13.2	13.0	13.0	12.9	12.2	13.3	14.2	14.8	14.3	14.0	13.8
		MCWBR	4.3	4.1	4.4	4.3	5.1	5.6	5.8	5.9	5.4	4.9	4.4	4.4
	5% WB	MCDBR	10.8	9.7	9.8	10.8	9.9	8.9	10.8	12.5	13.4	12.3	12.7	11.2
		MCWBR	3.6	3.4	3.7	3.9	4.7	4.7	5.4	5.9	5.3	4.5	4.3	4.0
Clear-Sky Solar Irradiance	taub	0.352	0.350	0.341	0.327	0.302	0.287	0.292	0.301	0.334	0.347	0.354	0.353	
	taud	2.540	2.557	2.557	2.546	2.560	2.590	2.547	2.489	2.422	2.421	2.462	2.523	
	Ebn at Noon	991	978	959	928	912	909	915	941	950	970	983	991	
	Edh at Noon	111	107	102	94	84	78	84	98	114	121	119	113	
All-Sky Solar Radiation	RadAvg	7.69	7.14	6.27	5.34	4.44	3.94	4.25	5.37	6.46	7.22	7.51	7.51	
	RadStd	0.50	0.57	0.41	0.38	0.34	0.33	0.29	0.25	0.30	0.42	0.31	0.48	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.87	N/A	N/A	N/A	N/A	N/A	+171
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page