

YULARA, Australia

WMO: 944620

Lat: 25.190S

Lon: 130.974E

Elev: 1616

StdP: 13.86

Time Zone: 9.50 (AUC)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.8	38.1	5.4	7.7	79.0	10.0	9.7	75.5	21.2	65.7	19.0	62.6	5.3	190	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.8	106.0	65.8	103.8	65.5	101.7	65.3	74.7	85.9	73.3	85.6	71.8	86.3	11.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.2	126.6	78.5	70.2	117.8	79.0	67.7	107.9	78.2	39.6	85.4	38.1	85.1	36.7	85.7	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.9	17.3	31.5	109.8	2.4	1.9	29.8	111.1	28.4	112.2	27.1	113.3	25.3	114.7
			27.6	76.8	3.1	2.2	25.3	78.5	23.5	79.8	21.8	81.0	19.5	82.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.3	86.8	84.7	79.1	71.7	61.7	55.3	54.7	58.9	68.1	74.0	78.9	82.8	(6)
	DBStd	12.62	5.40	6.29	6.47	6.00	6.00	5.56	5.01	5.82	7.06	6.87	6.60	5.94	(7)
	HDD50	18	0	0	0	0	0	7	10	1	0	0	0	0	(8)
	HDD65	1044	0	0	2	12	142	298	322	206	50	10	2	0	(9)
	CDD50	7796	1140	971	903	652	362	167	155	278	542	742	868	1016	(10)
	CDD65	3347	675	551	440	214	39	7	2	18	142	288	419	552	(11)
	CDH74	47661	10348	8059	5775	2475	524	106	84	496	2185	4073	5755	7781	(12)
	CDH80	27406	6697	4978	3164	1055	147	21	8	135	1003	2186	3338	4674	(13)
(14) Wind	WSAvg	8.7	9.9	10.0	9.7	8.5	7.5	7.2	7.2	7.8	8.5	9.3	9.4	9.9	(14)
(15) Precipitation	PrecAvg	12.4	1.4	1.9	1.2	0.7	0.6	0.8	0.7	0.3	0.4	0.8	1.5	1.8	(15)
	PrecMax	32.6	3.7	13.6	8.4	3.7	3.8	5.9	3.0	1.2	2.9	4.1	4.3	8.5	(16)
	PrecMin	4.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	(17)
	PrecStd	7.5	1.0	3.0	2.0	1.1	1.1	1.3	0.9	0.4	0.6	1.2	1.2	2.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.9	107.4	102.8	97.2	89.2	82.6	80.7	88.9	96.1	101.9	106.1	106.9	(19)
		MCWB	67.6	66.1	66.4	64.4	60.6	58.6	56.8	58.9	60.9	61.8	63.2	65.2	(20)
	2%	DB	106.8	104.7	99.7	92.7	84.4	76.7	76.1	84.0	93.1	98.8	102.7	103.6	(21)
		MCWB	66.6	65.8	65.7	62.8	59.2	56.6	55.4	56.5	60.1	61.2	63.7	64.6	(22)
	5%	DB	104.3	102.4	97.1	89.5	80.0	72.1	72.5	79.8	90.1	95.6	99.3	101.0	(23)
		MCWB	66.6	65.7	64.9	61.3	57.5	54.4	53.2	54.6	58.6	60.8	63.2	64.6	(24)
	10%	DB	101.6	99.6	94.1	86.3	76.0	68.0	68.7	75.5	86.5	92.0	95.6	98.2	(25)
		MCWB	66.2	65.8	64.2	60.2	55.9	52.2	51.9	52.9	57.5	59.8	62.4	64.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	76.6	75.0	69.9	65.7	63.0	66.1	61.2	66.1	68.7	71.5	75.0	(27)
		MCDB	85.5	86.0	83.9	83.1	76.8	74.4	68.0	81.2	85.0	83.5	83.9	87.1	(28)
	2%	WB	74.2	74.9	72.8	67.5	62.6	59.7	60.0	58.8	63.2	66.0	69.0	72.8	(29)
		MCDB	85.9	86.3	83.0	80.2	74.1	71.5	68.6	76.7	82.6	83.1	85.4	85.9	(30)
	5%	WB	72.7	73.5	70.6	64.8	60.2	56.9	56.2	56.5	61.2	64.4	67.5	71.1	(31)
		MCDB	87.1	86.8	85.9	80.7	74.1	67.0	66.8	74.5	82.2	82.3	84.4	85.7	(32)
	10%	WB	71.0	71.8	68.7	62.6	58.1	54.4	53.3	54.5	59.2	62.6	66.2	69.7	(33)
		MCDB	89.5	85.5	86.6	80.9	72.2	63.8	66.6	72.4	81.7	83.5	83.3	84.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.8	23.5	24.1	25.3	25.3	24.4	26.0	29.4	30.2	28.9	26.8	25.1	(35)
		MCDBR	29.1	28.2	27.3	29.2	30.3	29.7	32.9	36.2	35.4	34.9	32.3	29.8	(36)
	5% WB	MCWBR	8.9	8.9	9.3	10.6	12.9	14.3	16.2	16.2	13.7	13.3	9.9	9.6	(37)
		MCWBR	22.4	19.2	20.0	22.2	23.6	22.8	24.9	29.4	29.1	26.3	25.0	22.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.354	0.353	0.339	0.323	0.299	0.285	0.288	0.300	0.337	0.351	0.357	0.357	(40)
		taud	2.523	2.533	2.551	2.553	2.572	2.594	2.564	2.496	2.415	2.411	2.455	2.505	(41)
	Ebn at Noon		313	309	305	296	290	289	292	299	300	306	311	313	(42)
		Edh at Noon	36	35	32	30	26	24	26	31	36	39	38	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2448	2294	2035	1720	1407	1251	1344	1687	2015	2274	2386	2390	(44)
	RadStd		158	202	141	121	115	102	99	75	103	147	100	157	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) -1.89	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	-1.89	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page