

YULARA, Australia

WMO: 944620

Lat: 25.190S

Lon: 130.974E

Elev: 493

StdP: 95.55

Time Zone: 9.50 (AUC)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 2.1	(c) 3.4	(d) -14.8	(e) 1.1	(f) 26.1	(g) -12.2	(h) 1.4	(i) 24.2	(j) 9.5	(k) 18.7	(l) 8.5	(m) 17.0	(n) 2.4	(o) 190	(p) 0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 14.3	(c) 41.1	(d) 18.8	(e) 39.9	(f) 18.6	(g) 38.7	(h) 18.5	(i) 23.7	(j) 29.9	(k) 22.9	(l) 29.8	(m) 22.1	(n) 30.2	(o) 4.9	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.3	18.1	25.8	21.2	16.8	26.1	19.8	15.4	25.7	74.1	29.7	70.8	29.5	67.5	29.8	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.4	8.5	7.7		-0.3	43.2	1.3	1.1	-1.2	44.0	-2.0	44.6	-2.7	45.2	-3.7	45.9	
			DB	-2.4	24.9	1.7	1.2	-3.7	25.8	-4.7	26.5	-5.7	27.2	-7.0	28.2	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.8	30.4	29.3	26.2	22.1	16.5	13.0	12.6	15.0	20.0	23.3	26.1	28.2
	DBStd	7.01	3.00	3.49	3.59	3.33	3.34	3.09	2.79	3.23	3.92	3.82	3.67	3.30
	HDD10.0	10	0	0	0	0	0	4	6	1	0	0	0	0
	HDD18.3	580	0	0	1	7	79	166	179	114	28	6	1	0
	CDD10.0	4331	633	539	502	362	201	93	86	154	301	412	482	564
	CDD18.3	1859	375	306	244	119	22	4	1	10	79	160	233	307
	CDH23.3	26478	5749	4477	3208	1375	291	59	47	276	1214	2263	3197	4323
	CDH26.7	15226	3721	2766	1758	586	82	12	4	75	557	1214	1854	2597
Wind	WSAvg	3.9	4.4	4.5	4.3	3.8	3.4	3.2	3.2	3.5	3.8	4.2	4.2	4.4
Precipitation	PrecAvg	314	35	48	31	17	15	21	17	8	10	21	39	46
	PrecMax	828	95	345	214	93	97	149	75	31	74	104	110	215
	PrecMin	101	3	1	0	0	0	0	0	1	2	0	1	0
	PrecStd	190	25	75	50	28	27	33	23	9	15	30	30	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.3	41.9	39.3	36.2	31.8	28.1	27.1	31.6	35.6	38.8	41.2	41.6
		MCWB	19.8	18.9	19.1	18.0	15.9	14.8	13.8	15.0	16.0	16.6	17.3	18.4
	2%	DB	41.6	40.4	37.6	33.7	29.1	24.8	24.5	28.9	33.9	37.1	39.3	39.8
		MCWB	19.2	18.8	18.7	17.1	15.1	13.7	13.0	13.6	15.6	16.2	17.6	18.1
	5%	DB	40.2	39.1	36.2	31.9	26.7	22.3	22.5	26.6	32.3	35.3	37.4	38.4
		MCWB	19.2	18.7	18.3	16.3	14.2	12.5	11.8	12.6	14.8	16.0	17.3	18.1
	10%	DB	38.7	37.6	34.5	30.2	24.4	20.0	20.4	24.2	30.3	33.3	35.4	36.8
		MCWB	19.0	18.8	17.9	15.7	13.3	11.2	11.0	11.6	14.2	15.4	16.9	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	24.8	23.9	21.1	18.7	17.2	19.0	16.2	18.9	20.4	21.9	23.9
		MCDB	29.7	30.0	28.8	28.4	24.9	23.5	20.0	27.3	29.5	28.6	28.8	30.6
	2%	WB	23.5	23.8	22.6	19.7	17.0	15.4	15.5	14.9	17.4	18.9	20.6	22.6
		MCDB	30.0	30.2	28.3	26.8	23.4	21.9	20.3	24.8	28.1	28.4	29.7	29.9
	5%	WB	22.6	23.1	21.5	18.2	15.6	13.8	13.4	13.6	16.2	18.0	19.7	21.7
		MCDB	30.6	30.4	29.9	27.1	23.4	19.4	19.3	23.6	27.9	28.0	29.1	29.9
	10%	WB	21.6	22.1	20.4	17.0	14.5	12.4	11.9	12.5	15.1	17.0	19.0	21.0
		MCDB	31.9	29.7	30.3	27.1	22.3	17.7	19.2	22.5	27.6	28.6	28.5	29.4
Mean Daily Temperature Range	5% DB	MDBR	14.3	13.1	13.4	14.0	14.1	13.6	14.5	16.3	16.8	16.1	14.9	14.0
		MCDBR	16.2	15.7	15.2	16.2	16.8	16.5	18.3	20.1	19.7	19.4	18.0	16.5
		MCWBR	5.0	5.0	5.2	5.9	7.2	7.9	9.0	9.0	7.6	7.4	5.5	5.3
	5% WB	MCDBR	12.4	10.7	11.1	12.3	13.1	12.7	13.8	16.4	16.2	14.6	13.9	12.6
		MCWBR	4.0	3.3	4.0	4.7	5.8	6.4	8.2	7.6	6.3	5.5	4.3	4.2
Clear-Sky Solar Irradiance	taub	0.354	0.353	0.339	0.323	0.299	0.285	0.288	0.300	0.337	0.351	0.357	0.357	
	taud	2.523	2.533	2.551	2.553	2.572	2.594	2.564	2.496	2.415	2.411	2.455	2.505	
	Ebn at Noon	988	975	960	933	915	910	919	942	946	965	979	988	
	Edh at Noon	113	109	102	93	83	77	83	97	115	122	120	115	
All-Sky Solar Radiation	RadAvg	7.72	7.23	6.42	5.42	4.44	3.94	4.24	5.32	6.35	7.17	7.52	7.54	
	RadStd	0.50	0.64	0.45	0.38	0.36	0.32	0.31	0.24	0.33	0.46	0.32	0.49	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-1.05	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	-1.05	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page