

PUKATJA, Australia

WMO: 944740

Lat: 26.2636S

Lon: 132.1772E

Elev: 704

StdP: 93.15

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	1.9	3.5	-14.8	1.1	23.6	-12.2	1.4	23.9	11.8	14.0	9.7	15.0	1.7	80	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	39.2	17.6	37.7	17.4	36.4	17.3	22.4	28.4	21.6	28.4	20.7	28.4	5.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.1	17.2	24.2	19.7	15.7	24.2	18.4	14.4	24.1	69.9	28.5	66.4	28.3	63.2	28.4	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	8.9	8.0	-1.4	40.9	1.1	1.5	-2.2	41.9	-2.9	42.8	-3.5	43.7	-4.3	44.8
			-3.1	23.1	1.1	1.1	-3.9	23.9	-4.5	24.6	-5.1	25.2	-5.9	26.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	28.6	27.4	24.7	20.7	15.2	11.5	11.8	13.8	18.4	22.2	24.7	26.4
	DBStd	6.92	3.61	3.40	3.66	3.38	3.18	2.74	3.00	3.38	4.27	4.28	3.95	3.94
	HDD10.0	29	0	0	0	0	1	12	13	4	0	0	0	0
	HDD18.3	747	1	0	2	14	107	205	202	146	53	14	3	1
	CDD10.0	3834	576	488	457	322	163	57	70	123	251	378	442	508
	CDD18.3	1509	318	256	201	85	11	1	1	6	54	133	194	250
	CDH23.3	18921	4396	3335	2284	833	107	7	21	109	663	1613	2368	3186
(13)	CDH26.7	9786	2571	1836	1102	287	13	1	1	19	236	753	1216	1751
(14)	Wind	WSAvg	4.3	4.7	4.6	4.5	4.0	3.8	3.7	3.5	4.0	4.3	4.6	4.7
(15) Precipitation	PrecAvg	268	33	41	16	20	15	15	12	9	12	24	31	38
	PrecMax	714	96	196	137	106	78	135	47	31	84	110	80	206
	PrecMin	43	4	0	0	5	0	0	0	1	1	2	1	2
	PrecStd	132	23	42	27	25	21	26	16	8	16	24	20	42
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.6	39.2	38.0	33.7	28.4	24.1	25.5	28.9	33.0	36.5	39.1	41.0
		MCWB	18.3	18.0	17.5	16.0	14.0	12.5	11.8	13.1	14.1	14.9	15.9	17.4
	2%	DB	39.6	37.7	35.7	31.7	26.2	21.4	23.3	26.4	31.2	34.7	36.8	38.6
		MCWB	18.2	18.1	17.1	15.9	13.5	11.6	11.1	11.8	13.6	14.7	15.9	16.8
	5%	DB	37.8	36.4	34.1	29.9	24.2	19.3	21.2	24.0	29.5	33.1	35.0	36.6
		MCWB	18.0	17.8	16.5	14.9	12.9	10.6	10.3	11.0	12.9	14.3	15.7	16.9
	10%	DB	36.2	35.0	32.3	28.1	21.9	17.5	19.0	21.8	27.5	31.1	33.1	34.6
		MCWB	18.0	17.5	16.2	14.4	12.0	9.7	9.4	10.2	12.4	13.9	15.3	16.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.1	22.2	20.1	17.0	15.2	15.1	14.6	17.5	18.4	20.9	22.6
		MCDB	29.1	30.1	27.3	25.5	21.1	19.0	20.6	23.8	24.9	27.6	28.8	27.0
	2%	WB	22.6	22.2	21.0	18.2	15.2	13.8	12.6	13.1	15.3	17.1	19.3	21.4
		MCDB	27.9	29.9	26.5	24.2	21.5	17.7	19.6	22.4	26.0	25.3	27.3	26.6
	5%	WB	21.5	21.4	19.8	17.0	14.2	12.2	11.3	11.8	14.1	16.3	18.4	20.3
		MCDB	28.6	29.3	27.0	24.7	21.3	17.3	19.0	22.7	26.1	25.7	27.5	27.1
	10%	WB	20.4	20.6	18.5	15.8	13.1	10.7	10.1	10.7	13.1	15.4	17.3	19.5
		MCDB	30.0	28.9	28.6	25.0	20.6	16.2	18.1	20.8	25.4	27.0	27.0	27.6
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	12.1	11.9	12.2	11.7	11.4	12.5	13.4	13.5	13.5	12.9	12.4
		MCDBR	14.0	13.6	13.9	14.1	14.2	14.1	15.4	16.2	15.6	15.3	14.9	15.0
		MCWBR	4.5	4.3	4.9	5.3	6.0	7.0	7.3	7.3	6.2	5.7	5.0	4.8
	5% WB	MCDBR	11.0	10.7	10.0	10.7	11.1	10.2	13.3	14.4	13.4	11.8	12.5	10.7
		MCWBR	4.2	3.4	3.9	4.6	5.4	5.3	7.1	6.9	5.8	4.9	4.3	4.2
(40) Clear-Sky Solar Irradiance	taub		0.347	0.342	0.329	0.315	0.289	0.275	0.277	0.293	0.332	0.339	0.347	0.345
	taud		2.524	2.557	2.565	2.570	2.606	2.629	2.607	2.527	2.429	2.438	2.475	2.516
	Ebn at Noon		995	984	969	938	923	919	928	948	950	976	989	999
	Edh at Noon		113	106	100	91	79	74	78	93	113	118	118	114
(44) All-Sky Solar Radiation	RadAvg		7.84	7.31	6.50	5.33	4.33	3.80	4.10	5.18	6.29	7.10	7.53	7.63
	RadStd		0.48	0.65	0.43	0.39	0.34	0.30	0.29	0.26	0.32	0.52	0.35	0.52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	-1.05	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page