

OODNADATTA, Australia

WMO: 944760

Lat: 27.5538S

Lon: 135.4457E

Elev: 384

StdP: 14.49

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	38.0	40.4	13.7	11.2	70.5	16.7	13.0	70.1	22.8	64.9	20.8	64.9	4.4	190	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	109.2	68.7	106.7	68.1	104.1	67.6	75.6	89.2	73.8	91.0	72.2	91.3	12.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.6	122.5	79.6	69.5	109.9	79.8	66.3	98.4	80.8	39.4	89.3	37.7	90.8	36.1	90.7	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.2	24.2	21.7	DB	33.7	113.2	1.9	2.5	32.3	115.1	31.2	116.5	30.2	117.9	28.8	119.8
			WB	29.2	77.2	2.1	2.2	27.7	78.7	26.5	80.0	25.3	81.2	23.8	82.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.3	88.7	86.3	80.5	72.3	62.8	55.7	55.9	59.6	67.7	74.3	80.0	84.3
	DBStd	13.31	7.34	7.45	7.13	6.43	6.19	4.88	5.37	6.14	7.77	8.03	7.81	7.35
	HDD50	12	0	0	0	0	0	5	6	1	0	0	0	0
	HDD65	965	0	0	0	11	120	284	287	194	58	10	1	0
	CDD50	8140	1201	1016	945	669	398	175	189	298	532	753	900	1064
	CDD65	3619	736	596	480	230	53	4	6	27	139	298	451	599
	CDH74	51752	11731	9012	6296	2530	473	39	93	365	1835	4024	6357	8997
	CDH80	30953	7947	5814	3538	1070	112	3	11	103	834	2127	3720	5674
(14) Wind	WSAvg	11.0	13.4	12.5	11.5	9.9	8.9	8.2	8.7	10.1	11.4	12.4	12.2	12.6
(15) Precipitation	PrecAvg	6.4	0.4	1.3	0.4	0.4	0.4	0.5	0.4	0.3	0.3	0.6	0.6	0.8
	PrecMax	12.4	2.0	4.8	4.1	2.6	1.3	3.5	2.6	1.8	1.9	2.8	1.9	3.3
	PrecMin	2.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.2	0.6	1.7	0.9	0.7	0.4	0.7	0.6	0.5	0.5	0.7	0.6	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	113.7	110.6	106.1	97.5	87.3	78.8	81.3	89.0	98.1	103.5	109.0	111.3
		MCWB	70.2	71.2	67.4	65.6	60.4	58.5	57.1	59.4	62.9	64.4	66.0	68.4
	2%	DB	110.2	107.0	101.5	93.6	83.4	73.5	76.4	82.4	93.8	99.8	104.7	107.3
		MCWB	69.3	69.3	67.0	63.5	59.9	56.3	55.4	56.3	60.6	63.1	65.5	67.1
	5%	DB	107.2	104.4	98.5	89.9	79.5	69.8	72.2	77.6	89.4	96.0	100.2	103.9
		MCWB	68.8	68.8	66.1	62.3	58.2	54.3	53.7	54.9	59.2	62.0	64.7	66.7
	10%	DB	104.3	101.5	95.2	86.4	75.6	66.8	68.2	73.5	84.4	91.7	96.4	100.4
		MCWB	68.2	68.1	65.6	61.0	56.7	52.9	52.2	53.2	57.5	60.7	63.6	66.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.2	78.0	76.1	71.3	64.2	62.7	62.6	61.3	66.9	68.3	72.4	75.3
		MCDB	95.8	87.8	84.0	80.1	73.1	70.6	73.4	80.9	80.9	90.1	89.8	87.5
	2%	WB	74.5	76.1	73.1	68.3	61.8	59.6	57.1	58.5	63.6	66.2	69.9	72.9
		MCDB	92.8	89.1	87.2	78.2	75.5	68.4	71.1	77.0	83.8	87.6	89.3	89.3
	5%	WB	72.7	74.6	70.9	65.8	60.2	56.8	54.8	56.3	61.2	64.4	68.3	71.2
		MCDB	95.4	90.4	88.3	82.5	74.6	66.5	69.1	74.8	85.4	87.2	88.6	90.3
	10%	WB	71.0	72.7	68.4	63.6	58.5	54.4	53.0	54.3	59.0	62.7	66.8	69.4
		MCDB	95.1	91.1	90.0	82.9	73.1	64.7	66.9	71.4	82.9	86.3	88.5	91.2
(35) Mean Daily Temperature Range	5% DB	MDBR	23.7	22.5	22.6	23.2	22.2	22.1	23.1	24.7	25.5	25.4	24.6	24.3
		MCDBR	26.3	24.7	25.9	26.4	25.1	25.4	28.1	28.8	30.9	29.8	28.1	27.8
		MCWBR	9.3	8.3	10.0	11.1	11.5	13.6	14.2	13.7	13.3	11.9	10.3	10.1
	5% WB	MCDBR	20.8	17.3	18.5	19.8	20.4	19.5	23.8	25.6	26.1	24.9	22.9	21.5
		MCWBR	7.7	5.9	7.5	8.7	9.9	11.0	12.8	12.8	12.2	10.4	8.5	8.1
(40) Clear-Sky Solar Irradiance	taub		0.382	0.372	0.349	0.331	0.307	0.291	0.293	0.308	0.349	0.360	0.374	0.366
	taud		2.386	2.441	2.474	2.508	2.540	2.567	2.545	2.478	2.369	2.360	2.373	2.422
	Ebn at Noon		305	302	300	290	284	283	286	294	295	303	305	310
	Edh at Noon		41	38	35	30	27	24	26	31	38	41	41	40
(44) All-Sky Solar Radiation	RadAvg		2543	2348	2083	1649	1307	1137	1239	1564	1941	2236	2412	2503
	RadStd		102	178	107	100	91	72	69	73	96	156	124	128

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+297	+200

Nomenclature: See separate page