

WINDORAH, Australia

WMO: 944880

Lat: 25.423S

Lon: 142.656E

Elev: 129

StdP: 99.79

Time Zone: 10.00 (E10)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 4.4	(c) 5.7	(d) -9.5	(e) 1.7	(f) 23.3	(g) -7.5	(h) 2.0	(i) 21.7	(j) 11.0	(k) 17.8	(l) 9.0	(m) 18.5	(n) 0.6	(o) 310	(p) 0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.2	41.9	21.0	40.6	21.0	39.3	20.9	25.5	32.7	24.8	32.1	24.2	31.8	3.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.2	27.7	23.2	18.2	27.8	22.0	17.0	28.0	79.4	32.5	76.3	31.7	73.7	31.3	35.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.5	8.5	7.3	DB	2.1	44.3	0.8	1.3	1.5	45.3	1.1	46.0	0.6	46.8	0.0	47.7	
			WB	0.0	28.4	1.1	2.8	-0.8	30.5	-1.4	32.1	-2.0	33.7	-2.8	35.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.6	31.3	30.6	28.3	23.6	18.7	15.6	14.8	16.9	21.6	24.7	28.0	30.2
	DBStd	6.77	2.93	2.80	3.01	3.57	3.32	3.69	3.14	3.60	4.12	3.66	3.76	3.30
	HDD10.0	2	0	0	0	0	0	1	1	1	0	0	0	0
	HDD18.3	350	0	0	0	4	37	101	118	72	16	2	0	0
	CDD10.0	4984	661	577	567	408	269	168	150	213	349	456	539	627
	CDD18.3	2290	402	343	309	162	48	18	8	27	116	199	289	368
	CDH23.3	31556	6178	5029	4089	1777	413	138	87	344	1436	2549	3974	5542
CDH26.7	18321	4008	3093	2308	817	94	17	8	86	661	1350	2348	3531	
Wind	WSAvg	2.7	2.9	3.1	2.5	2.3	2.0	2.0	2.2	2.8	3.0	3.3	3.4	3.2
Precipitation	PrecAvg	269	44	50	29	19	19	13	16	10	9	16	23	26
	PrecMax	480	182	236	147	179	105	73	113	60	52	95	118	120
	PrecMin	67	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	117	43	60	33	36	27	19	26	13	12	21	28	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	42.1	40.7	36.4	30.9	28.7	27.7	31.6	36.5	40.3	43.0	42.8
		MCWB	22.9	21.5	20.4	20.2	17.6	16.6	16.2	16.8	17.8	19.1	20.7	20.9
	2%	DB	41.8	40.5	38.5	34.4	29.2	26.7	25.5	29.1	34.4	37.6	40.1	41.3
		MCWB	21.6	22.5	20.3	19.3	17.3	16.9	14.8	16.2	17.5	18.4	19.5	20.3
	5%	DB	40.3	39.0	37.0	33.0	27.7	25.0	24.0	27.4	33.0	35.6	38.0	39.9
		MCWB	21.5	22.2	20.8	18.7	16.6	15.7	14.1	15.3	17.3	17.8	19.8	20.2
	10%	DB	38.8	37.5	35.4	31.4	25.7	22.9	22.2	25.2	31.1	33.7	36.3	38.4
		MCWB	21.3	21.8	20.4	18.3	15.6	14.6	12.8	14.1	16.2	17.4	19.5	20.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.5	27.5	23.7	20.6	19.4	18.0	19.4	21.1	21.9	24.1	24.7
		MCDB	37.0	33.7	31.5	32.0	26.7	25.5	25.4	27.8	31.7	32.2	32.3	31.6
	2%	WB	25.2	25.7	24.8	22.4	19.2	18.1	16.2	17.7	19.5	20.7	23.2	23.8
		MCDB	33.0	33.0	31.2	28.4	24.1	24.1	23.4	25.8	29.0	30.3	30.8	31.8
	5%	WB	24.5	25.0	23.8	21.2	18.2	16.9	14.9	16.3	18.5	19.8	22.3	23.1
		MCDB	32.3	32.1	30.7	27.5	24.1	23.0	21.8	24.9	28.9	30.5	30.4	31.8
	10%	WB	23.8	24.4	22.7	19.9	17.1	15.6	13.7	15.1	17.5	19.0	21.6	22.5
		MCDB	32.1	32.0	31.0	28.4	23.6	21.6	20.8	23.2	28.5	29.9	30.4	32.2
Mean Daily Temperature Range	5% DB	MDBR	13.2	12.2	12.8	13.1	12.9	13.1	13.9	14.8	15.4	15.0	13.8	13.5
		MCDBR	15.2	14.1	14.3	14.6	14.0	13.8	15.1	15.8	16.8	17.1	15.7	15.5
		MCWBR	5.2	4.9	5.3	6.1	6.1	6.5	7.8	7.6	7.4	7.1	6.1	5.8
	5% WB	MCDBR	11.3	11.1	10.7	11.1	11.0	12.0	13.3	13.4	14.4	13.7	12.2	11.4
	MCWBR	4.2	3.7	4.7	5.6	5.2	6.2	7.2	6.8	7.2	6.5	4.7	4.5	
Clear-Sky Solar Irradiance	taub		0.373	0.365	0.347	0.330	0.313	0.301	0.300	0.313	0.361	0.361	0.375	0.377
	taud		2.463	2.496	2.528	2.526	2.519	2.550	2.523	2.464	2.346	2.373	2.388	2.414
	Ebn at Noon		970	963	952	924	897	890	903	927	922	956	961	967
	Edh at Noon		120	113	104	96	88	81	86	100	123	127	128	126
All-Sky Solar Radiation	RadAvg		7.64	7.26	6.47	5.51	4.38	3.82	4.21	5.25	6.29	7.30	7.58	7.71
	RadStd		0.43	0.57	0.38	0.28	0.19	0.24	0.26	0.21	0.43	0.43	0.43	0.49

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page