

QUILPIE, Australia

WMO: 944940

Lat: 26.613S

Lon: 144.258E

Elev: 646

StdP: 14.36

Time Zone: 10.00 (E10)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.6	41.8	12.8	10.8	75.5	16.7	13.1	70.6	19.6	66.3	17.7	66.7	1.5	180	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	105.0	68.4	102.8	68.2	100.5	67.8	76.6	87.8	75.2	87.7	73.8	86.7	6.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	129.2	81.6	72.2	122.0	80.5	70.3	114.1	80.0	40.7	87.0	39.2	87.7	37.9	86.8	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	17.2	14.2	35.3	109.7	1.4	2.3	34.2	111.4	33.4	112.8	32.6	114.1	31.5	115.8		
(5)			31.1	81.0	2.3	2.5	29.5	82.9	28.1	84.3	26.8	85.8	25.1	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	87.2	85.3	81.9	73.1	64.2	58.5	56.6	60.1	68.4	74.7	80.0	85.1	(6)
(7)		DBStd	12.19	5.63	5.54	5.06	5.79	5.50	5.65	4.83	6.05	6.96	5.85	6.82	5.84	(7)
(8)		HDD50	6	0	0	0	0	0	2	3	1	0	0	0	0	(8)
(9)		HDD65	787	0	0	0	8	82	207	266	178	43	3	0	0	(9)
(10)		CDD50	8348	1153	989	990	692	441	257	206	315	551	766	901	1087	(10)
(11)		CDD65	3656	688	569	525	250	58	13	5	27	144	304	451	622	(11)
(12)		CDH74	48138	10159	7877	6745	2463	393	90	44	325	1726	3582	5755	8979	(12)
(13)		CDH80	26639	6341	4580	3587	989	58	3	2	65	687	1690	3185	5452	(13)
(14)	Wind	WSAvg	4.4	4.7	4.7	4.0	3.5	3.1	3.1	3.6	4.7	5.0	5.5	5.4	5.2	(14)
(15)	Precipitation	PrecAvg	14.4	2.4	2.0	1.4	1.1	1.3	0.7	0.7	0.6	0.5	0.7	1.3	1.4	(15)
(16)		PrecMax	26.5	13.2	9.3	7.1	12.5	6.8	3.1	3.8	1.9	2.0	2.2	6.6	10.8	(16)
(17)		PrecMin	3.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.0	2.6	2.4	1.5	2.3	1.7	0.7	0.8	0.6	0.6	0.7	1.5	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.6	105.4	102.6	95.1	84.9	80.1	78.7	86.2	95.5	100.5	106.3	106.4	(19)
(20)			MCWB	69.6	70.9	67.3	67.0	61.6	60.7	57.2	59.9	61.9	63.1	65.9	68.4	(20)
(21)		2%	DB	105.6	102.8	98.7	91.6	82.0	77.0	74.6	81.4	91.4	96.6	101.8	103.5	(21)
(22)			MCWB	68.9	71.4	67.1	64.2	61.0	60.1	56.2	58.2	60.7	62.3	64.9	67.0	(22)
(23)		5%	DB	102.9	99.9	96.0	88.9	78.9	73.7	71.8	78.2	88.4	93.0	98.1	101.3	(23)
(24)			MCWB	68.9	70.5	67.2	63.0	59.4	58.6	54.8	56.7	60.0	61.6	64.7	67.1	(24)
(25)		10%	DB	99.9	97.1	93.5	85.9	75.6	70.2	68.6	74.3	84.8	89.5	94.6	98.9	(25)
(26)			MCWB	68.5	69.8	66.9	62.1	58.4	56.6	53.0	55.0	59.0	60.9	64.4	66.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.3	80.3	76.3	72.2	67.9	65.0	64.5	64.4	67.4	70.7	73.8	75.9	(27)
(28)			MCD B	87.7	95.3	84.7	83.8	71.6	74.0	70.6	81.3	81.8	83.2	83.7	94.7	(28)
(29)		2%	WB	75.6	77.6	74.1	70.1	65.3	62.9	59.7	60.9	64.8	67.5	72.0	73.6	(29)
(30)			MCD B	88.5	90.3	84.4	81.6	73.1	70.6	69.3	73.8	78.4	80.6	81.7	90.2	(30)
(31)		5%	WB	74.3	76.1	72.4	67.7	63.7	60.8	57.4	58.8	62.9	65.7	70.2	72.1	(31)
(32)			MCD B	88.0	87.5	85.4	78.9	72.6	70.1	67.3	72.4	80.4	80.5	81.2	88.2	(32)
(33)		10%	WB	72.9	74.6	70.6	65.2	61.8	58.8	55.0	57.0	61.0	64.0	68.6	70.9	(33)
(34)			MCD B	86.9	86.3	85.6	79.5	71.2	68.7	66.2	71.7	80.4	81.6	81.7	87.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.4	19.3	21.2	21.6	20.6	21.3	23.0	24.7	25.3	24.4	22.1	21.9	(35)
(36)			MCDBR	24.3	22.2	23.6	25.3	23.9	24.6	27.5	29.0	29.4	30.0	26.8	25.2	(36)
(37)			MCWBR	7.8	6.4	7.8	9.2	9.5	11.3	13.1	13.1	10.8	10.5	8.4	8.5	(37)
(38)		5% WB	MCDBR	19.0	18.0	17.9	17.1	16.3	19.8	20.9	22.7	22.2	21.3	18.6	20.3	(38)
(39)			MCWBR	6.9	7.1	6.9	8.4	7.1	10.4	11.1	10.3	9.0	10.1	7.6	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.361	0.353	0.335	0.317	0.300	0.291	0.289	0.305	0.348	0.348	0.364	0.363	(40)	
(41)		taud	2.501	2.539	2.572	2.576	2.570	2.595	2.571	2.500	2.384	2.416	2.429	2.464	(41)	
(42)		Ebn at Noon	311	309	305	296	288	285	289	296	296	307	308	311	(42)	
(43)		Edh at Noon	36	34	31	29	26	24	26	30	37	38	39	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2411	2262	2014	1698	1336	1144	1270	1596	1945	2272	2373	2453	(44)	
(45)		RadStd	128	186	116	95	60	71	82	70	133	139	181	149	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page