

ST GEORGE, Australia

WMO: 945170

Lat: 28.049S

Lon: 148.594E

Elev: 199

StdP: 98.96

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.8	3.2	-8.9	1.8	21.8	-7.0	2.1	20.4	9.0	19.8	8.0	16.3	1.0	250	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	39.3	19.6	37.5	19.3	36.0	19.2	23.8	29.9	22.9	29.4	22.2	29.0	4.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	17.6	25.4	21.2	16.3	25.0	20.4	15.4	24.9	72.5	30.0	68.9	29.3	66.4	29.1	34.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.3	7.3	-1.0	42.0	1.0	1.6	-1.7	43.1	-2.3	44.1	-2.9	44.9	-3.7	46.1
			-1.2	26.4	0.9	4.0	-1.9	29.2	-2.4	31.6	-2.9	33.8	-3.6	36.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	28.5	27.1	25.0	21.1	16.2	13.2	12.5	14.2	18.2	22.1	25.5	27.3
	DBStd	6.53	3.02	3.09	2.88	2.86	3.05	2.93	2.96	3.53	3.81	3.78	3.69	3.43
	HDD10.0	16	0	0	0	0	0	5	8	3	0	0	0	0
	HDD18.3	629	0	0	1	9	81	156	183	139	49	11	1	0
	CDD10.0	3977	574	478	465	332	192	101	84	131	245	374	463	537
	CDD18.3	1548	316	245	207	91	14	1	2	10	44	127	214	279
	CDH23.3	18043	4048	2893	2154	813	123	7	13	123	572	1406	2459	3431
CDH26.7	8950	2257	1499	960	227	13	0	1	31	201	614	1259	1889	
Wind	WSAvg	3.5	4.1	3.9	3.6	3.0	2.7	2.9	2.8	3.1	3.4	3.9	4.2	4.1
Precipitation	PrecAvg	537	87	53	52	33	47	24	32	29	27	41	50	57
	PrecMax	906	332	293	360	204	310	75	121	137	106	102	140	154
	PrecMin	302	11	4	0	0	1	0	0	0	0	2	0	9
	PrecStd	142	76	53	66	53	54	19	30	27	24	27	38	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	40.5	37.6	32.6	28.2	24.4	25.1	29.9	34.2	36.6	40.2	40.8
		MCWB	21.1	20.3	19.6	17.5	15.7	15.4	14.1	15.0	16.2	17.4	19.5	19.5
	2%	DB	38.8	37.5	35.1	30.6	26.2	22.5	22.6	26.4	31.2	34.2	37.5	38.7
		MCWB	19.8	19.7	19.2	17.5	15.8	14.7	12.8	14.4	15.3	16.9	18.5	19.3
	5%	DB	37.0	35.7	33.2	29.1	24.6	21.0	20.9	24.1	28.9	32.2	35.1	36.8
		MCWB	19.9	19.9	18.9	17.2	15.1	13.8	12.7	13.1	14.6	16.7	18.0	19.0
	10%	DB	35.3	33.8	31.5	27.8	23.2	19.3	19.1	22.0	26.7	30.2	33.0	34.9
		MCWB	19.8	19.7	18.8	16.6	14.5	13.1	11.9	12.2	14.0	16.4	17.8	18.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	24.2	23.2	21.4	19.4	17.7	17.5	17.4	18.8	22.2	25.7	26.0
		MCDB	29.3	30.6	27.8	26.9	23.5	21.0	20.4	25.9	26.4	29.5	30.9	31.3
	2%	WB	23.9	23.1	22.3	20.0	17.6	16.2	15.1	15.8	17.5	20.1	21.7	22.8
		MCDB	29.9	29.1	27.9	25.7	22.3	20.1	19.3	22.7	24.6	27.1	28.8	29.6
	5%	WB	23.0	22.5	21.5	18.9	16.6	15.2	13.9	14.5	16.4	19.0	20.5	21.9
		MCDB	29.8	29.0	27.6	25.7	22.4	19.0	18.2	21.3	24.4	26.9	28.2	28.5
	10%	WB	22.3	21.8	20.7	17.8	15.5	14.2	12.8	13.3	15.4	17.9	19.7	21.2
		MCDB	29.6	28.8	27.3	25.2	21.6	18.0	18.1	20.3	24.2	25.7	27.8	28.4
Mean Daily Temperature Range	5% DB	MDBR	11.4	11.2	11.8	13.1	13.4	11.9	13.5	14.9	14.9	13.9	12.5	12.0
		MCDBR	13.6	13.7	13.8	13.9	14.5	13.7	15.2	16.9	17.4	16.2	14.6	14.5
		MCWBR	4.2	4.0	4.3	5.1	6.2	6.9	7.4	7.6	6.9	6.0	4.9	4.7
	5% WB	MCDBR	10.6	10.4	10.2	11.3	11.3	10.2	11.0	13.6	13.3	12.4	11.6	11.0
		MCWBR	4.1	3.7	4.3	4.8	6.0	5.5	6.2	6.8	6.3	5.7	5.1	4.4
Clear-Sky Solar Irradiance	taub	0.364	0.359	0.337	0.319	0.300	0.292	0.287	0.299	0.334	0.351	0.372	0.366	
	taud	2.508	2.534	2.587	2.595	2.597	2.630	2.622	2.564	2.455	2.443	2.434	2.483	
	Ebn at Noon	977	966	958	928	903	890	910	936	944	962	964	978	
	Edh at Noon	114	108	97	88	79	72	76	88	109	117	122	118	
All-Sky Solar Radiation	RadAvg	7.46	6.88	6.04	5.05	4.00	3.30	3.72	4.73	5.86	6.75	7.22	7.45	
	RadStd	0.48	0.52	0.33	0.27	0.19	0.26	0.24	0.27	0.40	0.49	0.68	0.60	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page