

DALBY, Australia

WMO: 945420

Lat: 27.161S

Lon: 151.263E

Elev: 1130

StdP: 14.11

Time Zone: 10.00 (E10)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.6	34.4	16.0	12.9	58.4	19.7	15.4	51.3	22.9	64.1	21.1	64.1	4.7	60	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	97.0	66.8	94.2	66.8	91.5	66.5	72.9	84.4	71.8	83.0	70.8	82.0	12.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.0	115.0	77.1	68.7	109.9	76.3	67.5	105.4	75.6	37.4	84.4	36.4	82.8	35.4	82.1	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.0	20.9	19.1	DB	25.9	102.8	2.3	3.2	24.2	105.1	22.9	107.0	21.6	108.8	19.9	111.2	(4)
(5)			WB	23.9	75.2	2.7	1.2	21.9	76.0	20.3	76.7	18.8	77.4	16.8	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	77.8	76.8	73.6	67.1	59.9	54.6	53.2	55.6	62.3	68.8	74.1	76.1	(6)	
	DBStd	10.14	4.11	4.35	4.27	4.09	4.97	4.84	5.26	5.67	5.79	5.63	5.51	4.89	(7)	
	HDD50	53	0	0	0	0	1	15	26	11	0	0	0	0	(8)	
	HDD65	1317	0	0	1	24	170	311	365	298	119	26	3	0	(9)	
	CDD50	6115	862	749	733	514	307	154	126	185	370	582	723	810	(10)	
	CDD65	1905	397	330	269	87	11	0	1	7	39	143	276	345	(11)	
	CDH74	19003	3969	3308	2357	795	149	6	10	114	587	1519	2816	3373	(12)	
	CDH80	7864	1849	1511	867	133	14	2	0	22	157	527	1245	1537	(13)	
(14) Wind	WSAvg	9.7	10.9	11.2	10.5	9.1	8.1	8.1	8.0	8.7	9.6	10.4	10.8	10.8	(14)	
(15) Precipitation	PrecAvg	22.6	3.3	2.6	1.9	0.9	1.3	1.3	0.8	0.9	1.3	2.0	2.7	3.7	(15)	
	PrecMax	39.0	7.7	6.9	7.0	3.6	6.1	4.8	2.6	4.1	5.5	4.3	6.8	11.3	(16)	
	PrecMin	14.8	0.4	0.2	0.2	0.0	0.2	0.1	0.1	0.0	0.1	0.2	0.5	1.1	(17)	
	PrecStd	5.4	2.1	1.5	1.8	1.0	1.3	1.2	0.7	0.9	1.3	1.0	1.5	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.9	100.8	96.8	87.1	81.9	73.7	75.4	82.5	89.7	93.3	97.2	100.2	(19)	
		MCWB	69.7	67.5	66.3	64.1	61.2	58.1	56.8	58.8	62.2	61.9	65.9	65.4	(20)	
	2%	DB	95.3	95.9	91.1	83.5	77.8	70.9	71.9	76.8	84.4	89.1	93.9	95.7	(21)	
		MCWB	68.0	67.5	67.5	62.7	59.8	57.2	56.2	56.9	59.4	62.1	65.2	66.6	(22)	
	5%	DB	92.7	91.7	88.0	80.9	75.0	68.9	69.1	73.1	80.6	85.9	90.8	91.8	(23)	
		MCWB	67.8	68.2	66.9	62.0	58.5	56.5	55.3	55.2	58.6	61.9	64.1	66.2	(24)	
	10%	DB	89.5	88.4	84.9	78.8	72.5	66.4	66.1	70.0	76.9	82.4	87.5	88.1	(25)	
		MCWB	67.7	67.5	66.3	61.8	57.7	55.9	54.0	53.8	57.8	61.0	63.6	66.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.6	74.2	72.8	68.7	64.4	62.1	63.7	62.9	66.3	69.7	71.7	73.5	(27)	
		MCDB	86.7	85.2	83.6	78.4	75.2	69.9	70.2	74.1	77.3	81.5	85.5	85.3	(28)	
	2%	WB	73.1	72.7	71.2	66.4	62.7	60.1	60.7	60.6	64.0	67.0	69.8	71.8	(29)	
		MCDB	84.9	83.6	81.2	76.2	72.3	66.4	67.5	70.4	75.1	78.6	84.6	82.7	(30)	
	5%	WB	71.9	71.1	70.0	65.1	61.3	58.7	57.9	58.5	62.0	65.2	68.1	70.6	(31)	
		MCDB	83.5	82.4	80.7	75.7	70.7	65.5	64.4	67.9	73.9	77.5	82.7	81.3	(32)	
	10%	WB	70.8	69.9	68.8	63.8	59.8	57.2	55.9	56.4	60.3	63.7	66.7	69.4	(33)	
		MCDB	82.0	81.8	79.2	74.5	69.0	64.4	63.2	66.2	72.2	76.1	80.4	80.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	22.1	21.7	24.0	25.4	23.3	26.3	29.3	28.4	25.2	23.7	22.2	(35)	
		MCDBR	26.7	27.2	26.1	26.8	28.7	26.4	29.2	32.7	33.5	30.0	27.8	27.9	(36)	
	5% WB	MCWBR	6.6	7.0	8.0	10.0	13.4	14.5	15.7	16.6	14.0	9.9	8.0	7.0	(37)	
		MCWBR	19.5	20.4	19.9	21.6	21.9	20.0	20.7	24.3	24.7	22.0	22.8	19.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.362	0.355	0.333	0.318	0.296	0.292	0.284	0.295	0.330	0.351	0.363	0.370	(40)	
		taud	2.542	2.569	2.629	2.639	2.653	2.667	2.674	2.617	2.504	2.480	2.487	2.500	(41)	
	Ebn at Noon		311	308	305	296	290	284	292	299	301	305	308	309	(42)	
		Edh at Noon	35	33	30	27	24	23	23	27	33	36	37	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2213	2032	1776	1526	1248	1037	1178	1488	1821	2043	2208	2226	(44)	
	RadStd		164	182	113	77	58	82	89	104	141	185	206	218	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.76	+1.22	N/A	N/A	N/A	N/A	N/A	-130	+340	+198

Nomenclature: See separate page