

DALBY, AustraliaWMO: **945420**Lat: **27.161S**Lon: **151.263E**Elev: **344**StdP: **97.26**Time Zone: **10.00 (E10)**Period: **06-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.2	1.3	-8.9	1.8	14.7	-6.8	2.2	10.7	10.3	17.8	9.4	17.8	2.1	60	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.9	36.1	19.4	34.6	19.3	33.1	19.2	22.7	29.1	22.1	28.3	21.6	27.8	5.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	16.4	25.1	20.4	15.7	24.6	19.7	15.1	24.2	69.2	29.1	66.7	28.2	64.5	27.8	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	9.4	8.5	-3.4	39.3	1.3	1.8	-4.3	40.6	-5.1	41.7	-5.8	42.7	-6.7	44.0
			-4.5	24.0	1.5	0.7	-5.6	24.5	-6.5	24.8	-7.3	25.2	-8.4	25.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	25.4	24.9	23.1	19.5	15.5	12.6	11.8	13.1	16.8	20.4	23.4	24.5
	DBStd	5.64	2.29	2.42	2.37	2.27	2.76	2.69	2.92	3.15	3.22	3.13	3.06	2.72
	HDD10.0	29	0	0	0	0	1	8	14	6	0	0	0	0
	HDD18.3	732	0	0	1	13	94	173	203	166	66	14	2	0
	CDD10.0	3397	479	416	407	286	171	86	70	103	206	323	402	450
	CDD18.3	1058	221	183	149	48	6	0	1	4	22	79	153	192
	CDH23.3	10557	2205	1838	1309	442	83	3	6	63	326	844	1564	1874
	CDH26.7	4369	1027	839	482	74	8	1	0	12	87	293	692	854
Wind	WSAvg	4.3	4.9	5.0	4.7	4.1	3.6	3.6	3.6	3.9	4.3	4.7	4.8	4.8
Precipitation	PrecAvg	575	83	67	49	22	33	32	21	23	33	50	69	93
	PrecMax	991	195	175	177	92	156	123	66	103	140	108	173	288
	PrecMin	377	10	6	6	0	4	2	2	0	2	5	12	27
	PrecStd	138	53	38	46	25	34	30	17	24	33	26	38	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	38.2	36.0	30.6	27.7	23.1	24.1	28.1	32.1	34.1	36.2	37.9
		MCWB	20.9	19.7	19.1	17.8	16.2	14.5	13.8	14.9	16.8	16.6	18.8	18.6
	2%	DB	35.2	35.5	32.8	28.6	25.5	21.6	22.2	24.9	29.1	31.7	34.4	35.4
		MCWB	20.0	19.7	19.7	17.1	15.5	14.0	13.5	13.9	15.2	16.7	18.4	19.2
	5%	DB	33.7	33.2	31.1	27.2	23.9	20.5	20.6	22.8	27.0	29.9	32.6	33.2
		MCWB	19.9	20.1	19.4	16.7	14.7	13.6	12.9	12.9	14.8	16.6	17.8	19.0
	10%	DB	31.9	31.4	29.4	26.0	22.5	19.1	19.0	21.1	24.9	28.0	30.8	31.2
		MCWB	19.8	19.7	19.0	16.6	14.3	13.3	12.2	12.1	14.3	16.1	17.5	18.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.5	22.7	20.4	18.0	16.7	17.6	17.2	19.1	20.9	22.0	23.1
		MCDB	30.4	29.6	28.7	25.8	24.0	21.0	21.2	23.4	25.2	27.5	29.7	29.6
	2%	WB	22.8	22.6	21.8	19.1	17.0	15.6	15.9	15.9	17.8	19.5	21.0	22.1
		MCDB	29.4	28.7	27.3	24.6	22.4	19.1	19.7	21.4	23.9	25.9	29.2	28.2
	5%	WB	22.2	21.7	21.1	18.4	16.3	14.8	14.4	14.7	16.7	18.4	20.1	21.4
		MCDB	28.6	28.0	27.0	24.3	21.5	18.6	18.0	19.9	23.3	25.3	28.2	27.4
	10%	WB	21.5	21.1	20.4	17.7	15.5	14.0	13.3	13.6	15.7	17.6	19.3	20.8
		MCDB	27.8	27.7	26.2	23.6	20.5	18.0	17.3	19.0	22.3	24.5	26.9	26.8
Mean Daily Temperature Range	5% DB	MDBR	11.9	12.3	12.1	13.3	14.1	12.9	14.6	16.3	15.8	14.0	13.2	12.4
		MCDBR	14.9	15.1	14.5	14.9	15.9	14.7	16.2	18.1	18.6	16.7	15.5	15.5
		MCWBR	3.6	3.9	4.4	5.6	7.4	8.0	8.7	9.2	7.8	5.5	4.5	3.9
	5% WB	MCDBR	10.9	11.3	11.0	12.0	12.2	11.1	11.5	13.5	13.7	12.2	12.6	10.9
		MCWBR	3.7	3.8	4.0	4.8	6.0	6.5	7.1	7.6	6.0	4.7	4.3	3.9
Clear-Sky Solar Irradiance	taub	0.362	0.355	0.333	0.318	0.296	0.292	0.284	0.295	0.330	0.351	0.363	0.370	
	taud	2.542	2.569	2.629	2.639	2.653	2.667	2.674	2.617	2.504	2.480	2.487	2.500	
	Ebn at Noon	980	971	963	933	913	896	919	944	950	963	972	974	
	Edh at Noon	111	105	94	84	75	71	73	85	104	113	116	116	
All-Sky Solar Radiation	RadAvg	6.98	6.41	5.60	4.81	3.93	3.27	3.71	4.69	5.74	6.44	6.96	7.02	
	RadStd	0.52	0.57	0.36	0.24	0.18	0.26	0.28	0.33	0.44	0.58	0.65	0.69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.42	+0.68	N/A	N/A	N/A	N/A	N/A	-72	+189	+110

Nomenclature: See separate page