

KINGAROY, Australia

WMO: 945490

Lat: 26.5736S

Lon: 151.8397E

Elev: 434

StdP: 96.22

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.8	0.9	-9.1	1.8	16.6	-5.6	2.5	12.8	8.8	14.1	8.1	14.6	0.5	180	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	34.2	20.1	32.8	19.9	31.2	19.8	23.3	28.5	22.6	27.6	22.0	26.9	4.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.6	24.9	21.2	16.7	24.2	20.6	16.1	23.8	71.8	28.7	68.9	27.5	66.5	27.1	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.2	6.4	-3.5	37.4	1.2	1.8	-4.4	38.7	-5.0	39.7	-5.7	40.7	-6.5	42.0		
(5)			-4.3	24.8	1.4	1.1	-5.3	25.6	-6.1	26.2	-6.9	26.9	-7.9	27.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	24.2	23.4	21.9	18.7	14.6	12.5	11.5	12.6	16.2	19.3	21.7	23.2
	DBStd	5.16	2.23	2.22	2.14	2.09	2.61	2.78	2.62	2.67	2.83	2.87	2.65	2.58
	HDD10.0	29	0	0	0	0	1	8	14	6	0	0	0	0
	HDD18.3	811	0	0	1	19	117	177	213	181	76	22	3	1
	CDD10.0	3049	439	376	368	261	144	82	59	85	187	288	351	409
	CDD18.3	789	181	143	111	31	2	1	0	2	13	52	104	151
	CDH23.3	6832	1561	1094	723	226	42	3	3	38	240	607	954	1341
CDH26.7	2421	646	409	201	27	3	1	0	6	57	185	342	544	
Wind	WSAvg	2.9	3.3	3.4	3.1	2.7	2.4	2.5	2.4	2.7	3.0	3.1	3.2	3.3
Precipitation	PrecAvg	792	112	91	67	49	50	35	45	34	37	71	81	118
	PrecMax	1090	287	252	193	219	167	141	213	99	122	174	158	417
	PrecMin	338	13	15	7	0	6	0	0	0	0	7	2	27
	PrecStd	151	68	54	46	54	39	30	43	27	30	38	39	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	35.7	33.4	29.1	26.6	23.1	23.4	26.7	30.8	33.9	34.3	36.1
		MCWB	21.5	22.0	20.3	18.2	16.0	14.9	14.1	14.4	16.1	17.3	18.4	19.3
	2%	DB	33.8	33.1	30.5	27.2	24.3	21.3	21.8	24.0	28.2	30.6	32.2	33.8
		MCWB	20.5	21.3	20.4	17.8	15.1	14.3	13.3	13.8	15.4	17.1	18.3	20.0
	5%	DB	32.0	30.9	28.9	25.8	22.8	20.1	20.0	22.1	26.0	28.7	30.3	31.7
		MCWB	20.5	20.9	20.0	17.3	14.8	13.7	12.2	13.0	15.1	16.8	18.4	20.0
	10%	DB	30.2	29.1	27.2	24.4	21.3	18.8	18.7	20.4	24.1	26.8	28.5	29.8
		MCWB	20.4	20.5	19.6	17.2	14.4	13.3	12.1	12.2	14.4	16.4	18.3	19.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	24.4	23.0	21.0	18.5	17.3	17.8	17.3	18.7	20.9	22.9	24.1
		MCDB	28.9	30.8	27.8	25.5	23.0	20.4	20.2	22.9	25.2	27.4	29.1	29.6
	2%	WB	23.2	23.1	22.2	19.8	17.3	16.3	16.0	15.8	17.6	19.7	21.2	22.5
		MCDB	28.2	28.3	26.6	23.7	21.6	19.2	18.7	20.5	23.6	25.2	27.0	28.1
	5%	WB	22.6	22.3	21.5	18.9	16.5	15.4	14.5	14.7	16.6	18.7	20.2	21.7
		MCDB	27.6	27.3	25.7	22.8	20.4	18.2	17.6	19.2	22.7	24.2	25.8	27.1
	10%	WB	21.9	21.6	20.8	18.2	15.7	14.5	13.3	13.6	15.7	17.9	19.5	21.1
		MCDB	26.9	26.5	25.0	22.2	19.4	17.3	16.9	18.3	21.3	23.4	25.1	26.3
Mean Daily Temperature Range	5% DB	MDBR	11.5	10.7	10.7	12.2	13.9	12.8	14.9	16.3	15.6	14.1	12.9	12.1
		MCDBR	14.8	14.1	13.6	14.6	16.3	14.6	17.2	18.9	18.5	17.3	15.8	15.4
		MCWBR	4.6	4.4	5.0	6.4	8.4	8.3	9.7	9.8	7.8	6.5	5.1	4.9
	5% WB	MCDBR	10.9	11.0	10.5	10.7	11.9	10.0	12.1	14.4	14.2	13.2	12.2	11.7
		MCWBR	4.1	4.0	4.4	5.0	6.5	6.0	7.5	8.0	6.5	5.5	4.6	4.4
Clear-Sky Solar Irradiance	taub	0.364	0.354	0.335	0.317	0.298	0.290	0.284	0.295	0.329	0.353	0.360	0.373	
	taud	2.527	2.571	2.619	2.646	2.645	2.669	2.669	2.615	2.507	2.472	2.493	2.483	
	Ebn at Noon	978	973	962	936	914	901	922	946	953	962	976	971	
	Edh at Noon	112	105	95	84	77	71	74	85	104	114	115	118	
All-Sky Solar Radiation	RadAvg	6.64	6.10	5.32	4.63	3.88	3.25	3.73	4.64	5.66	6.28	6.75	6.77	
	RadStd	0.53	0.56	0.38	0.29	0.19	0.25	0.31	0.35	0.47	0.57	0.65	0.73	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.37	+0.55	N/A	N/A	N/A	N/A	-70	+183	+110

Nomenclature: See separate page