

OAKEY, Australia

WMO: 945520

Lat: 27.4033S

Lon: 151.7414E

Elev: 1336

StdP: 14.00

Time Zone: 10.00 (E10)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.5	31.5	17.6	14.0	55.0	21.5	16.9	50.9	25.4	60.0	23.2	59.9	4.6	90	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	95.5	67.6	92.4	67.2	89.5	67.0	73.3	84.1	72.1	82.7	71.1	81.5	12.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.6	118.5	76.5	69.3	113.3	75.9	68.1	108.5	75.2	37.9	83.8	36.8	82.9	35.8	81.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.7	21.3	19.5	DB	23.5	100.9	2.1	3.3	22.0	103.3	20.8	105.2	19.6	107.0	18.1	109.4	(4)
(5)			WB	22.2	75.6	2.3	1.3	20.5	76.6	19.2	77.4	17.8	78.1	16.1	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.8	76.0	74.9	72.0	65.6	58.1	53.1	51.7	54.0	61.0	66.9	71.2	74.2	(6)	
	DBStd	9.99	4.13	4.44	3.94	4.27	5.20	5.30	5.14	5.36	5.71	5.37	5.18	5.02	(7)	
	HDD50	95	0	0	0	0	5	28	41	20	1	0	0	0	(8)	
	HDD65	1576	0	0	2	42	220	356	414	345	146	41	8	2	(9)	
	CDD50	5510	805	698	683	468	256	122	93	143	330	524	636	752	(10)	
	CDD65	1515	340	279	220	60	6	0	0	3	25	100	194	288	(11)	
	CDH74	14254	3115	2358	1728	574	87	5	5	77	523	1215	1874	2693	(12)	
	CDH80	5393	1334	954	552	87	8	1	0	14	142	418	736	1147	(13)	
(14) Wind	WSAvg	9.9	11.4	11.4	10.6	9.2	8.2	8.4	8.2	9.0	9.7	10.6	11.1	11.1	(14)	
(15) Precipitation	PrecAvg	25.1	3.0	3.3	1.9	1.4	1.7	1.1	1.3	1.0	1.2	2.3	3.1	3.9	(15)	
	PrecMax	35.5	8.4	10.3	4.3	9.0	7.5	5.4	5.4	2.5	4.1	7.7	8.1	7.4	(16)	
	PrecMin	13.2	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0	0.5	(17)	
	PrecStd	6.3	2.1	2.6	1.3	1.8	1.9	1.1	1.1	0.8	1.1	1.7	2.1	1.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.3	98.8	94.9	86.1	80.2	73.4	74.4	80.6	89.1	94.2	95.7	98.7	(19)	
		MCWB	69.7	69.7	67.5	63.8	60.2	57.7	56.7	57.6	61.0	62.5	65.5	67.3	(20)	
	2%	DB	94.4	93.3	89.1	82.4	76.4	70.6	70.8	75.4	84.1	88.4	91.7	94.1	(21)	
		MCWB	68.7	70.0	67.7	62.8	59.1	57.1	55.5	55.3	59.2	61.5	65.0	66.8	(22)	
	5%	DB	90.8	89.3	85.6	79.8	73.5	68.4	68.0	71.8	80.1	84.6	87.9	89.9	(23)	
		MCWB	68.7	69.3	67.2	62.4	58.2	56.0	54.5	54.2	58.4	61.7	64.4	67.1	(24)	
	10%	DB	87.3	85.9	82.7	77.2	71.2	66.0	65.3	68.6	76.0	80.8	84.2	86.4	(25)	
		MCWB	68.5	68.4	66.3	62.0	57.3	55.0	53.0	53.1	57.3	60.5	64.2	67.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.6	74.9	73.0	69.8	65.2	62.7	63.0	62.0	65.5	69.3	71.5	73.6	(27)	
		MCDB	86.4	86.3	82.0	77.5	72.1	68.4	69.2	73.0	77.1	79.6	84.6	86.1	(28)	
	2%	WB	73.2	73.4	71.2	66.9	63.0	60.4	59.6	59.5	63.3	66.9	69.8	72.0	(29)	
		MCDB	84.1	83.7	80.7	75.8	70.5	66.1	65.2	68.8	74.7	77.3	82.1	83.3	(30)	
	5%	WB	72.0	72.0	70.0	65.4	61.4	58.7	57.2	57.5	61.6	65.0	68.2	70.8	(31)	
		MCDB	82.8	81.7	79.0	74.3	68.9	64.8	63.2	66.2	73.1	75.9	79.7	81.8	(32)	
	10%	WB	70.8	70.7	68.8	63.9	59.9	57.1	55.4	55.6	59.9	63.4	66.7	69.6	(33)	
		MCDB	81.6	80.4	77.8	72.8	67.5	63.1	62.4	64.7	70.9	74.7	78.0	80.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	20.5	21.2	23.7	26.1	25.1	27.3	29.6	28.8	25.7	23.5	22.2	(35)	
		MCDBR	27.5	26.5	26.4	27.3	29.2	28.0	30.1	33.6	34.3	32.2	29.6	28.3	(36)	
	5% WB	MCWBR	8.1	7.6	8.5	11.0	14.4	15.5	16.7	16.9	13.9	11.6	9.4	8.7	(37)	
		MCWBR	21.2	20.6	20.2	21.0	21.1	20.8	21.6	25.0	26.1	23.9	22.6	22.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.364	0.356	0.334	0.317	0.296	0.290	0.283	0.295	0.330	0.353	0.363	0.372	(40)	
		taud	2.529	2.559	2.623	2.639	2.647	2.670	2.673	2.611	2.501	2.471	2.483	2.485	(41)	
	Ebn at Noon		310	307	305	296	289	285	292	299	301	305	309	308	(42)	
		Edh at Noon	36	34	30	27	24	22	23	27	33	36	37	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2174	1990	1732	1499	1230	1019	1163	1466	1797	2007	2177	2182	(44)	
	RadStd		170	181	108	70	62	80	88	106	140	190	204	216	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	+1.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-119	+322	+196	

Nomenclature: See separate page