

APPLETHORPE, Australia

WMO: 945530

Lat: 28.6217S

Lon: 151.9533E

Elev: 2863

StdP: 13.24

Time Zone: 10.00 (E10)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 27.9	(c) 30.4	(d) 17.2	(e) 14.6	(f) 59.2	(g) 21.2	(h) 17.7	(i) 56.5	(j) 17.8	(k) 47.4	(l) 16.2	(m) 47.1	(n) 0.8	(o) 50	(p) 0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	87.9	64.8	84.9	64.1	82.0	63.3	69.7	78.8	68.4	76.7	67.3	75.2	7.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.3	111.9	72.1	66.1	107.2	71.1	65.0	102.9	70.1	35.6	78.7	34.4	77.0	33.5	75.2	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	13.7	12.1	DB	22.9	93.3	2.1	3.3	21.4	95.7	20.2	97.6	19.0	99.5	17.5	102.0	
			WB	27.7	72.9	2.8	3.4	25.7	75.4	24.1	77.4	22.6	79.3	20.6	81.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	69.7	68.3	65.7	59.6	52.6	48.2	46.6	48.5	55.1	60.2	64.6	67.6	(6)	(7)
	DBStd	9.37	4.41	4.26	3.73	4.15	4.63	4.67	4.36	4.66	5.33	5.29	5.29	4.91	(7)	(8)
	HDD50	335	0	0	0	1	27	88	123	83	12	1	0	0	(8)	(9)
	HDD65	2757	9	11	36	167	385	504	569	511	302	167	69	27	(9)	(10)
	CDD50	3564	612	513	487	289	107	35	18	38	164	316	438	547	(10)	(11)
	CDD65	510	156	104	58	5	0	0	0	1	4	17	56	109	(11)	(12)
	CDH74	3991	1153	698	356	36	3	0	0	8	69	229	550	889	(12)	(13)
	CDH80	1063	364	199	67	1	0	0	0	1	8	36	136	251	(13)	(14)
(14) Wind	WSAvg	5.4	5.9	5.9	5.7	5.0	4.5	5.0	5.1	5.5	5.6	5.5	5.5	5.8	(14)	(15)
(15) Precipitation	PrecAvg	30.9	3.9	3.3	2.6	1.7	2.1	1.5	2.0	1.7	1.8	2.8	3.3	3.9	(15)	(16)
	PrecMax	43.0	9.8	10.0	9.0	9.5	9.1	4.1	5.7	5.0	4.6	9.4	10.0	8.4	(16)	(17)
	PrecMin	20.7	0.8	0.2	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.6	0.9	0.7	(17)	(18)
	PrecStd	6.1	2.4	2.0	2.0	1.9	1.9	1.0	1.5	1.2	1.2	1.7	1.9	2.0	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	91.1	86.2	78.2	71.6	65.0	65.5	71.9	80.4	84.5	88.2	90.3	(19)	(20)
		MCWB	65.7	66.7	64.1	60.3	56.5	54.0	51.6	51.6	57.5	57.9	63.7	64.2	(20)	(21)
	2%	DB	87.5	85.7	81.4	74.4	68.0	62.2	61.9	66.5	75.4	79.6	83.9	86.2	(21)	(22)
		MCWB	65.5	66.6	64.0	59.5	55.3	52.4	50.4	50.1	55.7	58.0	61.9	63.9	(22)	(23)
	5%	DB	84.3	81.6	77.9	71.6	65.4	60.0	59.6	63.0	71.7	76.2	80.2	82.5	(23)	(24)
		MCWB	64.8	65.3	63.8	58.9	53.9	51.5	49.8	49.2	54.4	57.4	60.7	63.2	(24)	(25)
	10%	DB	80.6	78.2	74.9	69.0	62.8	57.7	57.2	60.1	67.7	72.6	76.5	79.1	(25)	(26)
		MCWB	64.9	65.1	63.0	58.3	53.1	50.7	48.5	48.0	53.3	56.7	60.0	62.7	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.3	71.7	69.0	64.5	61.1	58.0	58.8	56.9	62.1	65.2	68.4	70.3	(27)	(28)
		MCDB	80.9	81.9	76.6	71.4	65.7	61.1	61.6	66.0	69.2	73.0	80.1	80.7	(28)	(29)
	2%	WB	69.6	69.7	67.5	62.8	58.6	55.7	55.6	54.3	58.7	62.6	65.8	68.2	(29)	(30)
		MCDB	78.6	78.3	74.4	69.1	63.5	58.9	58.4	59.9	68.0	70.5	75.4	77.4	(30)	(31)
	5%	WB	68.4	68.1	66.2	61.3	56.9	54.1	52.6	52.5	56.9	60.9	64.3	66.6	(31)	(32)
		MCDB	76.6	76.0	72.5	67.3	61.8	57.2	56.2	58.6	65.7	69.4	72.7	75.0	(32)	(33)
	10%	WB	67.3	66.6	64.9	59.9	55.4	52.6	50.7	50.8	55.5	59.1	62.8	65.3	(33)	(34)
		MCDB	75.3	74.0	70.9	65.7	59.8	55.8	54.7	57.1	64.0	67.5	71.4	73.3	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.9	17.3	17.5	18.8	20.6	18.3	20.5	23.2	23.5	21.8	20.5	19.4	(35)	(36)
		MCDBR	26.1	24.8	23.5	22.9	24.7	22.6	25.1	28.3	30.0	28.5	26.9	26.1	(36)	(37)
		MCWBR	7.6	7.8	8.7	9.8	12.3	12.0	12.8	12.5	12.4	10.2	8.5	7.9	(37)	(38)
		MCWBR	18.9	19.0	17.8	17.9	16.9	14.9	15.8	18.3	22.2	20.5	19.7	19.4	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub	taub	0.340	0.329	0.311	0.295	0.275	0.270	0.264	0.275	0.308	0.329	0.342	0.343	(39)	(40)
		taud	2.571	2.623	2.674	2.689	2.697	2.711	2.716	2.658	2.540	2.511	2.519	2.548	(40)	(41)
		Ebn at Noon	318	316	312	303	296	291	297	305	308	312	315	318	(41)	(42)
		Edh at Noon	34	31	28	25	23	21	22	25	32	35	36	35	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg	RadAvg	2162	1959	1684	1449	1181	976	1108	1412	1746	1969	2122	2156	(43)	(44)
		RadStd	171	173	104	65	73	71	82	102	143	185	205	205	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-108	+310	+196

Nomenclature: See separate page