

JIMNA, Australia

WMO: 945570

Lat: 26.6644S

Lon: 152.4606E

Elev: 523

StdP: 95.20

Time Zone: 10.00 (E10)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.3	2.8	-3.6	3.0	13.7	-2.0	3.4	11.5	5.2	13.4	4.5	13.5	0.3	180	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.5	31.8	19.9	30.2	19.8	28.7	19.4	22.7	27.2	22.0	26.2	21.4	25.4	2.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	17.3	24.0	20.9	16.6	23.6	20.2	15.9	23.0	70.0	27.2	67.2	26.2	64.9	25.3	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	5.7	5.0	-2.0	35.4	1.0	1.4	-2.7	36.5	-3.3	37.3	-3.9	38.1	-4.7	39.1		
			-2.3	23.8	1.0	0.7	-3.0	24.3	-3.6	24.8	-4.1	25.2	-4.8	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	22.6	22.0	20.4	17.9	14.2	12.1	11.2	12.5	15.6	18.1	20.4	21.9
	DBStd	4.65	2.28	1.93	1.90	1.89	2.32	2.59	2.34	2.71	2.75	2.72	2.60	2.47
	HDD10.0	28	0	0	0	0	1	9	13	6	0	0	0	0
	HDD18.3	891	0	0	3	29	129	186	221	183	91	38	9	2
	CDD10.0	2719	390	335	322	236	132	73	51	82	168	251	312	368
	CDD18.3	542	132	102	67	15	2	0	0	2	8	31	72	112
	CDH23.3	3303	812	484	279	76	11	1	1	19	99	311	483	728
	CDH26.7	886	259	110	54	4	2	0	0	3	16	75	133	229
Wind	WSAvg	1.9	2.4	2.1	2.1	1.8	1.3	1.3	1.3	1.6	1.7	2.2	2.5	2.4
Precipitation	PrecAvg	855	131	148	93	50	49	47	30	38	58	72	127	
	PrecMax	1451	519	481	267	147	123	147	116	128	162	196	169	366
	PrecMin	485	9	13	21	0	2	6	0	0	1	11	8	30
	PrecStd	237	106	105	59	43	33	37	26	33	36	43	46	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.6	32.2	31.1	27.2	24.6	21.5	21.4	25.7	28.6	31.7	32.2	33.5
		MCWB	20.5	22.4	20.4	17.6	15.8	16.1	13.9	15.0	15.4	16.8	18.9	19.7
	2%	DB	31.4	29.5	28.0	25.3	22.5	19.6	19.4	22.6	26.2	28.7	30.1	31.1
		MCWB	20.8	21.4	20.1	17.7	15.0	14.7	12.9	13.6	15.5	16.5	18.4	19.9
	5%	DB	29.6	27.8	26.1	23.9	20.9	18.2	18.1	20.6	24.0	26.7	28.1	29.2
		MCWB	20.5	20.9	19.5	17.3	14.3	13.9	12.4	13.2	14.9	16.2	18.5	19.8
	10%	DB	27.6	26.4	24.7	22.5	19.5	17.1	16.7	18.8	22.3	24.8	26.2	27.4
		MCWB	20.2	20.4	19.0	17.0	14.1	13.6	12.1	12.1	14.2	16.0	18.5	19.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.9	22.6	21.0	18.1	17.5	17.1	17.1	18.8	20.3	21.4	22.8
		MCDB	28.2	29.5	26.0	24.4	22.1	19.6	19.1	22.3	23.7	25.4	27.0	28.5
	2%	WB	22.6	22.9	21.6	19.6	16.7	16.4	15.5	15.6	17.4	18.9	20.5	21.9
		MCDB	27.3	27.0	25.1	22.1	19.9	18.0	16.6	19.9	22.0	23.7	25.7	26.9
	5%	WB	21.9	22.0	20.7	18.7	15.9	15.4	14.0	14.6	16.4	18.1	19.7	21.2
		MCDB	26.1	25.7	24.0	21.7	18.7	17.0	16.8	18.2	20.8	23.0	24.5	25.6
	10%	WB	21.3	21.2	19.9	17.9	15.2	14.4	12.8	13.6	15.5	17.2	19.1	20.6
		MCDB	25.5	24.6	23.3	21.0	17.7	16.2	15.2	17.1	20.0	22.1	23.6	24.7
Mean Daily Temperature Range	5% DB	MDBR	9.5	8.3	8.5	9.6	10.6	9.5	11.2	13.0	12.6	12.3	10.7	10.0
		MCDBR	13.3	11.3	11.4	12.2	13.2	10.9	13.4	15.4	15.8	16.0	13.9	13.4
		MCWBR	4.1	4.1	4.5	5.5	6.8	6.4	7.7	7.3	6.5	5.8	4.2	4.5
	5% WB	MCDBR	10.1	9.5	9.0	8.8	8.7	8.0	9.4	11.4	12.2	12.1	10.6	10.5
		MCWBR	3.6	3.7	4.1	4.6	5.0	5.4	6.1	5.9	5.5	4.9	3.9	4.1
Clear-Sky Solar Irradiance	taub	0.364	0.354	0.335	0.317	0.298	0.291	0.283	0.294	0.328	0.349	0.354	0.370	
	taud	2.522	2.561	2.616	2.647	2.651	2.670	2.682	2.624	2.515	2.486	2.507	2.488	
	Ebn at Noon	979	972	962	936	913	899	923	947	954	966	981	975	
	Edh at Noon	113	106	95	84	76	71	73	84	103	113	114	117	
All-Sky Solar Radiation	RadAvg	6.39	5.86	5.08	4.49	3.78	3.18	3.67	4.55	5.54	6.09	6.57	6.54	
	RadStd	0.57	0.54	0.37	0.29	0.21	0.24	0.31	0.37	0.48	0.58	0.65	0.75	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.34	N/A	N/A	N/A	N/A	N/A	N/A	-62	+176	+109

Nomenclature: See separate page