

SUNSHINE COAST, Australia

WMO: 945690

Lat: 26.6006S

Lon: 153.0903E

Elev: 13

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.9	44.4	29.6	23.7	61.5	33.8	28.5	58.2	22.4	65.9	20.5	64.3	6.1	270	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.2	86.5	75.1	84.8	74.6	83.4	73.9	78.4	83.3	77.2	82.1	76.1	81.0	14.9	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	140.9	81.6	75.7	134.7	80.4	74.5	129.2	79.4	42.0	83.2	40.8	82.4	39.6	81.1	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	21.9	19.9	DB	37.0	93.9	1.8	3.7	35.7	96.6	34.7	98.8	33.7	100.9	32.4	103.6	(4)
(5)			WB	35.9	80.4	1.7	1.6	34.7	81.5	33.7	82.4	32.7	83.3	31.5	84.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.6	76.8	76.6	74.7	70.2	64.8	61.0	59.3	60.4	64.8	68.4	71.9	74.8
	DBStd	7.10	2.74	2.60	2.65	2.98	3.84	4.13	3.98	4.07	3.93	3.69	3.34	3.04
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	572	0	0	0	3	49	127	181	152	50	9	1	0
	CDD50	6791	832	744	767	606	460	331	288	322	444	572	656	769
	CDD65	1890	367	324	302	159	45	9	4	9	44	116	207	304
	CDH74	11119	2771	2366	1811	562	87	10	15	48	160	429	969	1891
	CDH80	1655	504	415	206	27	2	0	1	4	19	56	114	307
Wind	WSAvg	10.4	12.0	12.2	11.3	10.2	9.0	8.8	8.6	9.1	9.8	11.0	11.3	11.6
Precipitation	PrecAvg	64.3	8.5	10.0	8.3	6.2	5.2	4.4	2.7	2.6	2.2	3.5	4.3	6.4
	PrecMax	115.9	27.2	30.2	21.3	15.3	15.0	12.0	9.6	14.1	7.4	11.5	8.9	24.3
	PrecMin	43.6	1.7	1.5	3.0	0.6	0.1	0.9	0.4	0.0	0.1	0.8	0.8	1.5
	PrecStd	16.5	5.6	7.7	4.6	3.1	3.3	3.2	1.9	3.0	1.9	2.3	2.0	4.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.8	88.1	86.0	83.1	78.9	75.4	76.0	78.7	82.6	86.4	86.5	89.1
		MCWB	77.8	76.2	75.4	71.0	67.4	64.8	62.3	62.4	65.1	66.6	70.6	74.6
	2%	DB	85.9	85.6	83.7	80.2	76.3	72.6	72.3	74.5	77.8	80.2	82.8	85.0
		MCWB	75.6	76.0	74.5	70.3	66.4	63.7	61.1	62.1	65.6	69.1	72.4	74.9
	5%	DB	84.3	84.0	82.3	78.6	74.5	70.9	70.0	71.8	75.3	77.8	80.8	83.0
		MCWB	75.0	75.0	73.2	69.6	65.7	62.7	60.8	61.3	65.4	68.6	71.2	73.8
	10%	DB	82.8	82.6	80.9	77.2	72.9	69.2	68.1	69.9	73.5	76.2	79.0	81.5
		MCWB	74.1	73.5	72.3	68.8	64.8	62.0	59.7	60.5	64.4	67.8	70.1	72.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	80.3	78.7	74.6	72.1	69.0	67.6	67.6	70.8	73.6	76.0	78.8
		MCDB	85.1	86.6	82.5	79.3	74.8	71.5	72.2	74.1	76.6	79.1	82.7	84.8
	2%	WB	78.4	78.3	76.6	72.7	69.6	66.8	65.3	65.8	69.0	71.9	74.3	77.1
		MCDB	83.0	83.2	81.3	77.5	73.6	70.0	69.1	71.3	74.8	77.3	80.5	82.8
	5%	WB	77.2	76.8	75.2	71.3	67.9	65.2	63.2	64.2	67.5	70.5	72.9	75.7
		MCDB	81.8	81.5	80.3	76.6	72.4	68.9	67.6	69.5	73.2	75.8	78.7	80.8
	10%	WB	75.9	75.5	73.8	70.2	66.4	63.6	61.5	62.6	66.2	69.1	71.6	74.4
		MCDB	80.7	80.1	79.1	75.4	71.0	67.6	66.3	67.6	71.8	74.4	77.1	79.3
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.2	11.8	13.8	16.1	16.2	18.7	19.9	17.8	14.8	13.5	12.3
		MCDBR	13.5	13.5	13.8	16.0	18.1	17.9	20.9	22.8	20.2	17.9	15.9	14.8
		MCWBR	6.1	6.3	6.7	8.3	9.7	10.2	11.8	12.4	11.1	9.6	8.1	7.5
	5% WB	MCDBR	11.7	12.1	12.3	13.8	14.0	13.3	16.6	18.3	16.7	14.7	13.7	13.2
		MCWBR	6.2	6.8	6.7	7.9	8.3	8.8	10.9	11.4	10.1	8.8	7.7	7.3
Clear-Sky Solar Irradiance	taub	0.396	0.385	0.363	0.346	0.322	0.316	0.307	0.321	0.357	0.378	0.383	0.397	
	taud	2.498	2.537	2.599	2.622	2.643	2.655	2.662	2.600	2.495	2.471	2.491	2.479	
	Ebn at Noon	301	299	296	287	281	276	284	291	293	298	302	301	
	Edh at Noon	37	34	31	28	24	23	24	28	34	36	37	37	
All-Sky Solar Radiation	RadAvg	2089	1918	1653	1422	1178	991	1147	1429	1760	1954	2140	2121	
	RadStd	179	160	115	83	65	74	97	113	135	165	182	233	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.63	N/A	N/A	N/A	N/A	-1.46	N/A	-110	+351	+218	(46)
(47) Regional (24 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-119	+322	+196	(47)

Nomenclature: See separate page