

TEWANTIN, Australia

WMO: 945700

Lat: 26.3911S

Lon: 153.0403E

Elev: 25

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.8	48.2	32.2	26.6	61.1	35.8	30.8	59.9	16.0	65.0	14.4	65.0	1.1	300	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.5	87.3	73.8	84.7	74.1	83.1	73.5	77.9	83.3	76.7	81.9	75.6	80.6	9.2	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.3	137.5	80.6	75.1	132.0	79.8	74.0	127.0	79.0	41.4	83.7	40.2	82.1	39.2	80.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.1	15.3	13.9	41.8	95.8	1.8	4.3	40.5	99.0	39.5	101.5	38.5	103.9	37.2	107.1		
(5)			39.1	79.5	1.7	1.3	37.9	80.5	36.9	81.2	35.9	82.0	34.6	82.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	77.0	76.7	75.2	71.0	65.9	62.1	60.7	62.0	66.3	69.6	72.2	75.2		
	DBStd	6.64	2.83	2.90	2.47	2.76	3.53	3.86	3.59	3.66	3.82	3.83	3.22	3.28		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	412	0	1	0	1	32	101	138	107	28	4	0	0		
	CDD50	7098	838	748	780	631	492	362	333	372	488	608	665	781		
	CDD65	2036	373	329	315	183	59	13	6	14	65	147	216	316		
	CDH74	10990	2699	2317	1772	548	95	13	12	62	230	512	835	1895		
	CDH80	1543	435	347	176	28	2	0	1	5	36	102	90	321		
(14) Wind	WSAvg	6.3	7.6	7.6	7.4	6.3	4.8	4.7	4.5	5.0	6.1	6.8	7.1	7.3		
(15) Precipitation	PrecAvg	66.1	8.4	9.2	8.4	6.7	6.4	4.1	3.8	2.4	1.9	3.5	5.8	6.3		
	PrecMax	103.4	44.6	48.4	22.5	27.4	17.9	23.5	28.1	6.9	5.5	10.6	14.8	15.7		
	PrecMin	34.8	0.7	0.8	1.2	1.1	0.9	0.8	0.3	0.0	0.0	0.2	0.5	0.6		
	PrecStd	16.2	8.1	8.8	6.1	5.0	4.2	5.0	4.8	1.9	1.5	2.5	3.0	4.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.7	89.7	86.7	83.2	79.2	75.8	75.5	79.4	84.2	88.6	87.0	91.6		
		MCWB	77.4	75.7	75.1	70.1	65.8	64.8	63.2	63.3	66.5	68.1	71.1	74.8		
	2%	DB	85.5	85.1	83.7	80.1	76.5	72.9	72.4	75.2	79.6	82.2	82.0	86.2		
		MCWB	75.8	75.5	74.4	70.0	66.1	63.2	61.6	62.0	65.4	68.5	71.8	74.0		
	5%	DB	83.7	83.5	81.8	78.4	74.6	71.0	70.3	72.4	76.2	78.5	79.9	82.9		
		MCWB	74.6	74.6	73.1	69.2	65.1	62.4	60.9	60.9	64.6	68.4	70.8	73.6		
	10%	DB	82.3	81.9	80.4	77.0	73.0	69.3	68.4	70.2	73.8	76.3	78.2	81.1		
		MCWB	73.7	73.2	72.0	68.4	64.2	61.6	59.9	60.4	64.2	67.7	69.8	72.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.3	79.6	78.2	74.6	71.5	68.2	68.0	68.2	70.4	73.5	75.5	78.2		
		MCDB	84.8	85.9	82.7	79.6	74.8	70.8	71.2	75.3	77.0	80.3	81.2	86.1		
	2%	WB	77.6	77.9	76.4	72.3	69.1	66.3	65.8	65.8	69.0	71.7	73.9	76.5		
		MCDB	83.1	82.8	80.5	77.0	73.4	70.0	69.3	71.3	75.2	77.7	79.0	82.6		
	5%	WB	76.5	76.4	75.3	71.0	67.4	64.8	63.6	64.2	67.4	70.4	72.7	75.3		
		MCDB	81.7	81.4	79.5	76.2	72.0	68.7	67.6	69.6	73.6	76.1	77.8	80.7		
	10%	WB	75.4	75.0	74.1	69.8	66.1	63.6	61.9	62.6	66.0	69.1	71.3	74.2		
		MCDB	80.4	80.0	78.6	75.3	70.8	67.5	66.5	67.7	72.0	74.7	76.6	79.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	9.5	10.2	11.8	14.3	14.4	16.2	17.5	15.7	13.0	11.1	10.6		
		MCDBR	11.7	12.0	12.6	13.8	16.4	15.7	18.2	21.1	19.6	17.4	13.7	13.9		
	5% WB	MCWBR	5.1	5.2	5.6	6.2	7.8	8.2	9.3	10.2	8.9	7.9	6.2	6.3		
		MCWBR	11.0	11.3	10.9	11.5	12.3	12.2	14.0	16.5	15.8	14.5	11.9	12.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.393	0.384	0.365	0.344	0.324	0.317	0.307	0.320	0.357	0.378	0.383	0.395		
		taud	2.504	2.539	2.591	2.630	2.634	2.651	2.661	2.604	2.495	2.469	2.491	2.484		
	Ebn at Noon	Ebn at Noon	301	299	296	288	281	277	284	292	293	298	303	301		
		Edh at Noon	36	34	31	27	25	23	24	28	34	36	37	37		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2088	1916	1652	1427	1184	999	1154	1436	1767	1958	2140	2124		
	RadStd	RadStd	178	161	118	88	65	75	98	114	136	165	184	234		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (24 neighbors)	DBAvg	+0.77	N/A	N/A	N/A	+1.31	+1.82	N/A	N/A	N/A
		+0.63	+0.94	N/A	N/A	N/A	N/A	-119	+324	+198

Nomenclature: See separate page