

BRISBANE ARCHERFIELD, Australia

WMO: 945750

Lat: 27.5716S

Lon: 153.0070E

Elev: 43

StdP: 14.67

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.8	44.1	27.1	21.0	62.9	30.5	24.7	60.6	22.9	64.6	20.2	63.3	3.5	190	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.1	91.3	73.1	88.8	72.7	86.7	72.0	77.2	85.8	75.9	83.9	74.8	82.3	12.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.8	130.8	80.3	73.7	125.5	79.8	72.5	120.8	79.0	40.7	85.9	39.5	84.0	38.4	82.4	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.5	16.6	36.6	99.3	2.1	4.0	35.1	102.2	33.8	104.6	32.7	106.8	31.1	109.7		
(5)			35.0	79.4	2.6	1.3	33.1	80.3	31.6	81.1	30.2	81.9	28.3	82.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.7	77.8	76.9	74.6	69.7	64.3	60.0	58.5	60.1	65.4	69.4	73.1	75.7
	DBStd	7.67	3.75	3.50	3.26	3.09	3.54	3.67	3.51	3.60	4.08	4.21	4.27	4.00
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	630	0	0	0	3	55	155	204	160	44	8	1	0
	CDD50	6835	861	753	761	590	443	299	264	312	461	601	694	796
	CDD65	1990	396	333	296	143	33	4	3	7	54	144	245	332
	CDH74	14125	3278	2585	1930	741	159	16	20	96	440	902	1555	2403
	CDH80	3830	1065	777	461	96	6	0	1	11	83	211	414	705
Wind	WSAvg	7.6	8.9	8.4	7.7	6.7	6.2	6.4	6.5	6.9	7.8	8.4	8.8	8.8
Precipitation	PrecAvg	46.3	5.8	6.1	5.2	3.9	4.0	2.7	2.6	1.7	1.2	3.7	4.7	5.3
	PrecMax	77.3	24.5	17.6	18.0	18.2	21.7	19.4	14.8	5.4	3.8	15.6	15.4	17.5
	PrecMin	23.2	0.9	1.2	0.2	0.3	0.2	0.1	0.0	0.0	0.0	0.7	0.4	1.5
	PrecStd	13.2	4.7	4.4	4.3	4.1	4.7	3.9	3.0	1.3	1.1	3.0	3.6	3.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.8	93.3	91.1	85.5	80.5	76.1	76.7	80.8	87.3	90.6	92.3	93.9
		MCWB	75.5	75.1	74.3	68.2	64.3	62.8	60.5	62.3	62.9	65.6	69.4	72.1
	2%	DB	90.6	89.6	87.0	82.6	77.6	73.0	72.9	76.4	81.9	85.0	87.5	89.3
		MCWB	75.1	74.7	72.5	67.6	63.5	60.9	58.8	59.9	63.8	67.0	70.6	72.8
	5%	DB	87.8	87.0	84.5	80.5	75.6	71.0	70.6	73.4	78.7	81.8	84.5	86.3
		MCWB	73.8	73.3	71.0	67.0	62.7	60.2	58.1	58.9	62.6	66.4	69.4	71.9
	10%	DB	85.5	84.7	82.4	78.3	73.6	69.0	68.5	70.9	75.9	79.0	81.9	83.9
		MCWB	72.7	72.2	70.2	66.0	62.3	59.4	57.1	57.5	61.8	65.5	68.6	70.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	78.6	77.0	72.9	71.0	66.6	66.2	66.4	69.6	72.5	75.3	77.1
		MCDB	87.7	89.2	83.7	78.5	72.9	70.1	72.5	74.8	78.7	81.8	84.7	88.0
	2%	WB	77.4	77.1	75.0	70.8	68.3	64.6	63.5	64.1	67.6	70.7	73.4	75.3
		MCDB	86.1	85.1	82.6	77.7	73.2	69.0	67.9	70.5	75.7	79.0	81.8	84.5
	5%	WB	76.1	75.7	73.7	69.4	66.2	63.1	61.3	62.0	66.2	69.1	72.0	74.1
		MCDB	84.0	82.9	80.8	76.5	71.9	68.0	66.7	68.8	73.8	77.0	80.3	82.2
	10%	WB	74.8	74.4	72.5	68.0	64.5	61.5	59.3	60.3	64.6	67.7	70.6	72.9
		MCDB	82.0	81.3	79.5	75.1	70.6	66.8	65.7	67.4	72.2	75.4	78.7	80.3
Mean Daily Temperature Range	5% DB	MDBR	15.1	15.1	16.2	18.5	20.0	19.2	22.0	23.8	22.4	19.0	16.7	15.7
		MCDBR	18.1	18.2	19.1	21.3	22.5	21.5	25.0	27.3	26.2	23.1	19.8	18.8
		MCWBR	6.2	6.2	6.8	8.6	10.3	11.1	12.7	12.9	10.9	9.2	7.2	6.9
		MCDDBR	16.1	15.7	15.9	17.7	16.1	16.6	18.9	21.6	20.7	19.8	17.6	16.4
	5% WB	MCWBR	6.4	6.0	6.6	8.0	8.6	9.6	11.2	11.8	9.8	8.8	7.1	6.8
Clear-Sky Solar Irradiance	taub	0.390	0.379	0.358	0.339	0.318	0.313	0.301	0.315	0.358	0.378	0.383	0.396	
	taud	2.494	2.535	2.590	2.623	2.632	2.641	2.659	2.597	2.472	2.450	2.474	2.463	
	Ebn at Noon	302	300	297	288	281	276	285	292	292	297	302	301	
	Edh at Noon	37	34	31	27	24	23	23	27	34	37	37	38	
All-Sky Solar Radiation	RadAvg	2063	1892	1633	1405	1170	966	1124	1406	1728	1919	2092	2074	
	RadStd	169	161	97	71	62	69	88	105	136	174	179	217	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.70	+1.44	N/A	N/A	N/A	-1.03	N/A	-135	+313	+187
(47) Regional (28 neighbors)		+0.74	+0.94	N/A	N/A	N/A	N/A	N/A	-121	+335	+202

Nomenclature: See separate page