

BRISBANE RAYMOND PARK, Australia

WMO: 945760

Lat: 27.4808S

Lon: 153.0389E

Elev: 27

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 46.6	(c) 48.7	(d) 27.6	(e) 21.5	(f) 63.9	(g) 31.2	(h) 25.5	(i) 62.7	(j) 14.7	(k) 64.3	(l) 12.8	(m) 63.0	(n) 2.5	(o) 220	(p) 0.282

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 13.0	(c) 90.4	(d) 73.5	(e) 88.1	(f) 73.3	(g) 86.3	(h) 72.5	(i) 77.2	(j) 85.9	(k) 76.0	(l) 84.1	(m) 75.0	(n) 82.6	(o) 8.1	(p) 30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.6	129.6	81.6	73.5	125.0	80.7	72.5	120.5	79.9	40.7	86.1	39.5	84.3	38.5	82.5	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 16.2	(b) 12.9	(c) 11.2	(e) 42.1	(f) 96.3	(g) 2.5	(h) 2.8	(i) 40.3	(j) 98.3	(k) 38.9	(l) 100.0	(m) 37.5	(n) 101.6	(o) 35.7	(p) 103.6		
			DB													
			WB													
				38.4	79.5	2.1	1.6	36.9	80.6	35.6	81.5	34.4	82.4	32.9	83.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	78.4	77.9	75.5	71.3	65.9	62.0	60.8	62.2	66.8	70.5	73.9	76.7
	DBStd	7.05	3.24	3.29	2.95	2.73	3.17	3.43	3.22	3.30	3.70	3.88	3.67	3.66
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	384	0	0	0	1	26	98	137	99	20	3	0	0
	CDD50	7342	881	781	790	640	494	361	333	378	505	635	717	827
	CDD65	2254	416	361	325	190	56	10	6	13	75	173	267	362
	CDH74	15138	3487	2872	2061	826	189	20	23	106	413	908	1564	2669
	CDH80	3714	1028	845	442	91	8	0	1	13	71	171	315	729
(14) Wind	WSAvg	4.6	5.6	5.3	4.9	4.1	3.7	3.7	3.6	3.8	4.5	4.9	5.3	5.3
(15) Precipitation	PrecAvg	46.6	6.4	5.4	5.2	3.9	3.5	2.6	2.4	1.6	1.4	3.7	4.6	5.2
	PrecMax	86.4	34.3	17.2	18.9	21.6	16.1	25.5	13.0	5.5	4.8	18.0	16.3	16.1
	PrecMin	23.9	1.0	1.1	0.2	0.4	0.2	0.1	0.0	0.0	0.0	0.1	0.3	1.5
	PrecStd	13.8	6.0	3.9	4.2	4.7	3.5	4.5	2.8	1.3	1.2	3.3	3.2	2.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.4	92.9	90.3	85.0	80.8	76.3	76.5	81.2	86.7	88.8	89.2	94.0
		MCWB	75.7	75.0	74.5	69.7	64.9	63.5	60.3	61.3	63.4	66.6	70.9	70.9
	2%	DB	89.3	89.2	86.7	82.5	78.2	73.6	73.5	76.6	81.4	84.2	85.7	89.0
		MCWB	75.0	74.8	72.9	68.6	64.0	61.7	59.7	60.3	63.8	67.0	71.3	72.5
	5%	DB	87.2	87.2	84.3	80.6	76.1	71.5	71.3	73.8	78.3	81.3	83.5	86.1
		MCWB	74.0	73.8	71.8	67.6	62.9	60.5	58.6	59.5	63.3	66.9	69.9	72.3
	10%	DB	85.2	85.0	82.3	78.8	74.0	69.6	69.2	71.5	75.9	78.9	81.4	83.9
		MCWB	73.0	72.7	70.6	67.0	62.2	59.8	57.8	58.2	62.4	66.0	69.0	71.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.8	79.0	76.5	73.4	69.6	67.0	66.7	67.1	69.8	72.8	75.4	77.2
		MCDB	87.9	88.9	84.2	79.8	75.6	71.5	72.1	74.6	78.8	82.4	85.0	87.7
	2%	WB	77.3	77.2	75.2	71.4	67.1	64.8	64.2	64.7	67.8	71.1	73.4	75.5
		MCDB	85.7	85.8	82.5	78.4	74.4	69.8	68.7	71.8	75.9	79.6	81.5	84.5
	5%	WB	76.0	75.8	74.1	69.9	65.6	63.4	61.8	62.7	66.4	69.6	72.0	74.4
		MCDB	83.8	83.7	81.2	77.1	72.7	68.7	67.6	69.8	74.5	77.4	80.3	82.6
	10%	WB	74.9	74.5	72.9	68.6	64.4	62.0	60.0	60.9	65.0	68.1	70.9	73.3
		MCDB	82.2	82.1	79.8	75.9	70.9	67.3	66.5	68.3	72.7	76.1	79.0	81.0
(35) Mean Daily Temperature Range	MDBR		13.0	13.4	13.8	15.3	17.2	16.0	18.4	19.9	18.8	16.2	14.1	13.6
	5% DB	MCDBR	15.2	16.1	16.3	17.8	19.7	18.2	21.1	23.2	22.4	19.8	16.4	16.5
		MCWBR	5.6	5.6	5.9	6.9	8.3	8.8	10.0	10.6	9.3	8.3	6.8	6.8
	5% WB	MCDBR	13.8	14.7	13.9	14.9	15.5	13.9	15.8	19.6	18.4	17.0	14.4	14.8
		MCWBR	5.8	5.9	5.9	6.6	7.2	7.9	8.9	10.6	8.5	8.1	6.6	6.7
(40) Clear-Sky Solar Irradiance	taub		0.391	0.380	0.359	0.340	0.320	0.313	0.303	0.316	0.359	0.379	0.383	0.396
	taud		2.495	2.535	2.594	2.626	2.630	2.644	2.659	2.598	2.475	2.452	2.477	2.465
	Ebn at Noon		302	300	297	288	281	276	284	292	292	297	302	301
	Edh at Noon		37	34	31	27	24	23	23	27	34	37	37	38
(44) All-Sky Solar Radiation	RadAvg		2065	1897	1638	1408	1171	967	1126	1408	1731	1922	2098	2078
	RadStd		168	160	98	72	62	69	88	105	135	172	178	218

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+1.69	N/A	N/A	N/A	N/A	N/A	-126	+365	N/A
(47) Regional (28 neighbors)	+0.74	+0.94	N/A	N/A	N/A	N/A	N/A	-121	+335	+202

Nomenclature: See separate page