

BRISBANE AP, Australia

WMO: 945780

Lat: 27.3917S

Lon: 153.1292E

Elev: 31

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	42.8	45.6	23.2	17.5	66.4	28.2	22.2	63.2	24.3	62.0	21.6	62.1	5.6	230	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	87.5	73.5	85.5	73.6	84.0	72.6	77.6	83.2	76.4	82.0	75.4	80.9	14.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.6	134.3	81.0	74.8	130.5	80.3	73.5	124.7	79.2	41.2	83.0	40.0	82.0	38.9	81.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	20.0	17.8	38.2	94.4	2.2	3.8	36.5	97.1	35.2	99.3	34.0	101.5	32.3	104.2		
(5)			35.8	79.9	2.2	1.3	34.2	80.8	32.9	81.5	31.7	82.2	30.1	83.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.5	77.0	76.5	74.4	69.8	64.7	60.7	59.0	60.3	65.0	68.6	72.1	74.9	(6)	(7)
	DBStd	7.10	3.01	2.94	2.74	2.83	3.41	3.69	3.51	3.42	3.67	3.55	3.52	3.28	(7)	(8)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD65	577	0	0	0	3	46	135	190	150	44	8	1	0	(9)	(10)
	CDD50	6766	836	742	758	595	456	320	278	320	449	576	664	772	(10)	(11)
	CDD65	1868	371	322	293	148	37	5	3	5	43	119	215	307	(11)	(12)
	CDH74	11585	2873	2387	1786	611	106	8	10	33	204	482	1073	2012	(12)	(13)
	CDH80	1953	599	491	245	37	3	0	1	4	29	60	139	345	(13)	(14)
(14) Wind	WSAvg	9.1	10.1	9.4	8.8	8.1	7.7	8.0	8.0	8.4	9.5	10.2	10.6	10.4	(14)	(15)
(15) Precipitation	PrecAvg	44.1	5.9	5.7	5.1	3.4	3.5	2.8	2.0	1.6	1.3	3.5	4.0	5.0	(15)	(16)
	PrecMax	85.4	31.7	16.9	16.3	19.8	15.0	27.6	15.7	5.0	4.0	16.0	16.1	17.8	(16)	(17)
	PrecMin	24.0	0.4	0.6	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.2	0.6	1.3	(17)	(18)
	PrecStd	13.7	5.0	4.3	3.8	3.7	3.0	4.1	2.6	1.4	1.1	3.1	2.8	3.3	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	89.3	86.5	83.0	79.0	75.2	75.1	77.4	83.9	85.9	87.7	89.8	(19)	(20)
		MCWB	75.9	75.7	73.9	68.1	63.2	62.3	58.2	57.9	59.7	62.7	66.3	68.9	(20)	(21)
	2%	DB	86.4	86.3	84.3	80.7	76.7	72.7	71.9	73.8	78.7	80.7	83.2	85.8	(21)	(22)
		MCWB	75.4	75.2	72.8	68.4	63.7	61.5	58.9	59.2	61.7	66.5	70.5	73.1	(22)	(23)
	5%	DB	84.6	84.5	82.6	79.0	75.0	70.9	70.0	71.8	75.7	78.5	81.0	83.3	(23)	(24)
		MCWB	74.0	73.9	71.7	67.6	63.3	60.5	58.3	58.9	62.7	67.1	70.2	72.7	(24)	(25)
	10%	DB	83.1	82.8	80.9	77.4	73.3	69.2	68.2	70.0	73.7	76.6	79.1	81.6	(25)	(26)
		MCWB	73.0	72.5	70.6	66.9	62.6	59.6	57.3	58.2	62.3	66.3	69.1	71.6	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	79.4	77.4	73.8	70.6	66.9	66.4	67.1	69.8	72.8	75.4	77.9	(27)	(28)
		MCDB	85.0	85.5	82.2	78.3	73.7	70.5	70.3	72.1	75.5	78.1	81.5	84.3	(28)	(29)
	2%	WB	77.8	77.5	75.9	71.6	68.5	65.0	63.9	64.6	68.1	71.2	73.8	76.2	(29)	(30)
		MCDB	83.3	83.1	80.7	76.9	72.7	69.1	67.8	69.5	73.4	76.6	79.8	82.1	(30)	(31)
	5%	WB	76.5	76.2	74.5	70.1	66.7	63.6	61.8	62.9	66.8	69.7	72.5	74.9	(31)	(32)
		MCDB	82.0	81.9	79.7	75.9	71.7	68.0	66.4	68.0	72.2	75.2	78.4	80.6	(32)	(33)
	10%	WB	75.2	74.7	73.3	69.0	65.2	62.1	60.0	61.1	65.3	68.3	71.2	73.7	(33)	(34)
		MCDB	80.8	80.5	78.7	74.9	70.4	66.7	65.3	66.7	71.1	74.0	77.2	79.2	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.8	13.7	16.0	17.7	17.5	19.8	20.6	19.0	16.0	14.1	13.2	(35)	(36)
		MCDBR	13.9	14.3	15.2	17.6	19.5	18.8	21.7	22.8	21.5	18.5	15.9	15.2	(36)	(37)
		MCWBR	6.1	6.2	6.5	8.1	9.6	10.0	11.5	12.1	10.9	9.8	7.7	7.5	(37)	(38)
	5% WB	MCDBR	13.0	13.0	12.8	15.0	14.2	14.8	16.6	18.9	17.0	15.5	14.2	13.3	(38)	(39)
		MCWBR	6.6	6.5	6.4	7.7	8.0	9.0	10.4	11.7	9.8	9.3	7.9	7.3	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.391	0.381	0.359	0.340	0.322	0.314	0.304	0.317	0.359	0.378	0.383	0.396	(40)	(41)
	taud		2.501	2.539	2.602	2.633	2.630	2.649	2.664	2.602	2.480	2.460	2.484	2.474	(41)	(42)
	Ebn at Noon		302	300	297	288	280	276	284	292	292	297	302	301	(42)	(43)
	Edh at Noon		36	34	30	27	25	23	23	27	34	37	37	38	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		2070	1902	1642	1407	1168	966	1125	1407	1732	1925	2105	2084	(44)	(45)
	RadStd		168	157	100	73	61	69	88	104	134	168	174	219	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.85	+2.05	N/A	N/A	N/A	N/A	N/A	-106	+292	+173
(47) Regional (27 neighbors)		+0.74	+0.94	N/A	N/A	N/A	N/A	N/A	-121	+335	+202

Nomenclature: See separate page