

BRISBANE AP, Australia

WMO: 945780

Lat: 27.3917S

Lon: 153.1292E

Elev: 10

StdP: 101.21

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	7.6	-4.9	2.5	19.1	-2.1	3.2	17.3	10.9	16.7	9.6	16.7	2.5	230	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.0	30.8	23.1	29.7	23.1	28.9	22.6	25.4	28.5	24.7	27.8	24.1	27.2	6.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.2	27.2	23.8	18.6	26.8	23.0	17.8	26.2	77.9	28.3	75.1	27.8	72.6	27.3	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.9	8.0	3.4	34.7	1.2	2.1	2.5	36.2	1.8	37.4	1.1	38.6	0.2	40.1		
			2.1	26.6	1.2	0.7	1.2	27.1	0.5	27.5	-0.2	27.9	-1.0	28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	25.0	24.7	23.6	21.0	18.2	15.9	15.0	15.7	18.3	20.3	22.3	23.8
	DBStd	3.94	1.67	1.63	1.52	1.57	1.90	2.05	1.95	1.90	2.04	1.97	1.96	1.82
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	321	0	0	0	2	26	75	106	83	24	4	1	0
	CDD10.0	3759	464	412	421	331	253	178	154	178	249	320	369	429
	CDD18.3	1038	206	179	163	82	21	3	2	3	24	66	119	171
	CDH23.3	6436	1596	1326	992	339	59	4	6	18	113	268	596	1118
CDH26.7	1085	333	273	136	21	2	0	1	2	16	33	77	192	
Wind	WSAvg	4.1	4.5	4.2	3.9	3.6	3.5	3.6	3.6	3.8	4.2	4.5	4.7	4.6
Precipitation	PrecAvg	1120	150	145	130	86	88	71	51	41	33	90	102	127
	PrecMax	2170	804	428	414	502	382	701	399	126	102	407	408	453
	PrecMin	610	9	15	6	3	3	1	1	0	0	4	16	32
	PrecStd	349	127	108	97	95	77	103	66	36	27	79	71	84
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	31.8	30.3	28.4	26.1	24.0	24.0	25.2	28.8	30.0	30.9	32.1
		MCWB	24.4	24.3	23.3	20.1	17.3	16.8	14.5	14.4	15.4	17.1	19.1	20.5
	2%	DB	30.2	30.2	29.0	27.1	24.9	22.6	22.2	23.2	25.9	27.1	28.4	29.9
		MCWB	24.1	24.0	22.7	20.2	17.6	16.4	14.9	15.1	16.5	19.2	21.4	22.8
	5%	DB	29.2	29.2	28.1	26.1	23.9	21.6	21.1	22.1	24.3	25.8	27.2	28.5
		MCWB	23.3	23.3	22.1	19.8	17.4	15.9	14.6	14.9	17.1	19.5	21.2	22.6
	10%	DB	28.4	28.2	27.2	25.2	22.9	20.7	20.1	21.1	23.2	24.8	26.2	27.5
MCWB		22.8	22.5	21.4	19.4	17.0	15.4	14.1	14.6	16.8	19.0	20.6	22.0	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.4	25.2	23.2	21.5	19.4	19.1	19.5	21.0	22.7	24.1	25.5
		MCDB	29.5	29.7	27.9	25.7	23.1	21.4	21.3	22.3	24.2	25.6	27.5	29.1
	2%	WB	25.4	25.3	24.4	22.0	20.3	18.3	17.7	18.1	20.1	21.8	23.2	24.6
		MCDB	28.5	28.4	27.1	24.9	22.6	20.6	19.9	20.8	23.0	24.8	26.5	27.8
	5%	WB	24.7	24.5	23.6	21.2	19.3	17.5	16.6	17.2	19.3	20.9	22.5	23.8
		MCDB	27.8	27.7	26.5	24.4	22.0	20.0	19.1	20.0	22.3	24.0	25.8	27.0
	10%	WB	24.0	23.7	23.0	20.6	18.4	16.7	15.6	16.2	18.5	20.1	21.8	23.2
MCDB		27.1	27.0	25.9	23.8	21.4	19.3	18.5	19.3	21.7	23.3	25.1	26.2	
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.1	7.6	8.9	9.8	9.7	11.0	11.4	10.6	8.9	7.8	7.4
		MCDBR	7.7	7.9	8.4	9.8	10.9	10.5	12.0	12.7	11.9	10.3	8.8	8.4
		MCWBR	3.4	3.4	3.6	4.5	5.3	5.5	6.4	6.7	6.0	5.5	4.3	4.2
	5% WB	MCDBR	7.2	7.2	7.1	8.3	7.9	8.2	9.2	10.5	9.4	8.6	7.9	7.4
		MCWBR	3.7	3.6	3.6	4.3	4.4	5.0	5.8	6.5	5.5	5.2	4.4	4.0
Clear-Sky Solar Irradiance	taub	0.391	0.381	0.359	0.340	0.322	0.314	0.304	0.317	0.359	0.378	0.383	0.396	
	taud	2.501	2.539	2.602	2.633	2.630	2.649	2.664	2.602	2.480	2.460	2.484	2.474	
	Ebn at Noon	952	945	937	909	883	869	896	920	921	937	953	949	
	Edh at Noon	115	108	96	85	78	72	74	86	107	116	116	119	
All-Sky Solar Radiation	RadAvg	6.53	6.00	5.17	4.43	3.68	3.04	3.55	4.44	5.46	6.07	6.63	6.57	
	RadStd	0.53	0.50	0.32	0.23	0.19	0.22	0.28	0.33	0.42	0.53	0.55	0.69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.47	+1.14	N/A	N/A	N/A	N/A	N/A	-59	+162	+96
(47) Regional (27 neighbors)		+0.41	+0.52	N/A	N/A	N/A	N/A	N/A	-67	+186	+112

Nomenclature: See separate page