

DOUBLE ISLAND POINT, Australia

WMO: 945840

Lat: 25.9319S

Lon: 153.1906E

Elev: 314

StdP: 14.53

Time Zone: 10.00 (E10)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	53.2	55.7	29.2	23.4	60.0	33.1	28.0	59.5	43.8	62.3	40.2	63.1	14.7	230	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	87.8	75.7	86.1	74.8	84.4	73.8	78.4	83.7	77.3	82.5	76.2	81.3	10.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	142.8	81.0	75.8	136.5	80.3	74.7	131.4	79.6	42.2	84.0	41.0	82.6	40.0	81.2	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.2	35.4	32.1	DB	49.3	92.5	2.5	2.6	47.5	94.4	46.0	95.9	44.6	97.4	42.7	99.2	(4)
(5)			WB	40.9	80.8	2.1	1.6	39.4	81.9	38.1	82.9	36.9	83.7	35.4	84.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.6	78.6	78.3	76.7	73.1	68.3	64.7	63.4	65.0	68.8	71.7	74.5	76.9	(6)	
	DBStd	6.15	2.83	2.81	2.58	2.88	3.36	3.68	3.42	3.55	3.28	3.00	3.13	3.16	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	182	0	0	0	0	10	48	72	44	7	1	0	0	(9)	
	CDD50	7898	887	791	829	694	567	442	416	466	565	671	736	834	(10)	
	CDD65	2604	422	371	364	244	112	40	22	45	122	207	286	369	(11)	
	CDH74	12134	2970	2513	1889	574	91	14	8	40	196	513	1162	2164	(12)	
	CDH80	2147	656	473	264	45	3	0	0	0	11	46	189	460	(13)	
(14) Wind	WSAvg	16.8	17.3	19.5	19.5	18.9	16.3	16.8	16.1	15.7	15.3	15.5	14.8	16.1	(14)	
(15) Precipitation	PrecAvg	61.8	7.6	7.3	6.9	5.7	6.6	5.2	4.2	2.8	1.7	3.5	4.6	5.7	(15)	
	PrecMax	98.0	28.4	24.2	24.2	13.6	17.1	22.9	26.6	9.8	4.8	10.5	11.1	10.5	(16)	
	PrecMin	29.8	1.2	0.9	0.7	1.3	1.5	1.2	0.5	0.0	0.0	0.0	0.8	0.6	(17)	
	PrecStd	15.6	5.9	5.4	4.8	3.3	3.9	4.5	4.5	2.0	1.3	2.7	2.7	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	89.7	88.0	84.3	79.3	75.8	75.2	77.7	81.5	83.9	86.7	89.1	(19)	
		MCWB	77.1	77.3	76.0	72.0	68.4	67.0	64.8	64.9	69.0	70.9	73.1	75.7	(20)	
	2%	DB	87.6	87.1	85.0	81.0	76.5	73.1	72.2	74.9	78.5	81.0	84.1	86.6	(21)	
		MCWB	76.0	76.1	74.6	70.6	67.0	64.9	62.7	63.6	67.1	69.4	71.9	74.7	(22)	
	5%	DB	85.6	85.0	82.9	78.9	74.3	70.9	69.8	72.5	76.2	78.9	82.1	84.5	(23)	
		MCWB	74.8	75.0	73.2	69.4	65.8	63.5	61.1	62.2	65.7	68.5	70.9	73.4	(24)	
	10%	DB	83.8	82.9	80.9	77.1	72.6	69.3	68.0	70.2	74.2	76.9	80.2	82.6	(25)	
		MCWB	74.0	73.9	72.2	68.8	65.0	62.8	60.9	61.2	64.5	67.2	69.6	72.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.7	79.7	79.4	75.9	71.8	69.4	67.8	68.1	71.1	74.1	75.3	78.3	(27)	
		MCDB	86.8	86.3	82.6	79.7	74.6	73.4	71.4	74.5	78.4	80.2	83.6	85.6	(28)	
	2%	WB	78.5	77.9	77.7	72.9	70.1	67.1	65.4	66.2	69.3	72.3	73.7	76.9	(29)	
		MCDB	83.9	83.7	81.1	77.7	73.4	70.4	69.0	71.5	75.5	77.4	81.1	83.3	(30)	
	5%	WB	77.2	76.7	76.1	71.4	68.5	65.8	63.7	64.8	68.0	70.9	72.5	75.7	(31)	
		MCDB	82.2	82.1	80.1	76.2	72.1	69.4	67.8	69.4	73.6	75.7	79.2	81.3	(32)	
	10%	WB	75.9	75.6	74.5	70.2	67.1	64.4	62.3	63.6	66.6	69.5	71.4	74.5	(33)	
		MCDB	80.9	80.7	79.0	75.0	71.1	68.3	66.8	68.1	71.9	74.4	77.4	79.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	8.9	8.6	7.7	7.9	7.8	8.6	10.0	10.7	10.6	10.8	10.5	(35)	
		MCDBR	12.3	11.9	11.3	10.2	9.8	9.4	11.2	13.2	13.6	13.4	13.4	13.4	(36)	
	5% WB	MCWBR	5.7	5.4	5.4	5.4	5.9	6.3	7.1	7.5	7.0	6.8	6.2	6.1	(37)	
		MCWBR	11.7	10.7	10.8	9.2	8.4	8.5	9.4	11.5	12.3	12.3	12.5	12.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.380	0.364	0.341	0.321	0.315	0.305	0.318	0.350	0.372	0.375	0.385	(40)	
		taud	2.532	2.560	2.601	2.650	2.656	2.665	2.676	2.622	2.525	2.494	2.518	2.522	(41)	
	Ebn at Noon		303	301	297	290	283	278	285	293	296	300	305	305	(42)	
		Edh at Noon	36	34	31	27	24	23	23	27	33	36	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2119	1935	1676	1442	1192	1013	1161	1445	1782	1974	2162	2148	(44)	
	RadStd		166	161	121	93	62	75	101	112	128	156	176	228	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.63	+1.06	N/A	N/A	N/A	N/A	N/A	-128	+340	+203

Nomenclature: See separate page