

CAPE MORETON LH, Australia

WMO: 945940

Lat: 27.0314S

Lon: 153.4661E

Elev: 101

StdP: 100.12

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	12.5	0.4	3.9	15.1	2.1	4.5	15.0	18.5	17.2	16.4	17.6	7.2	240	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.7	28.6	23.6	27.9	23.4	27.3	23.0	25.4	26.9	24.8	26.5	24.2	26.2	6.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.2	26.3	24.2	19.4	26.0	23.6	18.7	25.7	78.7	27.0	76.2	26.6	74.0	26.2	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.3	14.7	9.5	30.4	1.0	1.4	8.8	31.4	8.2	32.2	7.6	33.0	6.9	33.9		
(5)			5.7	26.1	1.0	0.7	5.0	26.7	4.4	27.1	3.8	27.5	3.1	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.2	25.0	25.0	24.2	22.1	19.7	17.4	16.8	17.5	19.4	20.9	22.6	23.9		
	DBStd	3.31	1.34	1.34	1.31	1.54	1.78	1.98	1.82	1.75	1.57	1.54	1.42	1.49		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	148	0	0	0	1	8	39	53	37	8	2	0	0		
	CDD10.0	4083	464	420	441	364	299	223	211	232	282	338	377	432		
	CDD18.3	1190	206	187	183	114	49	13	6	11	41	81	127	173		
	CDH23.3	4276	1203	1097	789	175	14	0	0	1	7	53	236	700		
	CDH26.7	275	102	92	36	1	0	0	0	0	0	2	3	39		
(14) Wind	WSAvg	8.0	8.6	9.0	8.9	8.4	7.6	7.3	6.9	7.2	7.6	7.9	8.0	8.2		
(15) Precipitation	PrecAvg	1532	152	148	162	141	169	154	123	81	51	94	110	135		
	PrecMax	2448	719	438	403	437	455	586	569	164	168	385	344	372		
	PrecMin	888	37	24	19	22	21	29	7	3	0	5	14	15		
	PrecStd	364	128	103	111	103	103	110	100	44	44	74	65	85		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.4	29.5	28.6	26.7	24.7	22.5	21.6	22.5	24.1	25.7	27.1	28.7		
		MCWB	24.3	24.0	23.6	21.3	19.6	18.5	17.3	17.2	18.0	19.5	21.7	22.3		
	2%	DB	28.5	28.5	27.6	25.7	23.6	21.7	20.8	21.5	23.1	24.6	26.1	27.6		
		MCWB	23.9	23.9	23.2	21.1	19.0	17.8	17.1	17.1	18.3	20.2	21.5	22.9		
	5%	DB	27.8	27.8	26.9	25.0	22.8	21.0	20.2	20.7	22.4	23.8	25.4	26.9		
		MCWB	23.6	23.4	22.7	20.6	18.8	17.4	16.6	16.6	18.1	19.8	21.1	22.6		
	10%	DB	27.1	27.1	26.2	24.3	22.2	20.4	19.6	20.1	21.7	23.1	24.7	26.2		
		MCWB	23.2	23.0	22.4	20.3	18.4	17.0	16.0	16.4	17.8	19.4	20.8	22.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.0	25.7	23.5	21.7	20.1	19.9	19.8	21.3	23.0	24.1	25.3		
		MCDB	27.5	27.5	26.8	25.2	22.8	21.3	20.7	21.2	22.5	23.9	25.1	26.8		
	2%	WB	25.4	25.2	24.7	22.3	20.9	19.1	18.9	18.9	20.4	21.8	23.1	24.5		
		MCDB	27.0	26.9	26.3	24.5	22.5	20.6	20.1	20.4	21.8	23.3	24.5	26.2		
	5%	WB	24.8	24.6	24.0	21.6	19.9	18.3	17.7	18.0	19.7	21.1	22.6	23.9		
		MCDB	26.6	26.6	26.0	24.0	22.1	20.2	19.5	20.0	21.4	22.8	24.2	25.7		
	10%	WB	24.2	24.1	23.3	21.0	19.2	17.6	16.8	17.2	19.0	20.5	21.9	23.3		
		MCDB	26.2	26.3	25.4	23.7	21.6	19.8	19.1	19.5	20.9	22.3	23.9	25.3		
(35) Mean Daily Temperature Range	MDBR		3.7	3.7	3.6	3.8	4.2	4.2	4.5	4.5	4.2	4.0	3.9	3.9		
	5% DB	MCDBR	4.4	4.4	4.3	4.2	4.4	4.1	4.4	4.7	4.6	4.6	4.5	4.7		
		MCWBR	2.3	2.3	2.4	2.5	2.8	2.9	3.4	3.5	3.2	3.0	2.5	2.7		
	5% WB	MCDBR	4.0	3.9	3.9	3.7	3.7	3.7	3.8	4.0	3.8	4.1	3.9	4.3		
		MCWBR	2.5	2.4	2.5	2.7	2.9	3.1	3.7	3.6	3.2	3.2	2.5	2.8		
(40) Clear-Sky Solar Irradiance	taub		0.384	0.375	0.355	0.338	0.319	0.313	0.303	0.316	0.352	0.371	0.372	0.387		
	taud		2.538	2.572	2.629	2.658	2.658	2.671	2.685	2.626	2.518	2.495	2.528	2.514		
	Ebn at Noon		958	951	941	914	888	873	898	922	929	944	963	958		
	Edh at Noon		111	105	94	83	76	71	73	84	103	112	111	114		
(44) All-Sky Solar Radiation	RadAvg		6.64	6.11	5.25	4.44	3.65	3.04	3.54	4.43	5.49	6.13	6.76	6.68		
	RadStd		0.53	0.47	0.34	0.23	0.19	0.21	0.28	0.33	0.40	0.49	0.51	0.70		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-66	+179	+109

Nomenclature: See separate page