

EVANS HEAD, Australia

WMO: 945980

Lat: 29.183S

Lon: 153.396E

Elev: 207

StdP: 14.59

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	47.1	49.0	28.5	22.7	57.2	32.1	26.7	56.6	25.7	61.6	22.7	62.2	8.9	340	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	90.4	73.4	86.9	72.6	83.9	72.0	77.1	84.5	75.8	82.0	74.6	80.1	12.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.3	133.8	78.8	74.1	128.3	78.0	73.0	123.6	77.2	40.7	84.7	39.5	82.5	38.3	80.1	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.7	23.9	20.7	DB	42.5	99.4	1.5	4.2	41.4	102.4	40.5	104.8	39.7	107.1	38.6	110.2	
			WB	38.0	79.3	1.5	1.9	36.9	80.7	36.0	81.8	35.2	82.9	34.1	84.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	74.9	74.5	72.7	68.5	63.5	59.9	58.8	60.5	64.8	67.6	70.8	73.2
	DBStd	6.81	3.73	3.54	3.21	3.35	3.39	3.44	3.50	4.01	4.40	4.54	4.28	3.98
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	662	0	0	0	8	68	157	196	152	56	21	3	1
	CDD50	6367	771	687	704	555	420	296	273	325	444	546	625	721
	CDD65	1553	306	267	239	114	23	3	3	12	49	103	178	256
	CDH74	7821	1819	1426	930	289	67	7	20	98	282	564	919	1400
	CDH80	1893	484	319	158	38	5	0	0	17	65	167	263	377
(14) Wind	WSAvg	10.5	11.2	11.5	10.8	10.9	9.3	9.9	9.1	9.7	10.1	11.1	11.1	10.9
(15) Precipitation	PrecAvg	54.4	6.4	7.0	6.8	5.1	4.4	5.6	2.7	3.2	1.9	2.9	3.9	4.6
	PrecMax	85.0	16.0	13.4	18.7	13.1	19.0	17.0	8.5	12.1	5.6	14.4	8.6	10.9
	PrecMin	35.2	1.0	2.2	0.7	0.6	0.0	0.6	0.3	0.6	0.1	0.6	0.7	0.8
	PrecStd	12.1	4.0	3.4	4.3	3.3	3.9	3.8	2.0	3.1	1.3	2.7	2.2	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.3	92.8	89.7	84.3	80.0	74.3	76.9	81.5	87.5	90.9	93.1	94.5
		MCWB	76.6	78.0	75.4	71.0	67.3	63.0	62.4	63.1	65.0	68.0	72.1	74.2
	2%	DB	88.4	87.1	83.6	79.9	75.4	70.9	72.2	76.4	80.9	84.6	86.8	87.7
		MCWB	74.9	75.1	73.8	69.3	65.3	60.6	60.1	61.1	64.9	67.6	71.4	73.0
	5%	DB	84.7	83.5	80.8	77.0	72.2	68.3	68.7	72.2	76.9	79.9	82.0	83.6
		MCWB	74.1	73.6	72.2	68.2	63.5	60.4	58.6	59.5	63.9	66.4	70.4	71.2
	10%	DB	81.9	81.0	78.7	74.8	69.9	66.2	65.8	68.7	73.3	76.1	78.8	80.8
		MCWB	72.7	72.2	70.9	67.3	62.1	59.7	57.8	58.2	62.8	65.9	69.0	70.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	78.9	77.2	74.4	70.5	66.5	67.6	67.1	70.0	72.8	76.2	77.8
		MCDB	88.8	89.2	83.6	79.1	75.2	69.7	71.7	74.1	79.4	83.1	87.2	87.4
	2%	WB	77.0	76.9	75.3	71.6	67.4	64.3	63.9	64.1	67.7	70.2	73.7	75.4
		MCDB	83.5	83.7	80.9	76.8	72.7	67.2	67.5	71.9	76.0	77.9	81.1	83.3
	5%	WB	75.6	75.6	74.0	70.0	65.7	62.7	61.4	61.9	66.2	68.7	72.0	73.7
		MCDB	81.2	80.6	78.7	74.7	69.9	66.1	65.2	68.2	73.2	75.8	78.3	79.9
	10%	WB	74.4	74.1	72.7	68.6	64.0	61.2	59.5	60.3	64.7	67.4	70.6	72.4
		MCDB	79.4	78.7	76.9	73.3	67.7	64.5	63.8	66.0	70.9	73.8	76.2	77.8
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	12.5	12.1	12.5	13.7	13.2	15.4	16.9	17.1	16.1	15.4	14.5
		MCDBR	19.4	17.2	16.3	16.6	16.9	16.0	20.1	23.4	23.4	24.8	22.1	20.9
		MCWBR	8.1	7.1	7.6	8.0	9.3	9.4	11.4	11.9	11.4	11.2	9.2	8.8
	5% WB	MCDBR	15.9	15.5	14.5	14.6	14.3	12.5	15.6	18.8	19.5	19.9	18.3	17.0
		MCWBR	7.7	7.5	7.8	8.2	8.7	8.6	10.3	10.9	10.4	9.9	8.3	8.0
(40) Clear-Sky Solar Irradiance	taub		0.385	0.371	0.355	0.337	0.313	0.309	0.300	0.312	0.352	0.378	0.381	0.389
	taud		2.511	2.563	2.601	2.628	2.652	2.651	2.665	2.610	2.492	2.449	2.485	2.484
	Ebn at Noon		304	302	297	288	281	275	283	292	293	296	303	303
	Edh at Noon		36	33	30	27	23	23	23	27	33	37	37	37
(44) All-Sky Solar Radiation	RadAvg		2069	1886	1587	1340	1099	910	1054	1338	1673	1872	2025	2055
	RadStd		165	146	89	67	68	56	83	96	123	162	167	196

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-104	+319	+198

Nomenclature: See separate page