

EVANS HEAD, Australia

WMO: 945980

Lat: 29.183S

Lon: 153.396E

Elev: 63

StdP: 100.57

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	9.4	-1.9	3.2	14.0	0.1	3.8	13.7	11.5	16.4	10.1	16.8	4.0	340	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.5	32.5	23.0	30.5	22.6	28.8	22.2	25.1	29.2	24.3	27.8	23.7	26.7	5.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.1	26.0	23.4	18.3	25.6	22.8	17.7	25.1	76.9	29.3	73.9	28.0	71.3	26.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	10.7	9.2	5.8	37.4	0.8	2.3	5.2	39.1	4.7	40.4	4.3	41.7	3.7	43.4		
(5)			3.3	26.3	0.8	1.1	2.7	27.1	2.2	27.7	1.8	28.3	1.2	29.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	23.8	23.6	22.6	20.3	17.5	15.5	14.9	15.8	18.2	19.8	21.6	22.9	(6)	(7)
	DBStd	3.78	2.07	1.97	1.78	1.86	1.88	1.91	1.94	2.23	2.44	2.52	2.38	2.21	(7)	(8)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD18.3	368	0	0	0	4	38	87	109	84	31	12	2	1	(9)	(10)
	CDD10.0	3537	428	382	391	308	233	164	152	181	247	303	347	401	(10)	(11)
	CDD18.3	863	170	148	133	63	13	2	2	7	27	57	99	142	(11)	(12)
	CDH23.3	4345	1011	792	517	161	37	4	11	54	157	313	511	778	(12)	(13)
	CDH26.7	1052	269	177	88	21	3	0	0	9	36	93	146	209	(13)	(14)
(14) Wind	WSAvg	4.7	5.0	5.1	4.8	4.9	4.2	4.4	4.1	4.3	4.5	5.0	5.0	4.9	(14)	(15)
(15) Precipitation	PrecAvg	1383	162	179	172	130	111	141	68	82	49	73	100	116	(15)	(16)
	PrecMax	2158	407	341	476	333	483	433	216	307	142	366	218	277	(16)	(17)
	PrecMin	895	26	55	17	15	0	14	8	14	3	16	17	21	(17)	(18)
	PrecStd	308	102	87	108	84	100	97	50	78	34	69	55	64	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	33.8	32.0	29.1	26.7	23.5	24.9	27.5	30.9	32.7	34.0	34.7	(19)	(20)
		MCWB	24.8	25.5	24.1	21.7	19.6	17.2	16.9	17.3	18.3	20.0	22.3	23.5	(20)	(21)
	2%	DB	31.4	30.6	28.7	26.6	24.1	21.6	22.3	24.7	27.2	29.2	30.5	30.9	(21)	(22)
		MCWB	23.9	24.0	23.2	20.7	18.5	15.9	15.6	16.2	18.3	19.8	21.9	22.8	(22)	(23)
	5%	DB	29.3	28.6	27.1	25.0	22.3	20.2	20.4	22.3	24.9	26.6	27.8	28.7	(23)	(24)
		MCWB	23.4	23.1	22.3	20.1	17.5	15.8	14.8	15.3	17.7	19.1	21.3	21.8	(24)	(25)
	10%	DB	27.7	27.2	25.9	23.8	21.1	19.0	18.8	20.4	22.9	24.5	26.0	27.1	(25)	(26)
		MCWB	22.6	22.4	21.6	19.6	16.7	15.4	14.3	14.6	17.1	18.9	20.5	21.6	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.0	25.1	23.5	21.4	19.2	19.8	19.5	21.1	22.7	24.6	25.4	(27)	(28)
		MCDB	31.5	31.8	28.6	26.2	24.0	20.9	22.1	23.4	26.3	28.4	30.7	30.8	(28)	(29)
	2%	WB	25.0	25.0	24.1	22.0	19.7	17.9	17.7	17.8	19.8	21.2	23.2	24.1	(29)	(30)
		MCDB	28.6	28.7	27.2	24.9	22.6	19.5	19.7	22.2	24.4	25.5	27.3	28.5	(30)	(31)
	5%	WB	24.2	24.2	23.3	21.1	18.7	17.0	16.3	16.6	19.0	20.4	22.2	23.2	(31)	(32)
		MCDB	27.3	27.0	25.9	23.7	21.0	18.9	18.4	20.1	22.9	24.3	25.7	26.6	(32)	(33)
	10%	WB	23.5	23.4	22.6	20.3	17.8	16.2	15.3	15.7	18.2	19.6	21.4	22.5	(33)	(34)
		MCDB	26.3	25.9	24.9	22.9	19.8	18.1	17.7	18.9	21.6	23.2	24.6	25.4	(34)	(35)
(36) Mean Daily Temperature Range	5% DB	MDBR	7.5	6.9	6.7	7.0	7.6	7.3	8.6	9.4	9.5	8.9	8.6	8.1	(35)	(36)
		MCDBR	10.8	9.5	9.1	9.2	9.4	8.9	11.1	13.0	13.0	13.8	12.3	11.6	(36)	(37)
		MCWBR	4.5	3.9	4.2	4.5	5.2	5.2	6.4	6.6	6.4	6.2	5.1	4.9	(37)	(38)
	5% WB	MCDBR	8.8	8.6	8.1	8.1	7.9	7.0	8.7	10.5	10.8	11.1	10.2	9.5	(38)	(39)
		MCWBR	4.3	4.2	4.3	4.5	4.8	4.8	5.7	6.1	5.8	5.5	4.6	4.4	(39)	(40)
(42) Clear-Sky Solar Irradiance	taub		0.385	0.371	0.355	0.337	0.313	0.309	0.300	0.312	0.352	0.378	0.381	0.389	(40)	(41)
	taud		2.511	2.563	2.601	2.628	2.652	2.651	2.665	2.610	2.492	2.449	2.485	2.484	(41)	(42)
	Ebn at Noon		957	953	937	907	885	866	892	919	924	934	954	955	(42)	(43)
	Edh at Noon		114	105	96	84	74	71	72	84	105	116	116	117	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		6.52	5.95	5.00	4.22	3.46	2.87	3.32	4.22	5.27	5.90	6.38	6.48	(44)	(45)
	RadStd		0.52	0.46	0.28	0.21	0.21	0.18	0.26	0.30	0.39	0.51	0.53	0.62	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-58	+177	+110

Nomenclature: See separate page