

CAPE NATURALISTE, Australia

WMO: 946000

Lat: 33.5372S

Lon: 115.0189E

Elev: 359

StdP: 14.51

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	45.5	47.1	36.5	32.0	51.7	38.0	34.1	52.5	40.6	54.9	36.9	56.1	13.1	130	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.0	87.5	66.5	84.0	65.8	81.0	65.2	69.6	80.5	68.2	79.0	67.1	77.3	12.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	98.2	73.2	64.6	92.5	72.3	63.3	88.1	71.7	33.9	80.5	32.7	79.4	31.8	77.3	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 34.5	30.9	27.8	DB	42.5	95.4	1.6	2.4	41.4	97.1	40.5	98.6	39.6	99.9	38.5	101.7	(4)
(5)			WB	39.5	72.2	1.5	1.8	38.4	73.4	37.5	74.5	36.7	75.5	35.6	76.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.5	69.0	69.7	67.9	64.7	61.4	58.5	56.5	56.4	57.2	59.5	63.5	66.2	(6)
(7)		DBStd	6.24	4.81	4.74	4.71	3.80	3.53	3.43	3.32	3.22	3.38	3.51	4.35	5.14	(7)
(8)		HDD50	3	0	0	0	0	0	0	1	1	1	0	0	0	(8)
(9)		HDD65	1464	10	7	19	51	121	195	265	267	236	174	78	41	(9)
(10)		CDD50	4564	590	553	555	440	353	256	201	199	215	295	406	501	(10)
(11)		CDD65	554	135	140	110	42	9	1	0	0	0	5	35	77	(11)
(12)		CDH74	3352	938	912	610	88	4	0	0	0	0	22	214	564	(12)
(13)		CDH80	869	253	239	151	5	0	0	0	0	0	1	43	177	(13)
(14)	Wind	WSAvg	15.9	16.7	16.3	15.5	14.1	14.8	16.8	17.2	16.0	16.4	15.5	15.9	16.3	(14)
(15)	Precipitation	PrecAvg	32.8	0.5	0.4	1.0	1.8	4.6	6.7	6.8	4.5	3.1	2.0	1.1	0.5	(15)
(16)		PrecMax	43.7	2.3	2.3	6.1	7.4	9.4	12.2	13.3	8.3	6.7	5.6	3.9	2.2	(16)
(17)		PrecMin	23.0	0.0	0.0	0.0	0.0	1.8	2.7	3.9	2.0	1.1	0.2	0.0	0.0	(17)
(18)		PrecStd	5.6	0.7	0.6	1.3	1.3	1.9	2.3	2.1	1.7	1.2	1.1	0.9	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.0	90.2	90.3	80.0	73.8	69.2	68.1	68.0	70.2	77.4	84.8	91.0	(19)
(20)			MCWB	67.7	68.0	66.7	64.1	63.6	60.7	61.2	59.9	60.2	61.2	63.1	65.2	(20)
(21)		2%	DB	86.0	86.3	84.0	76.4	71.3	67.2	65.1	65.5	67.2	72.2	79.7	85.3	(21)
(22)			MCWB	66.7	66.7	65.4	64.0	62.2	59.7	58.4	58.3	58.9	60.9	63.1	65.9	(22)
(23)		5%	DB	82.1	82.6	80.0	73.9	69.4	65.7	63.5	63.7	65.1	69.1	75.5	80.2	(23)
(24)			MCWB	65.8	66.2	64.6	62.8	61.1	58.8	57.2	57.0	57.6	59.5	61.9	64.5	(24)
(25)		10%	DB	79.1	79.5	76.9	71.8	67.7	64.3	62.0	62.0	63.2	66.8	72.2	75.9	(25)
(26)			MCWB	65.2	65.6	64.3	62.0	60.4	57.9	56.1	55.8	56.4	58.2	61.3	63.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	72.2	70.2	68.2	66.2	63.9	62.7	61.8	62.5	64.4	67.0	69.8	(27)
(28)			MCD B	82.8	82.9	79.6	73.9	71.1	66.8	65.7	65.5	67.6	71.6	76.1	81.6	(28)
(29)		2%	WB	69.0	69.7	68.3	66.4	64.3	61.6	60.0	59.8	60.3	62.2	65.0	67.6	(29)
(30)			MCD B	81.1	80.6	77.9	72.8	68.9	65.5	63.9	63.9	65.2	69.4	74.7	80.3	(30)
(31)		5%	WB	67.5	68.1	67.0	64.9	62.7	60.0	58.2	58.3	58.7	60.6	63.6	65.8	(31)
(32)			MCD B	79.3	79.2	76.1	71.1	67.8	64.4	62.4	62.5	63.8	67.6	72.8	77.1	(32)
(33)		10%	WB	66.1	66.7	65.6	63.4	61.1	58.5	56.8	56.7	57.2	59.1	62.2	64.1	(33)
(34)			MCD B	76.9	77.2	74.5	70.1	66.7	63.3	61.2	61.2	62.2	65.9	70.6	74.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.1	18.0	16.8	13.8	11.6	9.6	9.7	10.5	11.5	14.0	16.1	17.3	(35)
(36)			MCD BR	23.1	22.3	21.3	16.2	12.9	10.4	10.7	11.8	13.6	17.5	21.5	23.5	(36)
(37)			MCWBR	10.5	9.3	9.2	8.8	8.1	7.0	7.6	7.7	8.8	10.3	10.6	10.5	(37)
(38)		5% WB	MCD BR	19.4	18.3	16.8	13.5	11.3	9.5	9.9	10.6	12.2	15.5	18.0	20.2	(38)
(39)			MCWBR	10.1	9.2	9.0	8.8	8.6	7.5	8.3	8.2	9.0	10.0	10.2	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.330	0.320	0.315	0.310	0.305	0.303	0.312	0.324	0.323	0.326	0.323	(40)	
(41)		taud	2.622	2.635	2.661	2.669	2.646	2.643	2.647	2.611	2.559	2.579	2.593	2.625	(41)	
(42)		Ebn at Noon	320	313	305	290	275	268	275	287	299	312	319	323	(42)	
(43)		Edh at Noon	32	30	28	25	22	21	22	26	30	32	33	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2500	2229	1783	1273	922	738	790	1062	1430	1896	2283	2504	(44)	
(45)		RadStd	126	94	93	76	61	47	38	62	76	95	127	114	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	DBAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	DBAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page