

BADGINGARRA, AustraliaWMO: **946030**Lat: **30.338S**Lon: **115.539E**Elev: **902**StdP: **14.22**Time Zone: **8.00 (E08)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.9	42.5	25.1	19.8	71.9	28.5	23.2	70.4	26.4	59.6	24.4	57.4	7.7	150	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.5	100.8	66.8	97.5	66.3	94.4	65.7	72.0	87.6	70.2	86.7	68.8	85.6	12.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	106.2	75.3	65.9	98.6	73.7	64.1	92.7	72.0	36.3	87.4	34.7	86.6	33.4	85.5	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	24.1	22.3	DB	37.9	107.0	1.5	2.9	36.8	109.1	35.9	110.8	35.0	112.5	33.9	114.6
			WB	35.7	74.0	1.3	2.4	34.8	75.8	34.0	77.2	33.2	78.6	32.3	80.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	77.4	77.9	74.7	68.4	61.9	56.7	54.0	54.6	56.2	62.2	68.6	73.5	(6)
(7)		DBStd	10.32	6.34	6.27	6.68	5.97	4.88	3.72	3.48	3.84	4.82	6.12	6.76	7.13	(7)
(8)		HDD50	16	0	0	0	0	0	1	7	5	3	0	0	0	(8)
(9)		HDD65	1517	1	1	5	31	121	250	342	322	267	131	37	9	(9)
(10)		CDD50	5651	849	780	765	551	370	202	130	148	190	378	558	730	(10)
(11)		CDD65	1676	385	362	305	131	26	0	0	0	4	44	145	274	(11)
(12)		CDH74	17887	4319	4035	2994	1004	165	3	0	5	71	519	1631	3141	(12)
(13)		CDH80	8945	2381	2186	1443	349	27	0	0	1	9	168	741	1640	(13)
(14)	Wind	WSAvg	12.2	15.4	14.8	14.2	11.7	10.5	10.1	9.5	9.7	10.3	11.7	13.6	15.1	(14)
(15)	Precipitation	PrecAvg	19.6	0.6	0.5	0.9	1.0	2.4	3.3	3.9	3.1	2.1	0.9	0.6	0.4	(15)
(16)		PrecMax	29.4	3.1	3.2	5.3	2.8	6.4	7.0	7.2	5.8	3.5	2.2	3.0	1.7	(16)
(17)		PrecMin	13.5	0.0	0.0	0.0	0.1	0.7	0.9	1.7	0.4	0.4	0.0	0.0	0.0	(17)
(18)		PrecStd	4.1	0.9	0.8	1.1	0.7	1.4	1.5	1.5	1.1	0.8	0.6	0.7	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.9	103.9	100.8	92.9	83.4	73.9	70.1	73.5	81.0	90.6	98.0	104.1	(19)
(20)		MCWB	67.1	67.8	66.0	62.6	59.2	55.3	54.2	57.0	59.0	62.2	64.0	65.9	(20)	
(21)		2%	DB	100.4	99.5	96.4	88.1	78.6	70.3	66.1	69.1	75.2	84.6	93.1	99.0	(21)
(22)		MCWB	67.3	67.9	65.9	61.8	58.3	54.7	54.7	56.4	58.4	60.8	62.6	65.7	(22)	
(23)		5%	DB	96.5	96.0	92.2	84.0	74.6	67.1	63.4	65.5	70.1	79.8	88.6	94.5	(23)
(24)		MCWB	66.6	66.9	65.3	61.4	57.5	55.1	54.8	56.1	57.3	59.9	61.8	64.7	(24)	
(25)		10%	DB	92.6	92.5	88.4	79.9	71.0	64.1	61.2	62.7	66.0	75.1	84.1	89.8	(25)
(26)		MCWB	65.8	66.6	64.5	61.0	57.3	54.8	54.4	55.6	56.5	59.1	61.1	63.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	74.5	72.5	68.6	65.7	62.6	60.9	62.1	62.8	65.3	68.1	70.2	(27)
(28)		MADB	90.0	87.9	86.0	80.4	70.2	65.6	63.5	67.3	72.6	80.4	87.6	91.6	(28)	
(29)		2%	WB	72.2	72.0	70.0	66.5	63.6	60.3	58.6	59.9	60.5	63.5	66.1	68.3	(29)
(30)		MADB	87.4	88.6	83.6	76.9	68.9	64.3	61.5	64.3	68.4	77.6	83.6	88.8	(30)	
(31)		5%	WB	70.2	70.2	68.5	65.0	62.0	58.5	57.0	58.0	59.0	62.0	64.4	66.9	(31)
(32)		MADB	86.3	88.0	83.0	74.9	68.1	62.4	60.3	62.7	66.6	74.7	80.6	86.9	(32)	
(33)		10%	WB	68.4	68.6	67.0	63.5	60.4	56.8	55.5	56.4	57.4	60.5	62.9	65.4	(33)
(34)		MADB	84.7	86.8	81.5	73.4	66.8	61.2	59.4	61.1	64.2	71.6	78.0	84.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	27.3	26.5	23.6	21.3	17.6	15.8	15.4	17.0	20.1	24.3	26.0	26.8	(35)	
(36)		5% DB	MADB	32.5	29.9	27.5	25.5	22.1	19.3	18.1	20.7	25.7	30.2	32.2	32.6	(36)
(37)		MCWBR	10.0	9.4	8.6	9.2	9.1	9.9	10.8	11.9	12.9	12.0	10.4	10.1	(37)	
(38)		5% WB	MADB	26.3	26.5	23.7	20.7	15.9	14.9	14.6	16.8	21.7	26.0	27.9	28.7	(38)
(39)		MCWBR	9.7	9.3	8.6	8.8	9.4	10.3	10.9	11.6	12.8	12.0	10.1	9.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.338	0.320	0.308	0.294	0.286	0.287	0.293	0.311	0.315	0.317	0.324	(40)	
(41)		taud	2.544	2.551	2.582	2.604	2.616	2.628	2.609	2.585	2.516	2.528	2.547	2.543	(41)	
(42)		Ebn at Noon	319	312	308	296	285	281	285	297	306	316	323	323	(42)	
(43)		Edh at Noon	35	34	30	27	24	22	23	27	32	34	35	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2619	2383	1991	1505	1154	961	1010	1290	1689	2151	2503	2695	(44)	
(45)		RadStd	143	90	104	79	74	62	57	49	84	98	84	119	(45)	