

MANDURAH, Australia

WMO: 946050

Lat: 32.5219S

Lon: 115.7119E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 6.8	(c) 8.0	(d) 1.6	(e) 4.2	(f) 19.0	(g) 2.8	(h) 4.6	(i) 16.1	(j) 14.4	(k) 16.5	(l) 13.0	(m) 16.4	(n) 2.0	(o) 110	(p) 0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 9.9	(c) 34.7	(d) 19.7	(e) 32.7	(f) 19.6	(g) 31.0	(h) 19.2	(i) 22.5	(j) 28.3	(k) 21.7	(l) 27.7	(m) 21.0	(n) 26.9	(o) 4.3	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.0	15.7	24.1	20.1	14.8	23.6	19.2	13.9	23.3	66.3	27.9	63.2	27.9	60.9	26.7	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.4	(b) 9.9	(c) 8.6	(e) 5.3	(f) 38.5	(g) 1.5	(h) 1.6	(i) 4.2	(j) 39.6	(k) 3.3	(l) 40.5	(m) 2.5	(n) 41.4	(o) 1.4	(p) 42.5		
(4) 11.4	(5) 9.9	(6) 8.6	(7) 5.3	(8) 38.5	(9) 1.5	(10) 1.6	(11) 4.2	(12) 39.6	(13) 3.3	(14) 40.5	(15) 2.5	(16) 41.4	(17) 1.4	(18) 42.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	23.6	23.8	22.5	19.7	16.9	14.8	13.9	14.2	15.0	17.1	19.8	21.9		
	DBStd	4.42	3.05	3.17	3.01	2.55	2.14	1.92	1.94	1.83	2.05	2.45	2.86	3.38		
	HDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0		
	HDD18.3	618	1	1	3	13	53	107	139	127	101	55	14	4		
	CDD10.0	3132	421	387	387	292	215	144	120	132	151	219	296	370		
	CDD18.3	706	163	154	131	55	10	0	0	0	2	16	59	116		
	CDH23.3	5492	1441	1369	984	242	18	0	0	1	8	93	394	943		
	CDH26.7	2023	574	549	335	47	1	0	0	0	0	19	122	376		
(14) Wind	WSAvg	4.3	4.8	4.6	4.2	3.6	3.7	4.0	4.3	4.2	4.4	4.3	4.8	4.8		
(15) Precipitation	PrecAvg	842	10	14	20	44	117	176	174	117	81	44	27	11		
	PrecMax	1075	78	108	103	110	259	341	315	191	154	125	127	54		
	PrecMin	526	0	0	0	0	34	65	86	36	22	1	4	0		
	PrecStd	126	17	22	26	32	51	66	51	36	35	26	22	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	36.5	35.1	30.6	25.2	21.7	20.0	21.4	24.3	29.2	33.2	36.6		
		MCWB	20.2	20.7	20.2	17.7	16.3	14.8	14.8	14.8	15.5	17.2	18.3	20.0		
	2%	DB	34.1	34.1	32.2	27.9	23.3	20.1	18.7	19.5	21.5	26.0	30.1	33.5		
		MCWB	19.6	19.9	19.5	17.9	16.5	14.9	14.8	15.2	15.2	16.4	17.7	19.3		
	5%	DB	31.8	32.1	30.1	26.0	22.1	19.2	18.0	18.6	19.9	23.5	27.5	30.8		
		MCWB	19.8	19.9	18.9	17.8	16.2	14.9	14.4	14.7	15.2	16.0	17.3	18.8		
	10%	DB	29.9	30.2	28.3	24.3	20.9	18.4	17.3	17.8	18.7	21.6	25.4	28.4		
		MCWB	19.4	19.6	18.5	17.4	16.3	14.6	13.9	14.2	14.7	15.7	17.1	18.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	24.1	22.7	21.6	20.1	18.1	17.3	18.2	18.2	19.1	20.7	22.2		
		MCDB	28.1	29.8	26.9	23.4	21.3	19.2	18.3	19.1	20.2	23.0	25.1	29.6		
	2%	WB	22.4	22.5	21.7	20.6	19.0	17.0	16.2	16.7	17.2	18.3	19.7	21.2		
		MCDB	28.6	28.8	26.6	23.3	20.9	18.6	17.6	18.0	19.2	22.2	24.8	28.5		
	5%	WB	21.4	21.6	21.0	19.6	18.0	16.1	15.3	15.7	16.2	17.5	19.0	20.3		
		MCDB	28.0	28.3	26.0	23.4	20.5	18.0	17.1	17.6	18.8	21.2	24.3	27.4		
	10%	WB	20.6	20.8	20.2	18.7	17.0	15.3	14.6	14.9	15.3	16.7	18.2	19.5		
		MCDB	27.2	27.5	25.8	22.8	20.0	17.5	16.6	17.1	18.2	20.5	23.7	26.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	9.9	9.5	8.3	7.6	6.8	6.3	6.6	7.0	8.1	8.6	9.2		
		MCDBR	13.8	13.2	12.4	10.8	9.2	7.7	6.6	7.8	9.3	11.8	12.7	13.6		
		MCWBR	5.6	5.4	5.1	5.2	5.4	5.0	4.6	5.1	5.5	5.9	5.9	5.6		
		MCDBR	9.7	9.6	8.1	7.1	6.4	5.9	5.3	5.8	7.0	8.2	8.8	10.6		
	5% WB	MCWBR	5.1	4.9	4.5	4.8	5.3	5.0	4.8	5.0	5.4	5.2	5.0	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.337	0.336	0.324	0.316	0.310	0.305	0.303	0.311	0.331	0.327	0.329	0.328		
	taud		2.599	2.614	2.646	2.656	2.641	2.634	2.639	2.609	2.526	2.556	2.575	2.599		
	Ebn at Noon		1002	983	962	917	871	850	871	909	938	981	1003	1014		
	Edh at Noon		104	99	89	79	72	68	71	82	99	103	105	104		
(44) All-Sky Solar Radiation	RadAvg		8.13	7.31	6.00	4.30	3.17	2.55	2.71	3.58	4.82	6.35	7.62	8.32		
	RadStd		0.38	0.28	0.29	0.26	0.20	0.17	0.18	0.20	0.29	0.26	0.36	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page