

PERTH JANDAKOT, Australia

WMO: 946090

Lat: 32.1011S

Lon: 115.8794E

Elev: 31

StdP: 100.96

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 2.0	(c) 3.4	(d) -1.3	(e) 3.4	(f) 19.6	(g) 0.2	(h) 3.8	(i) 14.9	(j) 12.2	(k) 15.9	(l) 11.1	(m) 16.1	(n) 1.0	(o) 110	(p) 0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 13.4	(c) 36.5	(d) 19.8	(e) 34.7	(f) 19.6	(g) 32.8	(h) 19.2	(i) 22.9	(j) 30.0	(k) 21.7	(l) 29.3	(m) 20.9	(n) 28.5	(o) 5.6	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	25.2	19.6	14.4	24.0	18.6	13.5	23.4	68.1	29.9	63.5	29.6	60.4	28.6	36.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.3	9.3	8.4	-0.5	40.6	1.2	1.3	-1.4	41.5	-2.1	42.3	-2.8	43.0	-3.7	43.9		
			-0.4	27.0	1.0	3.8	-1.2	29.7	-1.8	32.0	-2.3	34.1	-3.1	36.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	23.9	24.1	22.3	18.8	15.4	13.1	12.3	12.6	13.8	16.1	19.4	21.8
	DBStd	5.26	3.50	3.50	3.65	3.20	2.69	2.34	2.47	2.31	2.45	3.12	3.45	3.81
	HDD10.0	16	0	0	0	0	1	3	8	4	1	0	0	0
	HDD18.3	916	2	2	7	33	96	156	187	177	139	84	26	9
	CDD10.0	2852	430	394	381	263	169	97	79	86	114	190	282	366
	CDD18.3	708	173	162	130	45	6	0	0	0	2	15	58	116
	CDH23.3	7314	1843	1722	1271	372	59	1	0	3	28	170	617	1227
CDH26.7	3214	883	821	543	104	7	0	0	0	4	47	243	561	
Wind	WSAvg	4.3	5.2	5.0	4.6	3.7	3.4	3.5	3.7	3.8	4.2	4.4	4.9	5.1
Precipitation	PrecAvg	760	12	12	24	38	96	146	150	127	79	38	27	10
	PrecMax	971	102	129	67	99	180	252	227	189	162	104	68	55
	PrecMin	507	0	0	0	6	31	51	49	32	25	5	1	0
	PrecStd	117	22	25	21	28	35	57	44	32	31	22	20	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	38.4	37.4	32.4	27.4	22.9	21.5	23.3	26.5	31.2	35.6	38.0
		MCWB	21.3	20.6	19.5	17.5	15.6	13.3	13.5	13.8	15.0	16.8	17.7	19.4
	2%	DB	35.9	35.9	34.2	29.5	24.9	21.0	19.8	20.9	23.1	27.6	32.2	35.2
		MCWB	19.8	20.4	19.3	17.4	15.4	13.9	13.4	14.2	14.8	16.5	17.4	19.2
	5%	DB	33.8	33.8	31.8	27.3	23.0	19.6	18.5	19.2	21.0	24.9	29.3	32.5
		MCWB	19.9	20.2	18.8	17.2	15.2	13.6	13.3	13.7	14.6	15.9	17.0	18.7
	10%	DB	31.5	31.7	29.6	25.2	21.4	18.4	17.2	18.0	19.2	22.7	26.8	29.7
		MCWB	19.4	19.7	18.5	17.1	15.0	13.3	12.9	13.4	13.9	15.4	16.7	18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	26.4	23.2	20.9	19.3	17.3	16.7	17.2	18.3	20.1	20.8	23.0
		MCDB	32.1	30.2	28.2	24.9	21.8	19.4	18.4	19.3	21.2	23.4	28.2	31.0
	2%	WB	22.6	23.0	21.7	19.9	18.1	16.2	15.5	15.9	16.6	18.1	19.4	20.9
		MCDB	30.5	30.2	28.1	24.1	20.9	18.4	17.4	18.3	20.1	23.9	26.8	29.7
	5%	WB	21.4	21.7	20.7	19.1	17.1	15.3	14.5	15.0	15.6	17.1	18.5	20.0
		MCDB	29.6	29.9	26.9	23.7	20.7	17.6	16.7	17.7	19.2	22.6	25.8	28.9
	10%	WB	20.5	20.7	19.8	18.1	16.1	14.4	13.7	14.1	14.6	16.2	17.6	19.1
		MCDB	28.6	28.9	26.8	23.1	19.6	16.9	16.2	16.9	18.3	21.0	24.5	27.1
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.4	13.0	12.4	12.1	10.9	10.4	10.9	11.1	12.2	12.5	12.7
		MCDBR	16.3	15.8	15.7	14.7	14.6	12.7	11.7	13.2	14.5	15.3	16.5	16.6
		MCWBR	6.1	5.9	5.7	6.2	7.3	7.2	7.0	7.7	7.9	7.0	6.4	6.2
	5% WB	MCDBR	13.2	13.4	12.1	11.3	10.4	9.5	8.6	9.7	11.4	12.4	13.5	14.0
		MCWBR	6.0	6.2	5.9	6.1	6.6	6.7	6.3	6.6	7.3	6.9	6.3	6.2
Clear-Sky Solar Irradiance	taub	0.339	0.339	0.324	0.317	0.308	0.302	0.302	0.308	0.327	0.327	0.328	0.328	
	taud	2.582	2.599	2.634	2.640	2.638	2.632	2.628	2.606	2.529	2.548	2.568	2.591	
	Ebn at Noon	1000	981	962	917	876	856	874	913	943	982	1004	1014	
	Edh at Noon	105	100	91	81	72	68	72	82	99	104	106	105	
All-Sky Solar Radiation	RadAvg	8.18	7.36	6.07	4.41	3.28	2.67	2.83	3.69	4.93	6.45	7.71	8.37	
	RadStd	0.38	0.26	0.30	0.26	0.21	0.18	0.18	0.19	0.29	0.28	0.34	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.31	N/A	N/A	+0.66	N/A	+0.47	N/A	N/A	N/A	+64
Regional (20 neighbors)	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page