

PERTH GOOSEBERY HILL, Australia

WMO: 946150

Lat: 31.941S

Lon: 116.051E

Elev: 722

StdP: 14.32

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	44.1	45.7	26.1	20.6	71.5	30.2	24.9	69.3	29.7	53.7	27.1	53.6	12.3	100	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.4	98.4	67.5	94.8	67.0	91.6	66.3	73.0	87.5	71.1	85.5	69.4	83.8	10.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.8	108.9	78.3	66.8	101.3	75.8	65.1	95.2	74.3	37.1	87.4	35.3	85.3	33.9	84.2	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.5	26.0	23.4	DB	41.0	105.5	1.1	2.9	40.3	107.6	39.6	109.3	39.0	110.9	38.2	113.0	(4)
(5)			WB	38.6	76.4	1.5	2.1	37.5	77.9	36.7	79.1	35.8	80.3	34.7	81.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	75.7	76.3	72.8	68.0	61.5	57.0	54.8	55.8	57.8	62.4	67.6	72.2	(6)	
	DBStd	9.26	6.25	6.12	6.10	5.46	4.49	3.76	3.35	3.82	4.60	5.34	6.31	6.65	(7)	
	HDD50	7	0	0	0	0	0	1	3	2	1	0	0	0	(8)	
	HDD65	1395	2	1	5	27	128	241	315	285	222	118	41	10	(9)	
	CDD50	5518	798	737	707	541	356	210	153	183	235	384	527	687	(10)	
	CDD65	1432	335	319	247	118	19	0	0	1	6	37	118	232	(11)	
	CDH74	13979	3667	3377	2208	707	75	0	0	4	39	317	1139	2446	(12)	
	CDH80	6277	1840	1664	925	192	8	0	0	0	5	81	438	1124	(13)	
(14) Wind	WSAvg	12.1	13.8	13.6	13.0	11.7	11.2	11.2	11.1	11.1	11.2	11.8	12.5	12.7	(14)	
(15) Precipitation	PrecAvg	30.1	0.6	0.4	0.9	1.4	3.7	5.5	5.9	5.4	3.4	1.5	0.9	0.4	(15)	
	PrecMax	39.9	4.2	3.2	3.5	4.3	6.9	10.8	9.8	8.5	7.4	3.5	3.1	1.7	(16)	
	PrecMin	17.2	0.0	0.0	0.0	0.2	1.4	1.1	1.4	1.0	0.8	0.0	0.0	0.0	(17)	
	PrecStd	5.1	1.0	0.7	0.9	1.1	1.4	2.6	2.1	1.6	1.4	0.9	0.9	0.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.1	102.6	98.7	90.3	80.4	71.1	68.1	72.3	78.6	87.8	95.7	101.2	(19)	
		MCWB	67.4	68.0	66.2	63.8	59.3	55.7	55.6	57.0	58.3	62.3	63.8	66.8	(20)	
	2%	DB	97.7	97.4	93.7	85.3	75.6	68.0	65.1	68.1	73.1	81.6	89.5	95.9	(21)	
		MCWB	68.3	68.2	66.3	63.1	58.9	56.5	54.9	56.7	58.3	61.7	63.6	66.2	(22)	
	5%	DB	93.8	93.7	88.9	81.2	72.1	65.4	62.7	64.8	69.2	77.2	84.8	90.8	(23)	
		MCWB	67.6	67.5	65.2	62.6	57.5	55.5	54.4	55.4	57.1	60.3	63.0	65.4	(24)	
	10%	DB	90.0	89.9	85.0	77.8	68.9	63.1	60.6	62.4	65.8	73.1	80.7	86.1	(25)	
		MCWB	66.9	67.0	64.8	61.6	57.3	55.2	54.1	54.8	56.1	59.1	61.8	64.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.9	76.6	73.1	69.7	65.5	61.9	61.2	61.8	63.0	66.5	69.9	71.9	(27)	
		MCDB	90.8	88.7	86.3	78.3	70.9	65.3	63.0	65.2	70.5	77.5	83.8	87.2	(28)	
	2%	WB	72.9	73.3	70.7	67.6	63.5	60.2	58.6	59.8	61.1	64.4	67.3	69.7	(29)	
		MCDB	87.4	88.5	83.8	76.2	68.0	63.3	60.8	63.2	67.7	76.2	81.7	86.7	(30)	
	5%	WB	71.1	70.8	68.9	66.0	61.7	58.6	57.1	58.1	59.6	62.6	65.4	68.0	(31)	
		MCDB	85.6	85.7	80.7	75.0	66.7	61.7	59.8	61.8	65.8	72.3	78.7	85.0	(32)	
	10%	WB	69.1	68.9	67.2	64.2	60.1	57.2	55.6	56.6	58.1	60.8	63.6	66.2	(33)	
		MCDB	83.8	84.2	78.9	72.8	65.6	60.5	58.5	60.3	63.6	69.9	76.0	81.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.8	24.4	21.6	17.4	13.9	11.2	11.0	12.6	14.8	18.6	21.2	23.7	(35)	
		MCDBR	30.5	28.9	26.6	22.2	18.2	13.7	13.5	16.1	19.8	25.3	28.5	30.2	(36)	
	5% WB	MCWBR	10.6	9.9	9.5	9.0	8.8	7.8	8.1	9.1	10.1	11.7	11.5	10.7	(37)	
		MCWBR	24.8	23.9	21.5	17.5	12.9	10.3	9.9	12.4	16.3	20.7	23.5	25.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.331	0.317	0.309	0.300	0.292	0.292	0.298	0.318	0.319	0.320	0.320	(40)	
		taud	2.584	2.599	2.633	2.641	2.637	2.641	2.639	2.614	2.531	2.551	2.571	2.593	(41)	
	Ebn at Noon		320	314	308	294	281	276	281	293	302	314	321	325	(42)	
		Edh at Noon	33	32	29	26	23	22	23	26	31	33	34	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2596	2339	1932	1410	1054	862	913	1183	1577	2054	2449	2658	(44)	
	RadStd		124	83	96	83	70	59	56	58	90	94	108	115	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-0.95	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page