

NEWDEGATE, Australia

WMO: 946280

Lat: 33.1131S

Lon: 118.8400E

Elev: 1053

StdP: 14.15

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.7	34.9	24.7	19.5	63.4	28.0	22.8	58.8	28.8	58.6	26.4	57.1	1.5	130	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.8	98.6	64.4	94.6	63.9	90.9	63.0	68.9	84.6	67.0	84.4	65.5	83.3	12.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	95.1	72.4	62.4	87.5	70.2	60.5	81.9	68.8	33.7	84.0	32.1	84.5	30.9	82.9	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.9	22.3	20.1	DB	28.4	106.7	1.6	3.2	27.2	109.0	26.3	110.9	25.4	112.7	24.2	115.1	(4)
(5)			WB	27.5	72.9	1.7	3.7	26.3	75.5	25.3	77.6	24.4	79.7	23.2	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	71.8	71.4	67.9	62.3	55.7	51.2	49.3	50.2	52.6	59.0	65.1	68.5	(6)	
	DBStd	9.78	6.19	6.02	6.34	5.76	4.61	3.83	3.66	3.83	4.96	5.91	6.54	6.43	(7)	
	HDD50	167	0	0	0	0	5	30	59	45	26	2	0	0	(8)	
	HDD65	2525	10	12	42	118	291	414	486	460	372	205	81	34	(9)	
	CDD50	3946	676	598	555	371	182	66	37	50	105	280	452	574	(10)	
	CDD65	831	222	190	132	38	3	0	0	0	1	18	83	144	(11)	
	CDH74	10901	2758	2208	1481	435	33	1	0	3	58	464	1311	2149	(12)	
	CDH80	5139	1443	1083	642	120	4	0	0	0	9	164	577	1097	(13)	
(14) Wind	WSAvg	9.8	12.3	11.9	10.7	8.8	7.6	8.4	8.8	8.7	9.3	9.8	10.8	11.1	(14)	
(15) Precipitation	PrecAvg	14.2	0.8	0.5	1.1	0.9	1.5	1.5	1.9	1.7	1.2	0.9	0.9	0.7	(15)	
	PrecMax	21.6	6.4	1.6	3.5	4.2	3.2	3.6	3.2	4.6	2.4	2.6	2.6	4.5	(16)	
	PrecMin	7.9	0.0	0.0	0.0	0.0	0.2	0.3	0.6	0.5	0.1	0.0	0.0	0.0	(17)	
	PrecStd	3.2	1.6	0.5	1.1	0.9	0.9	0.7	0.7	0.9	0.6	0.7	0.6	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.1	101.4	97.3	89.5	77.7	70.5	66.1	71.3	80.4	90.9	97.4	103.6	(19)	
		MCWB	67.0	67.3	64.0	61.1	57.6	54.1	52.5	55.6	57.2	59.9	62.8	64.3	(20)	
	2%	DB	98.2	95.9	92.6	83.3	73.2	66.5	62.7	66.2	73.8	84.8	92.2	97.0	(21)	
		MCWB	64.8	65.3	63.2	60.4	56.3	53.0	52.1	54.2	55.9	59.1	61.0	63.9	(22)	
	5%	DB	93.2	91.7	87.3	78.9	69.4	63.2	59.9	62.6	68.8	78.9	87.1	91.2	(23)	
		MCWB	63.7	64.5	62.8	59.4	55.4	52.3	52.0	53.5	54.7	57.7	60.0	61.8	(24)	
	10%	DB	88.4	86.7	82.2	74.8	66.2	60.2	57.6	59.6	64.8	73.9	82.0	85.8	(25)	
		MCWB	63.7	63.5	61.7	58.8	55.1	51.9	51.2	52.3	53.5	56.2	58.9	60.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	74.3	68.3	66.0	62.3	58.7	57.0	58.4	60.3	63.4	65.6	67.9	(27)	
		MCDB	88.3	85.4	80.3	75.3	67.8	63.8	61.3	65.3	74.0	80.0	85.4	87.1	(28)	
	2%	WB	69.1	69.2	66.6	63.9	60.1	56.4	54.8	56.4	57.6	60.9	63.5	65.3	(29)	
		MCDB	86.6	83.8	81.4	74.7	66.8	62.1	59.2	62.9	69.6	78.1	83.9	88.9	(30)	
	5%	WB	66.9	67.1	65.1	62.2	58.3	54.6	53.2	54.6	55.9	59.1	61.8	63.7	(31)	
		MCDB	86.8	83.6	80.0	73.1	65.1	60.0	57.7	60.7	65.7	75.2	80.6	86.3	(32)	
	10%	WB	65.0	65.3	63.6	60.5	56.4	53.0	51.7	52.8	54.3	57.4	60.3	62.1	(33)	
		MCDB	83.5	82.3	77.6	70.8	63.5	58.4	56.6	58.3	63.1	71.5	77.7	81.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	28.8	27.1	25.2	23.2	21.2	19.2	17.2	19.5	23.7	27.2	28.4	29.7	(35)	
		MCDBR	37.8	35.8	33.0	29.5	26.7	24.9	20.9	25.7	32.2	36.8	37.8	39.7	(36)	
	5% WB	MCWBR	10.7	10.2	10.5	11.6	13.6	14.3	13.1	15.7	16.6	14.6	11.8	11.5	(37)	
		MCWBR	31.3	29.2	25.6	22.0	18.7	18.5	16.9	20.9	26.4	30.7	31.8	34.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.335	0.328	0.315	0.303	0.290	0.283	0.285	0.289	0.308	0.317	0.321	0.325	(40)	
		taud	2.514	2.551	2.575	2.599	2.606	2.602	2.591	2.582	2.502	2.501	2.512	2.521	(41)	
	Ebn at Noon	Ebn at Noon	318	314	307	294	282	276	281	295	305	314	320	323	(42)	
		Edh at Noon	36	33	30	26	23	22	23	26	32	35	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2495	2212	1815	1338	999	836	890	1150	1546	1995	2325	2557	(44)	
	RadStd	RadStd	156	125	100	85	66	38	48	50	67	115	141	143	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page