

ROCKY GULLY, Australia

WMO: 946310

Lat: 34.5712S

Lon: 117.0106E

Elev: 251

StdP: 98.35

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	4.8	0.9	4.2	14.1	2.0	4.5	10.7	10.1	12.2	9.1	12.1	2.3	0	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.2	32.5	18.0	30.0	17.9	27.9	17.2	20.0	27.4	19.1	26.1	18.4	24.9	4.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.4	21.0	17.1	12.6	20.5	16.3	11.9	19.8	58.2	27.2	55.2	25.9	52.9	25.1	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 9.0	7.9	7.1	1.7	37.4	0.9	1.7	1.1	38.7	0.6	39.6	0.0	40.6	-0.6	41.8		
(5)			1.4	22.1	0.9	1.4	0.7	23.1	0.2	24.0	-0.3	24.8	-1.0	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	19.1	19.4	18.2	15.8	13.4	11.5	10.3	10.7	11.3	13.2	15.8	17.5	(6)
(7)		DBStd	4.28	3.12	3.19	3.37	3.08	2.41	2.01	1.88	2.08	2.43	2.88	3.37	3.38	(7)
(8)		HDD10.0	61	0	0	0	0	2	8	19	16	13	3	1	0	(8)
(9)		HDD18.3	1548	27	23	44	89	153	206	249	237	211	163	91	57	(9)
(10)		CDD10.0	1762	283	262	254	174	109	52	28	37	52	102	176	232	(10)
(11)		CDD18.3	207	52	52	39	13	1	0	0	0	0	3	16	31	(11)
(12)		CDH23.3	2036	520	464	341	93	8	0	0	0	2	40	198	371	(12)
(13)		CDH26.7	731	193	169	128	21	1	0	0	0	0	7	69	143	(13)
(14)	Wind	WSAvg	3.6	3.9	3.9	3.8	3.3	3.2	3.6	3.7	3.7	3.8	3.6	3.7	3.6	(14)
(15)	Precipitation	PrecAvg	791	22	16	40	52	92	105	121	108	98	61	44	33	(15)
(16)		PrecMax	995	101	49	103	160	162	313	193	165	181	116	128	78	(16)
(17)		PrecMin	571	5	2	6	17	49	51	64	47	44	28	11	6	(17)
(18)		PrecStd	114	24	12	25	33	29	48	34	29	35	22	28	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.3	34.5	34.3	29.5	24.1	19.3	17.7	19.7	22.5	27.5	32.4	35.4	(19)
(20)			MCWB	18.7	18.9	17.8	16.2	13.8	13.1	12.6	13.3	14.3	15.7	16.4	18.4	(20)
(21)		2%	DB	31.2	31.2	30.3	25.9	21.3	17.5	16.0	17.4	19.5	23.5	28.5	30.4	(21)
(22)			MCWB	18.5	18.4	17.9	15.9	13.9	12.5	12.2	12.7	13.5	15.1	16.6	17.9	(22)
(23)		5%	DB	28.4	28.6	27.1	23.4	19.3	16.2	14.9	15.9	17.6	20.7	25.2	27.2	(23)
(24)			MCWB	18.0	17.8	17.1	15.5	13.8	12.2	11.7	12.1	12.9	14.4	16.1	17.2	(24)
(25)		10%	DB	26.1	26.1	24.3	21.1	17.8	15.1	13.9	14.6	15.9	18.5	22.5	24.6	(25)
(26)			MCWB	17.2	17.3	16.5	15.0	13.5	11.8	11.2	11.4	12.2	13.6	15.2	16.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.7	20.2	18.5	17.2	15.1	14.2	15.0	15.9	17.6	19.2	20.3	(27)
(28)			MCDWB	30.1	28.9	27.7	23.9	19.8	17.0	15.7	17.4	20.0	24.1	26.4	29.4	(28)
(29)		2%	WB	19.9	19.7	19.1	17.4	16.0	14.1	13.1	13.6	14.3	16.2	17.8	18.7	(29)
(30)			MCDWB	27.9	26.3	25.2	22.0	18.1	16.1	14.7	16.2	18.0	21.6	24.9	27.2	(30)
(31)		5%	WB	18.7	18.8	18.4	16.6	15.0	13.2	12.3	12.6	13.3	15.0	16.7	17.7	(31)
(32)			MCDWB	26.3	25.4	23.5	20.7	17.7	15.1	14.1	14.9	16.8	19.4	23.2	25.4	(32)
(33)		10%	WB	17.7	18.0	17.6	15.7	14.1	12.3	11.5	11.8	12.5	14.1	15.7	16.6	(33)
(34)			MCDWB	24.6	24.2	22.1	19.5	16.6	14.2	13.4	14.1	15.6	17.8	21.7	23.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.6	12.2	11.1	9.6	8.3	6.9	6.8	7.4	8.4	9.9	11.7	12.6	(35)
(36)			MCDBR	17.3	16.7	15.8	13.2	10.7	8.4	7.9	9.2	11.0	14.0	16.8	17.9	(36)
(37)			MCWBR	6.1	5.4	5.0	4.9	5.2	5.0	4.9	5.4	5.9	6.6	6.5	6.6	(37)
(38)		5% WB	MCDWB	14.9	13.7	11.8	10.6	8.4	6.9	6.9	7.9	9.9	12.1	14.4	15.5	(38)
(39)			MCWBR	5.8	5.2	4.6	4.8	5.1	4.8	4.9	5.2	5.8	6.2	6.4	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.331	0.317	0.309	0.297	0.296	0.295	0.300	0.323	0.322	0.329	0.325	(40)	
(41)		taud	2.565	2.575	2.620	2.632	2.642	2.617	2.616	2.593	2.502	2.525	2.533	2.570	(41)	
(42)		Ebn at Noon	1005	984	964	916	875	846	868	912	940	982	1001	1016	(42)	
(43)		Edh at Noon	107	102	90	79	69	66	70	81	100	106	109	107	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.43	6.48	5.15	3.73	2.77	2.28	2.47	3.23	4.33	5.52	6.63	7.41	(44)	
(45)		RadStd	0.52	0.37	0.35	0.23	0.19	0.14	0.11	0.15	0.18	0.35	0.44	0.45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-79	N/A	N/A	(47)

Nomenclature: See separate page