

SOUTHERN CROSS, Australia

WMO: 946340

Lat: 31.233S

Lon: 119.333E

Elev: 1168

StdP: 14.09

Time Zone: 8.00 (E08)

Period: 90-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 35.7	(c) 38.0	(d) 26.2	(e) 21.0	(f) 70.5	(g) 28.7	(h) 23.6	(i) 65.9	(j) 33.9	(k) 56.8	(l) 32.6	(m) 57.0	(n) 0.5	(o) 180	(p) 0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 26.1	(c) 101.7	(d) 68.4	(e) 98.8	(f) 67.4	(g) 95.8	(h) 66.5	(i) 73.2	(j) 89.6	(k) 71.2	(l) 90.7	(m) 69.3	(n) 88.3	(o) 6.5	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.6	109.6	79.6	65.3	97.6	77.2	63.2	90.6	75.7	37.7	89.1	35.8	90.9	34.0	88.2	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.4	25.8	20.3		DB	31.4	107.0	1.4	2.3	30.4	108.7	29.6	110.0	28.8	111.3	27.8	113.0
				WB	30.4	76.7	1.4	2.9	29.4	78.8	28.6	80.5	27.8	82.1	26.8	84.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	78.9	76.9	72.9	66.9	59.6	53.7	51.9	53.1	58.1	64.0	71.3	75.2
	DBStd	11.15	7.13	6.91	7.15	5.75	5.61	4.02	4.17	4.65	5.78	6.44	6.47	6.56
	HDD50	66	0	0	0	0	1	13	29	18	5	0	0	0
	HDD65	1693	2	2	10	46	185	338	407	370	217	99	14	3
	CDD50	5593	896	754	711	506	299	125	87	114	249	433	638	781
	CDD65	1746	433	337	256	102	18	0	0	1	11	67	202	319
	CDH74	21428	5661	4274	2947	925	165	1	1	24	232	942	2389	3867
CDH80	10798	3263	2345	1424	307	30	0	0	3	51	319	1074	1982	
Wind	WSAvg	6.4	8.1	8.6	7.0	4.8	4.6	4.2	5.2	5.3	6.3	6.9	7.3	8.3
Precipitation	PrecAvg	12.7	0.9	1.0	0.9	1.2	1.5	2.0	1.6	1.3	0.8	0.6	0.8	0.6
	PrecMax	22.7	4.9	5.3	6.7	4.2	4.4	7.2	3.9	5.4	2.0	2.3	2.7	2.5
	PrecMin	7.2	0.0	0.0	0.0	0.0	0.1	0.6	0.2	0.4	0.1	0.0	0.0	0.0
	PrecStd	3.0	1.1	1.2	1.3	1.0	1.2	1.2	0.9	0.9	0.5	0.6	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.7	104.9	101.7	91.6	84.1	71.9	71.9	76.9	86.5	93.1	99.3	103.0
		MCWB	69.4	68.7	68.1	61.6	60.1	55.0	54.5	56.6	58.7	62.6	65.2	69.6
	2%	DB	101.8	101.0	97.2	87.4	78.6	68.7	66.9	71.4	79.9	87.7	94.9	98.2
		MCWB	69.0	68.1	66.6	61.6	59.7	55.1	53.7	55.3	57.7	60.9	64.6	66.0
	5%	DB	98.9	97.0	92.4	83.5	74.5	65.7	63.5	67.4	75.7	83.5	90.4	95.2
		MCWB	68.5	67.4	65.6	61.7	58.7	54.4	53.0	53.9	56.9	59.3	62.8	65.3
	10%	DB	95.4	92.9	87.8	79.4	70.6	62.8	61.0	63.7	71.4	79.2	86.7	91.5
		MCWB	67.5	66.1	64.2	61.1	57.9	53.5	52.7	52.6	56.0	58.1	61.4	64.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	75.5	71.7	67.4	65.5	60.0	59.7	60.8	62.1	65.5	69.2	72.1
		MCDB	93.5	86.5	92.0	78.6	76.4	65.9	63.2	68.1	77.2	83.5	91.3	95.0
	2%	WB	73.8	72.9	69.4	65.6	63.1	57.6	56.7	58.0	59.8	63.0	66.6	69.5
		MCDB	88.6	90.0	88.0	78.7	72.6	64.0	62.1	66.3	73.9	80.9	88.3	91.2
	5%	WB	71.7	71.1	67.7	64.0	61.1	55.9	54.9	56.0	58.2	61.0	64.7	67.6
		MCDB	92.3	87.5	85.6	76.3	69.8	62.3	60.7	64.6	71.4	79.5	84.5	88.0
	10%	WB	69.4	68.8	66.1	62.6	59.3	54.4	53.4	53.9	56.7	59.0	62.9	65.9
		MCDB	89.6	85.9	83.0	75.0	67.1	60.9	59.4	61.4	69.5	76.5	81.1	85.1
Mean Daily Temperature Range	5% DB	MDBR	26.1	24.8	23.1	21.2	19.5	19.4	18.3	20.9	24.2	24.8	24.3	24.9
		MCDBR	30.1	30.8	28.5	28.2	26.0	24.8	23.8	28.1	31.9	31.5	29.1	29.5
		MCWBR	9.9	10.6	9.5	10.9	11.6	13.7	13.0	13.5	13.8	11.9	10.1	10.0
	5% WB	MCDBR	27.2	25.3	24.7	21.7	19.2	19.2	17.3	22.6	25.9	27.1	25.7	26.7
		MCWBR	11.0	10.0	9.4	9.8	10.2	11.9	11.4	12.3	12.3	11.2	9.6	10.0
Clear-Sky Solar Irradiance	taub	0.331	0.332	0.315	0.302	0.286	0.278	0.276	0.283	0.300	0.313	0.317	0.319	
	taud	2.569	2.588	2.618	2.635	2.652	2.649	2.659	2.622	2.559	2.534	2.548	2.571	
	Ebn at Noon	320	314	309	297	288	282	289	299	309	316	322	325	
	Edh at Noon	34	32	29	26	23	22	22	26	30	34	35	34	
All-Sky Solar Radiation	RadAvg	2527	2246	1930	1467	1118	928	982	1293	1727	2155	2455	2640	
	RadStd	154	149	115	77	74	56	54	66	84	124	121	135	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page