

SOUTHERN CROSS, Australia

WMO: 946340

Lat: 31.233S

Lon: 119.333E

Elev: 356

StdP: 97.12

Time Zone: 8.00 (E08)

Period: 90-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.1	3.3	-3.2	3.0	21.4	-1.9	3.4	18.8	15.2	13.8	14.6	13.9	0.2	180	0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	38.7	20.2	37.1	19.7	35.5	19.1	22.9	32.0	21.8	32.6	20.7	31.3	2.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.7	26.4	18.5	13.9	25.1	17.3	12.9	24.3	69.7	31.7	65.3	32.7	61.3	31.2	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	11.5	9.1	DB	-0.4	41.7	0.8	1.3	-0.9	42.6	-1.3	43.4	-1.8	44.1	-2.3	45.0	
			WB	-0.9	24.8	0.8	1.6	-1.4	26.0	-1.9	26.9	-2.3	27.8	-2.9	29.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	26.1	25.0	22.7	19.4	15.3	12.1	11.0	11.7	14.5	17.8	21.8	24.0
	DBStd	6.19	3.96	3.84	3.97	3.19	3.11	2.23	2.32	2.58	3.21	3.58	3.59	3.65
	HDD10.0	37	0	0	0	0	1	7	16	10	3	0	0	0
	HDD18.3	941	1	1	6	26	103	188	226	206	121	55	8	2
	CDD10.0	3107	498	419	395	281	166	69	48	63	138	241	354	434
	CDD18.3	970	241	187	142	57	10	0	0	1	6	37	112	177
	CDH23.3	11904	3145	2374	1637	514	92	1	1	13	129	523	1327	2148
	CDH26.7	5999	1813	1303	791	171	17	0	0	2	28	177	597	1101
Wind	WSAvg	2.9	3.6	3.9	3.1	2.1	2.0	1.9	2.3	2.4	2.8	3.1	3.3	3.7
Precipitation	PrecAvg	323	22	25	24	31	39	50	41	34	20	16	20	14
	PrecMax	577	124	135	169	107	111	183	98	137	51	59	69	63
	PrecMin	183	0	0	0	0	2	14	6	9	2	0	0	0
	PrecStd	77	29	30	34	25	30	30	23	23	12	15	17	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.0	40.5	38.7	33.1	28.9	22.2	22.2	24.9	30.3	33.9	37.4	39.5
		MCWB	20.8	20.4	20.1	16.5	15.6	12.8	12.5	13.7	14.8	17.0	18.5	20.9
	2%	DB	38.8	38.3	36.2	30.8	25.9	20.4	19.4	21.9	26.6	30.9	35.0	36.8
		MCWB	20.6	20.1	19.2	16.4	15.4	12.8	12.1	12.9	14.3	16.1	18.1	18.9
	5%	DB	37.2	36.1	33.5	28.6	23.6	18.7	17.5	19.7	24.3	28.6	32.4	35.1
		MCWB	20.3	19.7	18.7	16.5	14.9	12.5	11.7	12.2	13.8	15.2	17.1	18.5
	10%	DB	35.2	33.8	31.0	26.3	21.4	17.1	16.1	17.6	21.9	26.2	30.4	33.1
		MCWB	19.7	18.9	17.9	16.2	14.4	11.9	11.5	11.4	13.3	14.5	16.3	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.2	22.1	19.7	18.6	15.6	15.4	16.0	16.7	18.6	20.6	22.3
		MCDB	34.2	30.3	33.4	25.9	24.6	18.8	17.3	20.0	25.1	28.6	32.9	35.0
	2%	WB	23.2	22.7	20.8	18.7	17.3	14.2	13.7	14.5	15.5	17.2	19.2	20.8
		MCDB	31.4	32.2	31.1	25.9	22.6	17.8	16.7	19.1	23.3	27.2	31.3	32.9
	5%	WB	22.1	21.7	19.8	17.8	16.2	13.3	12.7	13.3	14.6	16.1	18.1	19.8
		MCDB	33.5	30.8	29.8	24.6	21.0	16.9	15.9	18.1	21.9	26.4	29.2	31.1
	10%	WB	20.8	20.5	18.9	17.0	15.2	12.5	11.9	12.2	13.7	15.0	17.2	18.8
		MCDB	32.0	30.0	28.4	23.9	19.5	16.1	15.2	16.3	20.8	24.7	27.3	29.5
Mean Daily Temperature Range	5% DB	MDBR	14.5	13.8	12.8	11.8	10.8	10.8	10.2	11.6	13.5	13.8	13.5	13.8
		MCDBR	16.7	17.1	15.8	15.7	14.5	13.8	13.2	15.6	17.7	17.5	16.1	16.4
		MCWBR	5.5	5.9	5.3	6.0	6.5	7.6	7.2	7.5	7.7	6.6	5.6	5.6
	5% WB	MCDBR	15.1	14.0	13.7	12.1	10.7	10.7	9.6	12.6	14.4	15.0	14.3	14.8
		MCWBR	6.1	5.5	5.2	5.5	5.7	6.6	6.3	6.8	6.8	6.2	5.3	5.5
Clear-Sky Solar Irradiance	taub		0.331	0.332	0.315	0.302	0.286	0.278	0.276	0.283	0.300	0.313	0.317	0.319
	taud		2.569	2.588	2.618	2.635	2.652	2.649	2.659	2.622	2.559	2.534	2.548	2.571
	Ebn at Noon		1008	989	974	937	907	890	910	944	974	997	1016	1024
	Edh at Noon		107	102	92	82	72	68	70	81	96	106	109	107
All-Sky Solar Radiation	RadAvg		7.97	7.08	6.08	4.63	3.52	2.93	3.10	4.08	5.44	6.79	7.74	8.32
	RadStd		0.48	0.47	0.36	0.24	0.23	0.17	0.17	0.21	0.27	0.39	0.38	0.42

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page