

KALGOORLIE BOULDER, AustraliaWMO: **946370**Lat: **30.7847S**Lon: **121.4533E**Elev: **1201**StdP: **14.07**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.7	38.9	13.9	11.6	78.0	18.0	14.3	75.1	21.8	59.6	20.1	60.7	3.6	220	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.6	103.5	65.1	100.0	64.5	96.5	63.6	71.7	85.5	69.6	85.8	67.8	84.7	11.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	108.4	75.5	65.2	97.6	73.8	62.8	89.3	72.1	36.3	84.6	34.4	85.8	32.8	84.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.7	17.0	DB	31.9	109.4	1.5	2.8	30.9	111.4	30.0	113.0	29.2	114.6	28.1	116.6	(4)
(5)			WB	30.8	74.6	1.7	2.2	29.6	76.1	28.6	77.4	27.6	78.7	26.4	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	78.7	77.3	72.5	66.8	59.2	53.7	52.5	55.1	60.0	66.6	71.6	75.9	(6)
(7)		DBStd	11.17	7.42	7.50	7.17	6.01	5.61	4.51	4.48	5.49	6.32	7.25	7.45	7.50	(7)
(8)		HDD50	51	0	0	0	0	2	13	24	10	2	0	0	0	(8)
(9)		HDD65	1571	1	2	13	48	196	340	388	312	178	68	21	4	(9)
(10)		CDD50	5800	889	764	699	505	288	124	101	167	301	514	647	801	(10)
(11)		CDD65	1844	425	346	247	103	17	1	0	5	26	117	217	340	(11)
(12)		CDH74	22549	5542	4222	2663	916	149	5	4	97	401	1465	2680	4405	(12)
(13)		CDH80	11506	3159	2312	1261	306	24	0	0	15	115	616	1303	2395	(13)
(14)	Wind	WSAvg	8.9	10.9	10.5	9.3	7.6	6.8	7.0	7.3	7.8	8.8	9.8	10.3	10.7	(14)
(15)	Precipitation	PrecAvg	10.8	1.1	1.3	1.1	0.9	1.1	1.1	1.0	0.9	0.6	0.6	0.8	0.7	(15)
(16)		PrecMax	20.9	6.7	7.8	7.8	3.9	4.3	7.3	3.3	2.9	2.3	3.3	4.5	3.5	(16)
(17)		PrecMin	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.9	1.3	1.5	1.6	0.9	1.0	1.2	0.7	0.7	0.5	0.7	0.8	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.9	107.2	101.7	92.9	83.0	73.7	73.6	82.3	88.6	96.1	101.9	105.2	(19)
(20)			MCWB	65.6	66.2	63.3	61.2	57.5	54.0	52.4	54.4	57.5	59.6	62.4	63.9	(20)
(21)		2%	DB	103.8	102.0	96.3	87.8	78.2	69.8	69.6	76.4	83.2	91.5	96.8	101.2	(21)
(22)			MCWB	65.5	66.1	63.2	60.0	57.0	53.0	51.6	52.9	55.7	58.9	61.4	63.8	(22)
(23)		5%	DB	99.4	97.5	91.6	83.0	74.3	66.5	66.2	71.6	78.6	87.4	92.0	97.0	(23)
(24)			MCWB	65.2	65.4	63.3	59.8	56.1	52.0	50.8	52.2	54.8	58.1	60.5	63.2	(24)
(25)		10%	DB	95.0	93.2	87.3	79.0	70.6	63.7	63.0	67.4	74.1	82.5	87.8	92.7	(25)
(26)			MCWB	64.4	64.8	62.6	59.4	55.2	51.1	50.3	51.1	53.7	57.1	59.5	62.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	75.2	70.4	67.3	63.2	59.0	57.9	58.7	61.2	64.9	67.2	70.8	(27)
(28)			MCDWB	86.1	86.2	82.0	78.9	72.4	66.6	64.1	67.8	77.9	82.7	83.3	88.8	(28)
(29)		2%	WB	71.3	72.6	67.9	64.8	61.0	56.6	55.1	56.3	58.3	62.1	65.0	68.3	(29)
(30)			MCDWB	87.6	84.7	81.3	77.4	69.0	63.5	62.7	67.9	75.7	79.3	84.8	86.5	(30)
(31)		5%	WB	69.4	70.2	66.4	63.1	59.1	54.7	53.4	54.4	56.7	60.3	63.4	66.2	(31)
(32)			MCDWB	87.2	84.5	80.7	74.5	68.5	61.9	61.4	66.4	72.9	79.6	83.4	87.0	(32)
(33)		10%	WB	67.3	68.0	64.8	61.5	57.2	53.0	51.8	52.6	55.2	58.5	61.7	64.3	(33)
(34)			MCDWB	86.9	84.6	79.7	73.6	67.2	60.5	60.4	64.5	70.2	78.2	82.0	86.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	25.6	23.6	21.8	21.3	20.4	19.5	20.0	22.3	24.2	25.0	25.0	25.7	(35)
(36)			MCDBR	31.0	30.0	28.0	26.5	24.6	22.9	24.9	28.1	30.5	30.8	30.7	30.6	(36)
(37)			MCWBR	9.1	8.9	9.1	9.4	10.5	11.1	11.9	12.3	11.8	10.8	9.6	9.6	(37)
(38)		5% WB	MCDWR	26.0	23.9	21.8	20.8	18.7	18.4	19.3	22.7	25.4	26.5	27.6	27.2	(38)
(39)			MCWBR	9.2	9.1	8.8	9.0	9.4	10.4	10.9	11.7	11.0	10.3	9.4	9.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.337	0.317	0.304	0.286	0.276	0.274	0.282	0.300	0.315	0.321	0.321	(40)	
(41)		taud	2.605	2.615	2.650	2.659	2.687	2.688	2.695	2.642	2.579	2.554	2.567	2.604	(41)	
(42)		Ebn at Noon	319	312	309	297	289	285	291	301	309	316	321	324	(42)	
(43)		Edh at Noon	33	31	29	25	22	21	22	25	30	33	34	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2466	2165	1866	1461	1125	948	1036	1357	1796	2162	2413	2590	(44)	
(45)		RadStd	169	194	129	83	77	57	57	63	80	126	124	145	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page