

NORSEMAN, Australia

WMO: 946390

Lat: 32.200S

Lon: 121.783E

Elev: 278

StdP: 98.03

Time Zone: 8.00 (E08)

Period: 90-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.6	3.0	-0.3	3.8	9.2	0.7	4.1	9.5	12.3	14.5	10.7	16.5	0.1	0	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	37.9	21.4	35.7	20.8	33.8	20.3	24.3	32.3	22.7	32.1	21.6	30.8	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.2	28.7	20.0	15.2	26.4	18.8	14.0	25.0	74.7	31.8	68.6	32.2	64.0	30.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.5	7.7		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				-1.1	27.9	0.8	2.2	-1.8	29.5	-2.3	30.8	-2.7	32.1	-3.3	33.7
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	24.4	23.4	21.4	18.7	14.9	11.9	11.1	11.7	14.5	17.1	20.1	22.3		
	DBStd	5.63	3.49	3.60	3.71	3.13	2.92	2.21	2.39	2.61	3.30	3.97	3.96	3.59		
	HDD10.0	36	0	0	0	0	1	7	16	10	3	0	0	0		
	HDD18.3	1012	1	2	10	33	113	193	226	206	123	72	26	7		
	CDD10.0	2806	447	375	352	262	153	64	48	63	137	221	303	382		
	CDD18.3	741	189	143	104	45	7	0	0	1	7	35	78	131		
	CDH23.3	8731	2339	1665	1131	390	54	0	0	17	118	476	956	1585		
	CDH26.7	4109	1253	843	508	118	8	0	0	2	29	181	406	762		
(14) Wind	WSAvg	2.7	3.1	3.0	3.0	2.3	2.1	2.3	2.5	2.5	2.8	2.9	3.2	3.2		
(15) Precipitation	PrecAvg	305	23	28	27	25	33	33	30	23	23	18	23	24		
	PrecMax	610	116	159	189	92	113	104	80	65	66	72	87	151		
	PrecMin	177	0	0	0	0	1	5	2	4	0	0	0	0		
	PrecStd	86	29	36	40	20	28	21	18	14	18	15	19	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.5	41.0	38.2	32.5	28.2	21.6	21.8	25.3	30.2	34.3	36.2	37.8		
		MCWB	21.8	23.2	21.6	18.3	17.1	14.0	13.8	14.3	16.6	18.4	19.8	20.5		
	2%	DB	37.8	37.7	34.9	30.4	24.9	19.8	19.6	21.9	26.6	31.3	33.7	35.2		
		MCWB	21.5	22.0	20.7	18.2	16.0	13.7	12.8	13.2	15.3	17.7	19.5	20.1		
	5%	DB	35.4	34.9	31.7	27.8	22.8	18.4	17.8	19.7	24.1	28.6	31.2	33.1		
		MCWB	20.8	21.3	20.0	17.8	15.6	13.2	12.1	12.7	14.5	16.9	18.7	19.7		
	10%	DB	33.1	32.2	29.0	25.4	20.9	17.2	16.4	17.6	22.0	25.8	28.8	31.1		
		MCWB	20.3	20.9	18.8	17.2	15.0	12.5	11.5	11.9	13.8	15.9	17.7	19.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	26.7	24.1	20.9	19.4	16.2	15.5	16.0	17.8	20.1	23.0	24.8		
		MCDB	32.8	34.0	31.4	27.4	24.4	18.7	19.0	21.5	26.7	30.6	32.0	33.1		
	2%	WB	23.6	24.7	22.0	19.9	17.6	15.1	13.7	14.4	16.2	18.6	21.0	21.7		
		MCDB	33.0	31.6	30.9	25.8	22.1	17.8	17.3	19.3	24.3	28.6	30.7	31.3		
	5%	WB	22.2	23.1	20.8	18.9	16.6	14.2	12.8	13.3	15.1	17.3	19.6	20.6		
		MCDB	32.3	32.1	29.6	24.9	20.9	17.1	16.5	18.2	22.2	26.7	28.4	30.9		
	10%	WB	21.1	21.7	19.8	18.0	15.7	13.1	12.0	12.4	14.3	16.3	18.3	19.6		
		MCDB	31.4	30.0	27.2	23.7	19.5	16.3	15.5	16.9	20.8	25.0	26.8	29.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	14.1	13.0	12.1	10.7	11.0	10.6	11.8	13.0	14.2	14.1	14.7		
		MCDBR	18.4	18.9	17.2	15.6	13.5	13.0	12.7	16.1	16.7	17.4	17.2	17.8		
		MCWBR	6.2	6.7	6.4	6.9	6.9	7.7	7.3	8.7	7.6	7.0	7.0	6.2		
	5% WB	MCDBR	16.6	16.4	14.9	12.8	10.9	10.5	10.7	13.5	15.0	15.8	15.8	16.2		
		MCWBR	7.2	7.6	6.6	6.5	6.5	6.8	7.0	8.0	7.2	7.1	7.3	6.9		
(40) Clear-Sky Solar Irradiance	taub	0.337	0.338	0.319	0.308	0.292	0.281	0.279	0.288	0.307	0.319	0.325	0.325			
	taud	2.593	2.604	2.639	2.654	2.669	2.680	2.684	2.641	2.566	2.556	2.566	2.597			
	Ebn at Noon	1002	982	967	928	895	883	902	937	965	990	1007	1017			
	Edh at Noon	104	100	90	80	70	65	68	79	95	103	106	104			
(44) All-Sky Solar Radiation	RadAvg	7.63	6.70	5.61	4.29	3.24	2.76	2.98	3.92	5.24	6.41	7.27	7.94			
	RadStd	0.46	0.54	0.37	0.25	0.20	0.14	0.16	0.20	0.21	0.40	0.46	0.49			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.23	N/A	N/A	N/A	N/A	N/A	N/A	-62	+87	+40

Nomenclature: See separate page