

KATANNING, Australia

WMO: 946410

Lat: 33.6856S

Lon: 117.6064E

Elev: 321

StdP: 97.53

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.8	3.8	-2.3	3.2	23.4	-0.5	3.8	19.0	12.1	13.3	10.8	12.8	1.6	270	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	36.0	18.0	33.7	17.7	31.6	17.2	20.3	29.4	19.3	28.8	18.5	27.7	3.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	13.2	22.3	16.5	12.2	21.3	15.6	11.5	20.5	59.8	29.8	56.3	28.7	53.4	27.7	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	9.4	8.3	0.7	40.3	1.1	1.4	-0.1	41.3	-0.7	42.1	-1.3	42.9	-2.1	43.9		
(5)			0.1	23.6	1.0	2.9	-0.6	25.7	-1.2	27.5	-1.8	29.1	-2.5	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	21.5	21.5	19.7	16.9	13.6	11.3	10.2	10.6	11.5	14.2	17.8	19.7		
	DBStd	5.04	3.24	3.18	3.35	3.09	2.49	2.00	1.88	2.10	2.55	3.12	3.44	3.43		
	HDD10.0	64	0	0	0	0	2	9	22	17	12	2	0	0		
	HDD18.3	1368	7	7	23	63	148	212	253	240	206	134	51	24		
	CDD10.0	2134	358	322	300	208	114	47	26	36	57	132	233	300		
	CDD18.3	396	107	95	66	21	2	0	0	0	0	6	34	65		
	CDH23.3	4847	1301	1064	691	190	17	0	0	1	9	127	537	912		
	CDH26.7	2154	646	493	285	47	2	0	0	0	1	36	220	426		
(14) Wind	WSAvg	3.7	4.4	4.4	3.9	3.2	3.0	3.3	3.4	3.3	3.7	3.7	4.1	4.1		
(15) Precipitation	PrecAvg	480	14	17	21	32	60	77	73	65	47	33	26	15		
	PrecMax	675	87	74	134	106	165	154	129	130	105	95	98	61		
	PrecMin	330	0	0	0	0	7	22	27	19	16	5	4	0		
	PrecStd	88	20	20	29	25	33	36	26	23	22	19	20	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.3	37.5	35.9	30.9	25.4	20.0	18.1	20.6	24.5	30.5	35.0	38.1		
		MCWB	19.5	19.2	17.6	16.9	14.3	12.1	11.9	13.3	14.2	16.0	17.1	17.5		
	2%	DB	35.7	35.0	32.8	27.7	22.5	18.1	16.4	17.8	21.0	26.9	31.9	34.5		
		MCWB	18.1	18.9	17.7	16.5	13.7	12.0	11.6	12.5	13.4	15.1	16.1	17.4		
	5%	DB	33.0	32.3	30.0	25.3	20.4	16.6	15.2	16.3	18.8	23.9	29.1	31.4		
		MCWB	17.8	17.9	17.2	15.6	13.3	11.7	11.4	12.0	12.9	14.1	15.5	16.7		
	10%	DB	30.3	29.8	27.1	23.2	18.7	15.3	14.1	14.9	16.9	21.2	26.1	28.5		
		MCWB	17.2	17.4	16.5	14.9	13.0	11.5	10.9	11.3	12.1	13.4	14.8	15.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.6	20.1	18.7	17.3	14.8	13.8	14.7	15.9	18.0	18.8	20.3		
		MCDB	30.1	31.4	28.2	25.3	21.3	17.2	15.7	18.3	21.3	26.1	28.9	30.0		
	2%	WB	20.2	20.4	19.1	17.7	16.0	13.6	12.7	13.5	14.3	16.0	17.4	18.7		
		MCDB	29.7	29.3	27.3	23.7	19.0	16.3	15.0	16.5	19.4	23.8	27.5	29.3		
	5%	WB	19.0	19.3	18.3	16.9	14.9	12.7	12.0	12.6	13.3	15.0	16.4	17.6		
		MCDB	29.6	28.9	26.2	22.7	18.1	15.2	14.3	15.3	17.7	21.8	25.9	28.5		
	10%	WB	17.9	18.3	17.5	16.0	13.9	12.0	11.2	11.7	12.4	14.0	15.5	16.6		
		MCDB	28.0	27.3	24.8	20.9	17.3	14.4	13.6	14.3	16.3	20.2	24.3	26.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	14.5	13.0	11.2	9.8	8.2	7.9	8.7	10.4	12.8	14.5	15.1		
		MCDBR	20.4	19.1	17.7	14.7	12.9	10.1	9.3	10.8	13.7	17.4	19.8	20.7		
		MCWBR	5.9	5.5	5.7	5.8	6.1	5.7	5.9	6.6	7.4	7.2	6.6	6.2		
	5% WB	MCDBR	16.8	16.0	14.1	11.8	9.3	8.1	7.9	9.0	11.9	14.3	16.5	17.7		
		MCWBR	6.1	5.8	5.4	5.6	5.6	5.4	5.8	6.0	6.9	7.0	6.5	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.326	0.313	0.304	0.290	0.288	0.286	0.293	0.315	0.316	0.322	0.319		
	taud		2.527	2.544	2.578	2.597	2.613	2.596	2.600	2.563	2.471	2.500	2.507	2.536		
	Ebn at Noon		1009	991	969	925	886	861	882	922	951	990	1009	1022		
	Edh at Noon		111	105	95	83	72	68	72	84	103	109	113	111		
(44) All-Sky Solar Radiation	RadAvg		7.88	6.99	5.62	4.08	3.03	2.51	2.68	3.46	4.66	5.98	7.19	8.01		
	RadStd		0.49	0.36	0.33	0.27	0.20	0.13	0.13	0.14	0.18	0.35	0.45	0.45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e) +0.44	(f) -1.37	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105	N/A

Nomenclature: See separate page