

RED ROCKS POINT, Australia

WMO: 946440

Lat: 32.203S

Lon: 127.530E

Elev: 12

StdP: 14.69

Time Zone: 8.75 (AUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.3	43.1	25.2	19.2	67.8	30.1	24.2	61.8	23.4	59.1	21.2	56.7	10.0	350	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	89.3	63.3	82.7	64.3	78.5	66.2	71.7	78.1	70.5	76.1	69.4	74.4	13.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	109.3	74.8	68.4	104.5	73.8	67.5	101.0	73.0	35.6	78.8	34.5	76.6	33.6	74.5	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.9	25.4	23.3	DB	37.5	105.7	1.4	7.9	36.5	111.4	35.7	116.0	34.9	120.4	33.9	126.1	(4)
(5)			WB	35.1	74.7	1.9	1.3	33.8	75.7	32.7	76.4	31.6	77.2	30.2	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	70.3	70.0	68.4	65.5	60.7	56.7	54.8	56.1	58.5	62.2	64.8	67.7	(6)
(7)		DBStd	6.83	4.05	3.03	3.76	4.21	4.18	3.49	3.58	4.70	5.14	5.43	4.50	4.11	(7)
(8)		HDD50	3	0	0	0	0	0	0	1	2	0	0	0	0	(8)
(9)		HDD65	1442	2	0	9	42	147	249	318	283	210	120	50	12	(9)
(10)		CDD50	4729	629	560	572	465	332	202	150	190	255	380	445	549	(10)
(11)		CDD65	692	165	141	115	57	13	2	2	7	14	35	46	95	(11)
(12)		CDH74	2428	479	236	240	196	100	14	26	95	193	307	239	303	(12)
(13)		CDH80	896	145	60	81	70	33	0	5	25	81	163	121	112	(13)
(14)	Wind	WSAvg	13.6	16.4	15.8	14.9	12.3	10.9	10.7	10.1	11.2	12.8	15.4	16.7	15.7	(14)
(15)	Precipitation	PrecAvg	12.7	1.2	1.4	1.1	0.9	1.0	1.2	1.0	0.9	0.8	0.9	1.2	(15)	
(16)		PrecMax	21.3	5.0	9.1	3.4	2.8	2.4	2.4	2.9	2.8	3.7	1.9	2.2	3.5	(16)
(17)		PrecMin	3.1	0.2	0.0	0.0	0.1	0.1	0.4	0.1	0.2	0.1	0.1	0.1	0.2	(17)
(18)		PrecStd	3.6	1.3	1.8	0.9	0.6	0.7	0.6	0.7	0.7	0.8	0.5	0.6	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	89.3	89.1	89.2	84.8	76.1	77.5	83.6	90.5	95.8	94.3	93.6	(19)
(20)			MCWB	72.8	69.0	62.8	62.7	61.2	57.9	56.2	56.5	59.8	61.9	64.5	68.0	(20)
(21)		2%	DB	81.8	79.1	79.0	78.3	74.9	70.9	70.2	75.3	79.4	82.4	79.7	80.0	(21)
(22)			MCWB	70.4	69.7	67.9	63.9	59.0	56.1	54.0	55.1	57.0	60.6	64.5	67.5	(22)
(23)		5%	DB	78.2	76.1	75.2	74.5	70.8	67.0	65.8	68.7	71.3	72.5	73.3	76.1	(23)
(24)			MCWB	70.3	68.7	67.3	65.0	60.0	55.5	53.6	54.1	56.6	60.6	64.0	66.9	(24)
(25)		10%	DB	75.4	74.4	73.3	72.0	68.1	64.2	62.7	64.4	66.3	68.3	70.6	73.4	(25)
(26)			MCWB	68.3	67.3	66.4	64.7	60.3	55.5	54.2	55.2	57.3	60.7	63.4	66.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	72.7	71.4	69.3	66.5	62.1	60.1	60.8	62.3	66.0	69.2	71.8	(27)
(28)			MCD B	83.7	78.1	79.0	74.4	71.4	69.9	66.4	67.0	73.4	77.1	76.4	80.2	(28)
(29)		2%	WB	72.3	71.1	69.7	68.1	64.6	59.7	58.2	59.0	60.9	64.1	67.2	69.8	(29)
(30)			MCD B	79.5	75.7	74.5	72.6	69.1	65.8	64.5	65.9	69.4	72.0	73.8	77.0	(30)
(31)		5%	WB	70.8	70.2	68.5	67.1	62.9	58.3	56.7	57.5	59.4	62.9	65.5	68.3	(31)
(32)			MCD B	76.7	74.5	73.1	71.7	68.3	63.8	61.8	63.9	66.5	69.8	71.5	74.7	(32)
(33)		10%	WB	69.4	69.2	67.6	65.9	61.3	57.2	55.4	56.2	58.4	61.6	64.1	66.9	(33)
(34)			MCD B	74.5	73.3	72.2	70.7	66.8	62.1	60.6	62.3	64.7	67.8	69.9	72.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	8.7	9.9	14.2	15.6	16.2	17.6	17.7	16.7	13.9	11.4	10.6	(35)
(36)			MCDBR	16.7	14.0	15.0	20.0	21.7	22.5	24.1	27.3	28.1	26.9	20.7	18.9	(36)
(37)			MCWBR	9.4	8.9	9.0	11.3	12.0	12.3	13.5	13.4	12.5	11.8	10.1	10.6	(37)
(38)		5% WB	MCD BR	14.5	11.6	12.1	15.0	16.1	17.0	18.1	19.4	19.4	18.1	16.6	14.8	(38)
(39)			MCWBR	9.1	7.9	8.0	9.8	11.0	11.5	12.5	12.6	11.3	9.5	8.9	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.369	0.346	0.331	0.314	0.299	0.300	0.309	0.339	0.344	0.354	0.356	(40)	
(41)		taud	2.513	2.532	2.576	2.613	2.628	2.650	2.631	2.595	2.501	2.502	2.505	2.526	(41)	
(42)		Ebn at Noon	308	301	298	286	275	273	278	289	295	305	310	313	(42)	
(43)		Edh at Noon	36	34	30	26	23	21	23	26	32	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2305	2010	1703	1326	1009	872	962	1262	1658	2031	2235	2390	(44)	
(45)		RadStd	176	200	102	75	61	38	61	63	106	94	152	135	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page