

RED ROCKS POINT, Australia

WMO: 946440

Lat: 32.203S

Lon: 127.530E

Elev: 4

StdP: 101.28

Time Zone: 8.75 (AUE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	6.2	-3.8	2.7	19.9	-1.1	3.5	16.6	10.5	15.0	9.5	13.7	4.5	350	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	31.8	17.4	28.2	17.9	25.8	19.0	22.1	25.6	21.4	24.5	20.8	23.6	6.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.0	15.6	23.8	20.2	14.9	23.2	19.7	14.4	22.8	64.8	26.0	62.4	24.8	60.3	23.6	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.5	11.3	10.4	DB	3.0	41.0	0.8	4.4	2.5	44.1	2.1	46.7	1.6	49.1	1.1	52.3
			WB	1.7	23.7	1.1	0.7	1.0	24.3	0.4	24.7	-0.2	25.1	-1.0	25.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	21.3	21.1	20.2	18.6	15.9	13.7	12.7	13.4	14.7	16.8	18.2	19.8
	DBStd	3.79	2.25	1.68	2.09	2.34	2.32	1.94	1.99	2.61	2.86	3.02	2.50	2.28
	HDD10.0	2	0	0	0	0	0	0	1	1	0	0	0	0
	HDD18.3	801	1	0	5	23	82	138	177	157	117	67	28	7
	CDD10.0	2627	349	311	318	258	184	112	83	106	142	211	247	305
	CDD18.3	384	92	78	64	32	7	1	1	4	8	19	26	53
	CDH23.3	1349	266	131	133	109	56	8	14	53	107	171	133	168
	CDH26.7	498	81	33	45	39	18	0	3	14	45	91	67	62
Wind	WSAvg	6.1	7.3	7.0	6.7	5.5	4.9	4.8	4.5	5.0	5.7	6.9	7.5	7.0
Precipitation	PrecAvg	323	30	36	28	24	26	30	26	26	23	21	24	31
	PrecMax	541	126	230	86	71	62	60	73	72	94	48	56	90
	PrecMin	79	4	1	1	2	3	9	3	4	2	3	2	5
	PrecStd	92	32	45	23	16	18	14	18	17	20	13	15	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	31.8	31.7	31.8	29.3	24.5	25.3	28.7	32.5	35.4	34.6	34.2
		MCWB	22.7	20.5	17.1	17.1	16.2	14.4	13.5	13.6	15.4	16.6	18.1	20.0
	2%	DB	27.7	26.1	26.1	25.7	23.8	21.6	21.2	24.1	26.3	28.0	26.5	26.6
		MCWB	21.3	20.9	20.0	17.7	15.0	13.4	12.2	12.8	13.9	15.9	18.1	19.7
	5%	DB	25.7	24.5	24.0	23.6	21.5	19.5	18.8	20.4	21.8	22.5	23.0	24.5
		MCWB	21.3	20.4	19.6	18.4	15.6	13.1	12.0	12.3	13.7	15.9	17.8	19.4
	10%	DB	24.1	23.6	22.9	22.2	20.1	17.9	17.1	18.0	19.1	20.2	21.4	23.0
		MCWB	20.2	19.6	19.1	18.2	15.7	13.0	12.3	12.9	14.1	15.9	17.4	19.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	22.6	21.9	20.7	19.2	16.7	15.6	16.0	16.8	18.9	20.7	22.1
		MCDB	28.7	25.6	26.1	23.6	21.9	21.0	19.1	19.4	23.0	25.1	24.7	26.8
	2%	WB	22.4	21.7	21.0	20.1	18.1	15.4	14.6	15.0	16.0	17.8	19.5	21.0
		MCDB	26.4	24.3	23.6	22.5	20.6	18.8	18.1	18.9	20.8	22.2	23.2	25.0
	5%	WB	21.6	21.2	20.3	19.5	17.2	14.6	13.7	14.2	15.2	17.2	18.6	20.1
		MCDB	24.9	23.6	22.8	22.0	20.2	17.7	16.6	17.7	19.1	21.0	21.9	23.7
	10%	WB	20.8	20.7	19.8	18.8	16.3	14.0	13.0	13.5	14.7	16.5	17.8	19.4
		MCDB	23.6	23.0	22.3	21.5	19.3	16.7	15.9	16.8	18.2	19.9	21.1	22.3
Mean Daily Temperature Range	5% DB	MDBR	5.1	4.8	5.5	7.9	8.7	9.0	9.8	9.8	9.3	7.7	6.3	5.9
		MCDBR	9.3	7.8	8.3	11.1	12.0	12.5	13.4	15.2	15.6	14.9	11.5	10.5
		MCWBR	5.2	5.0	5.0	6.3	6.6	6.8	7.5	7.5	6.9	6.5	5.6	5.9
	5% WB	MCDBR	8.1	6.4	6.7	8.3	8.9	9.4	10.1	10.8	10.8	10.1	9.2	8.2
		MCWBR	5.0	4.4	4.4	5.5	6.1	6.4	6.9	7.0	6.3	5.3	4.9	5.1
Clear-Sky Solar Irradiance	taub	0.369	0.369	0.346	0.331	0.314	0.299	0.300	0.309	0.339	0.344	0.354	0.356	
	taud	2.513	2.532	2.576	2.613	2.628	2.650	2.631	2.595	2.501	2.502	2.505	2.526	
	Ebn at Noon	970	950	938	901	868	861	875	912	930	963	978	986	
	Edh at Noon	113	107	96	83	73	67	72	83	102	109	113	112	
All-Sky Solar Radiation	RadAvg	7.26	6.33	5.37	4.18	3.18	2.75	3.03	3.98	5.23	6.40	7.05	7.54	
	RadStd	0.56	0.63	0.32	0.23	0.19	0.12	0.19	0.20	0.33	0.29	0.48	0.43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page