

EUCLA, Australia

WMO: 946470

Lat: 31.680S

Lon: 128.879E

Elev: 307

StdP: 14.53

Time Zone: 8.75 (AUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.0	42.0	14.2	11.4	75.5	19.8	15.0	71.8	22.8	58.9	20.9	60.1	7.9	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	98.2	63.2	91.7	62.2	85.9	61.6	70.7	81.1	69.0	77.8	67.8	75.4	15.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	104.3	73.1	66.5	98.8	71.6	65.4	94.8	70.8	34.8	81.1	33.4	78.4	32.3	75.6	93.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.8	17.5	DB	36.1	110.0	1.4	3.9	35.1	112.8	34.3	115.0	33.5	117.2	32.5	120.0	(4)
(5)			WB	33.9	76.5	1.9	5.4	32.5	80.4	31.4	83.6	30.3	86.6	28.9	90.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	70.1	70.2	68.1	65.2	60.3	56.0	54.7	56.5	59.5	62.6	65.3	67.7	(6)	
	DBStd	7.65	5.80	5.37	5.53	5.16	4.84	3.74	3.83	5.23	6.37	6.80	6.42	6.01	(7)	
	HDD50	5	0	0	0	0	0	1	2	2	0	0	0	0	(8)	
	HDD65	1529	4	2	18	57	164	272	321	272	195	134	67	23	(9)	
	CDD50	4740	622	566	562	455	320	181	148	203	285	389	460	549	(10)	
	CDD65	788	161	149	115	62	20	2	1	8	29	58	76	107	(11)	
	CDH74	5964	1002	794	702	432	173	18	21	143	398	665	750	866	(12)	
	CDH80	2794	492	366	350	164	49	1	2	37	162	345	387	439	(13)	
(14) Wind	WSAvg	10.4	11.6	11.2	10.3	9.3	8.8	9.2	9.5	9.9	10.6	11.3	11.4	11.5	(14)	
(15) Precipitation	PrecAvg	11.9	0.5	0.8	1.0	1.1	1.3	1.3	1.1	1.2	1.1	0.6	0.9	0.9	(15)	
	PrecMax	16.7	3.3	7.2	3.8	3.3	4.1	4.1	3.3	4.4	2.8	2.2	2.7	5.9	(16)	
	PrecMin	5.7	0.0	0.0	0.0	0.1	0.0	0.1	0.3	0.1	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.0	0.8	1.3	1.1	0.8	0.8	0.9	0.7	0.9	0.8	0.6	0.7	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.4	102.8	100.9	92.7	85.8	76.6	76.8	84.8	92.8	98.7	101.8	105.4	(19)	
		MCWB	65.9	66.8	64.5	61.0	59.5	55.7	53.1	54.7	57.5	60.1	63.6	64.7	(20)	
	2%	DB	91.6	90.7	90.4	84.4	78.7	71.0	71.4	77.8	84.6	90.1	91.0	91.4	(21)	
		MCWB	65.7	65.6	63.2	60.1	57.8	54.5	53.1	53.3	56.8	58.3	61.8	63.6	(22)	
	5%	DB	83.8	82.2	81.4	78.5	73.2	67.5	67.3	72.0	77.6	81.2	82.2	82.0	(23)	
		MCWB	65.7	65.4	63.5	59.7	57.6	53.6	52.2	52.6	55.4	57.4	61.0	63.6	(24)	
	10%	DB	77.6	77.1	75.1	73.3	69.1	64.5	63.7	67.0	71.2	73.1	75.2	76.4	(25)	
		MCWB	66.4	66.6	64.1	60.9	57.2	53.6	51.6	52.0	54.5	56.5	60.9	63.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.5	73.4	70.9	67.7	65.0	61.4	59.3	59.4	63.0	64.8	68.8	71.9	(27)	
		MCDB	86.4	86.8	81.4	75.7	70.2	67.9	66.2	67.6	74.4	80.7	83.2	83.1	(28)	
	2%	WB	70.4	70.5	68.5	65.9	62.8	58.8	56.8	57.5	60.0	62.3	65.6	68.4	(29)	
		MCDB	81.6	78.7	76.2	71.8	69.3	64.7	63.0	66.3	71.6	74.3	78.6	79.2	(30)	
	5%	WB	68.7	68.9	67.2	64.7	61.2	57.0	55.2	55.9	58.3	60.8	63.8	66.6	(31)	
		MCDB	78.1	75.5	73.5	70.3	68.1	62.7	61.9	64.5	68.6	71.5	73.9	75.7	(32)	
	10%	WB	67.2	67.6	65.9	63.5	59.4	55.5	53.8	54.5	57.0	59.3	62.4	65.2	(33)	
		MCDB	75.1	73.6	71.7	69.3	66.1	61.3	60.6	62.8	66.8	69.3	71.3	72.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	12.9	14.1	16.7	17.7	17.7	18.7	20.3	20.8	18.6	16.3	15.2	(35)	
		MCDBR	27.9	25.7	27.5	26.7	25.0	23.2	25.3	29.3	32.9	34.3	32.4	29.1	(36)	
	5% WB	MCWBR	10.4	10.0	10.7	11.1	11.7	11.8	12.5	12.5	11.7	12.0	11.3	10.7	(37)	
		MCWBR	19.6	15.9	16.3	17.2	17.4	17.4	18.6	21.1	22.7	23.5	21.5	20.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.364	0.362	0.341	0.328	0.307	0.297	0.297	0.306	0.345	0.342	0.353	0.352	(40)	
		taud	2.507	2.533	2.574	2.604	2.632	2.630	2.619	2.581	2.457	2.483	2.489	2.517	(41)	
	Ebn at Noon		310	304	300	288	279	274	279	291	293	306	311	314	(42)	
		Edh at Noon	36	34	31	27	23	22	23	27	34	35	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2360	2105	1764	1371	1047	901	995	1302	1707	2088	2303	2452	(44)	
	RadStd		188	197	114	80	63	37	56	65	107	86	147	119	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page