

NULLARBOR, Australia

WMO: 946510

Lat: 31.449S

Lon: 130.898E

Elev: 65

StdP: 100.55

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.7	3.8	-7.0	2.1	24.4	-4.7	2.6	21.8	13.0	15.4	11.8	15.1	4.2	40	0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	39.1	18.9	36.0	18.1	32.9	17.5	21.9	29.7	20.9	27.9	20.1	26.1	7.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.1	22.7	19.2	14.1	22.0	18.4	13.3	21.5	64.4	29.4	60.7	27.8	57.8	26.0	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	11.2	10.3	DB	0.3	44.1	1.3	2.1	-0.6	45.7	-1.4	46.9	-2.1	48.1	-3.1	49.6	(4)
			WB	-0.5	24.0	1.6	1.4	-1.6	25.0	-2.5	25.8	-3.4	26.6	-4.5	27.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	21.8	21.6	20.1	18.3	15.0	12.5	12.0	12.9	15.0	17.2	19.1	20.7
	DBStd	4.79	3.80	3.55	3.48	3.03	2.68	2.09	2.06	2.78	3.53	3.97	4.10	3.89
	HDD10.0	8	0	0	0	0	0	2	3	2	1	0	0	0
	HDD18.3	948	3	3	14	37	111	177	196	172	114	72	37	13
	CDD10.0	2621	364	326	314	248	156	76	66	92	151	224	273	331
	CDD18.3	520	109	96	71	35	8	1	0	3	15	37	59	87
	CDH23.3	5432	976	799	648	374	93	7	10	72	272	553	728	899
CDH26.7	2801	548	431	342	152	24	1	1	13	113	287	399	491	
Wind	WSAvg	5.7	6.8	6.6	5.9	5.1	4.7	4.7	4.9	5.3	5.7	6.2	6.4	6.5
Precipitation	PrecAvg	265	11	15	28	24	27	25	27	24	25	22	19	20
	PrecMax	500	49	61	220	96	80	85	100	72	88	117	64	109
	PrecMin	109	0	0	0	1	0	0	3	0	0	0	0	0
	PrecStd	104	13	19	51	25	18	20	23	16	22	27	16	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	41.1	39.7	34.8	29.8	24.3	24.7	28.6	33.7	37.7	39.9	41.2
		MCWB	19.6	20.3	18.9	16.9	15.3	13.7	12.9	13.6	15.5	17.1	18.3	18.9
	2%	DB	37.7	36.9	34.8	30.8	25.8	21.4	21.6	25.4	30.3	33.7	35.6	36.6
		MCWB	19.8	19.5	18.2	16.3	14.7	12.6	12.0	12.7	14.9	15.8	17.4	17.9
	5%	DB	32.6	31.9	30.3	27.6	23.0	19.4	19.5	22.2	26.2	29.6	31.2	32.1
		MCWB	19.2	19.3	18.0	15.7	14.0	12.2	11.8	12.4	13.8	14.7	16.8	18.0
	10%	DB	28.3	27.7	26.0	24.5	20.5	17.7	17.6	19.5	22.8	25.4	27.1	28.0
		MCWB	18.7	18.9	17.3	15.8	14.1	12.0	11.6	11.7	13.0	14.5	16.3	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.6	21.9	19.8	18.0	16.1	15.5	15.6	17.3	19.3	20.6	22.9
		MCDB	30.8	31.7	28.4	24.1	21.1	19.3	19.0	20.7	26.9	27.4	30.0	29.1
	2%	WB	21.6	21.8	20.6	18.8	17.0	14.7	14.1	14.5	16.0	17.5	19.2	20.9
		MCDB	30.3	29.2	25.8	22.9	20.9	17.8	17.9	20.0	24.6	26.5	29.2	29.4
	5%	WB	20.6	20.7	19.6	18.0	16.0	13.7	13.1	13.5	15.0	16.3	18.1	19.6
		MCDB	28.0	26.6	24.2	22.3	20.3	17.0	17.2	18.9	22.2	24.5	26.9	27.1
	10%	WB	19.7	19.9	18.8	17.2	15.1	12.9	12.3	12.7	14.2	15.5	17.2	18.6
		MCDB	25.7	25.1	23.6	21.6	19.1	16.2	16.3	18.0	20.4	22.3	24.1	25.2
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.4	11.0	12.0	11.5	11.5	12.0	13.0	13.7	13.3	12.2	11.9
		MCDBR	20.5	19.8	19.3	18.1	16.0	15.0	15.6	17.9	20.4	21.8	21.5	20.6
		MCWBR	6.2	6.2	6.7	7.2	7.4	8.1	8.1	8.1	8.1	7.7	7.1	6.6
	5% WB	MCDBR	14.0	13.0	12.1	12.0	11.7	11.0	12.0	13.8	15.7	16.2	15.9	15.2
		MCWBR	5.1	5.1	5.4	6.1	6.7	7.2	7.6	7.6	7.3	6.7	6.1	6.1
Clear-Sky Solar Irradiance	taub	0.360	0.362	0.339	0.329	0.311	0.299	0.298	0.307	0.338	0.347	0.353	0.351	
	taud	2.510	2.522	2.570	2.589	2.606	2.620	2.616	2.571	2.480	2.458	2.479	2.511	
	Ebn at Noon	980	958	948	906	875	864	882	916	933	961	979	991	
	Edh at Noon	113	109	97	86	75	70	73	85	104	114	116	114	
All-Sky Solar Radiation	RadAvg	7.72	7.02	5.88	4.43	3.39	2.90	3.17	4.16	5.51	6.69	7.47	7.93	
	RadStd	0.54	0.48	0.32	0.28	0.18	0.12	0.17	0.20	0.31	0.28	0.39	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.31	N/A	-2.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page