

CEDUNA, Australia

WMO: 946530

Lat: 32.1297S

Lon: 133.6975E

Elev: 16

StdP: 101.14

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.9	3.3	-11.9	1.4	27.5	-7.9	1.9	26.1	12.4	14.9	11.3	14.9	2.7	70	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	39.5	18.4	36.8	17.7	33.9	17.3	22.0	29.9	20.8	28.6	20.0	27.0	7.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	14.9	23.7	18.8	13.7	22.8	17.8	12.8	22.1	64.7	29.6	60.4	28.8	57.3	26.9	34.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.9	10.0	-0.5	44.3	1.1	1.5	-1.3	45.4	-2.0	46.3	-2.6	47.1	-3.4	48.3		
(5)			-0.9	25.2	1.0	2.7	-1.6	27.1	-2.2	28.7	-2.7	30.2	-3.4	32.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	22.1	21.9	20.0	17.6	14.8	12.3	11.9	12.5	14.8	17.1	19.1	20.9	(6)
(7)		DBStd	5.13	4.39	4.20	3.95	3.46	2.96	2.41	2.33	2.85	3.50	4.23	4.31	4.35	(7)
(8)		HDD10.0	20	0	0	0	0	1	6	8	6	1	0	0	0	(8)
(9)		HDD18.3	1016	4	5	22	54	118	181	201	182	119	77	39	15	(9)
(10)		CDD10.0	2594	375	333	309	227	149	76	65	84	144	221	273	338	(10)
(11)		CDD18.3	549	121	105	73	31	8	1	1	2	13	39	61	94	(11)
(12)		CDH23.3	6515	1321	1112	795	359	83	6	6	43	222	594	834	1140	(12)
(13)	CDH26.7	3404	756	613	417	139	19	0	1	6	79	292	452	631	(13)	
(14)	Wind	WSAvg	5.4	6.3	6.0	5.5	4.8	4.4	4.3	4.6	4.9	5.5	5.9	6.0	6.2	(14)
(15)	Precipitation	PrecAvg	287	13	13	17	18	30	33	37	33	28	23	18	20	(15)
(16)		PrecMax	534	87	61	97	99	78	88	108	87	87	107	56	125	(16)
(17)		PrecMin	167	0	0	0	0	5	3	8	1	1	0	0	0	(17)
(18)		PrecStd	86	16	16	23	20	20	19	20	22	21	24	14	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	41.6	39.1	34.3	29.2	23.7	23.7	27.2	32.5	37.0	39.9	41.2	(19)
(20)			MCWB	19.4	19.7	17.8	16.4	14.7	13.3	12.3	12.9	14.6	16.2	17.2	17.9	(20)
(21)		2%	DB	39.1	38.2	35.2	30.6	25.6	20.7	20.7	24.1	29.0	33.3	35.7	37.6	(21)
(22)			MCWB	19.0	18.6	18.0	15.5	13.6	12.2	11.4	12.0	13.6	14.8	16.5	17.5	(22)
(23)		5%	DB	34.8	33.9	31.6	27.3	22.9	18.8	18.6	21.5	25.7	30.0	32.3	33.5	(23)
(24)			MCWB	18.6	18.9	17.2	14.9	13.2	12.0	11.3	11.5	12.9	14.0	16.2	17.1	(24)
(25)		10%	DB	30.4	29.9	27.6	24.6	20.5	17.3	16.9	18.7	22.4	26.3	28.2	29.8	(25)
(26)			MCWB	18.6	18.6	17.0	14.9	13.3	12.0	11.2	11.1	12.4	13.6	15.7	17.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	23.9	22.2	19.4	17.5	16.2	15.1	15.2	16.8	18.7	20.3	22.9	(27)
(28)			MCDWB	30.5	30.0	28.3	23.9	20.8	20.5	18.3	20.0	24.0	28.0	28.0	28.3	(28)
(29)		2%	WB	21.9	21.9	20.5	18.2	16.5	14.6	13.7	14.0	15.6	17.2	18.8	20.6	(29)
(30)			MCDWB	31.3	28.9	26.8	22.8	20.1	17.5	16.9	18.4	22.4	25.1	26.7	28.4	(30)
(31)		5%	WB	20.7	20.7	19.5	17.5	15.6	13.6	12.9	13.2	14.7	16.2	17.9	19.4	(31)
(32)			MCDWB	29.1	27.9	24.9	21.9	19.5	16.6	16.4	17.6	20.8	23.6	26.4	27.1	(32)
(33)		10%	WB	19.6	19.7	18.5	16.6	14.7	12.8	12.1	12.4	13.9	15.2	17.1	18.4	(33)
(34)			MCDWB	27.2	26.5	23.9	21.3	18.8	15.8	15.5	17.0	19.7	21.9	24.4	25.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.5	11.7	12.0	12.7	11.4	10.8	10.9	12.3	13.2	13.2	12.4	12.3	(35)
(36)			MCDBR	20.6	20.1	19.1	17.7	15.1	13.0	13.9	16.9	19.7	20.9	21.2	20.4	(36)
(37)			MCWBR	6.9	6.9	7.1	7.3	6.7	6.9	7.2	7.7	7.9	7.7	7.3	7.5	(37)
(38)		5% WB	MCDWB	14.1	13.7	12.4	11.9	10.7	9.8	10.6	12.5	15.0	15.3	14.7	14.8	(38)
(39)			MCWBR	5.9	5.8	6.1	6.5	6.4	6.4	6.8	7.4	7.4	7.1	6.6	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.351	0.332	0.324	0.311	0.296	0.298	0.308	0.334	0.348	0.352	0.343	(40)	
(41)		taud	2.518	2.540	2.574	2.585	2.590	2.618	2.604	2.559	2.486	2.446	2.472	2.522	(41)	
(42)		Ebn at Noon	986	968	953	909	870	862	876	912	935	959	980	998	(42)	
(43)		Edh at Noon	112	106	96	85	76	69	73	86	103	115	117	113	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.88	7.16	5.94	4.43	3.28	2.80	3.03	4.00	5.36	6.52	7.42	7.92	(44)	
(45)		RadStd	0.45	0.37	0.37	0.26	0.17	0.12	0.14	0.20	0.30	0.38	0.35	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	+60
(47)	Regional (3 neighbors)	+0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	+60

Nomenclature: See separate page