

TARCOOLA, Australia

WMO: 946550

Lat: 30.705S

Lon: 134.579E

Elev: 406

StdP: 14.48

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.4	37.1	11.0	9.8	76.2	15.6	12.3	75.4	25.4	62.5	23.2	63.3	4.0	240	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.6	107.8	67.2	104.4	66.3	101.0	65.2	74.1	87.8	71.6	88.7	69.5	88.8	12.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.4	117.7	77.3	67.3	102.0	75.6	63.8	90.1	75.5	38.0	87.0	35.6	88.4	33.8	88.6	97.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	21.5	19.4	DB	29.6	113.3	2.3	2.9	28.0	115.4	26.7	117.1	25.4	118.7	23.8	120.8	(4)
(5)			WB	28.2	80.8	2.5	8.5	26.4	86.9	24.9	91.8	23.5	96.6	21.7	102.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	82.3	80.7	75.4	67.5	59.5	53.5	53.2	56.1	62.3	68.7	74.0	78.2
	DBStd	12.32	8.14	7.88	7.45	6.38	5.61	4.59	4.85	5.65	7.35	8.07	8.31	8.20
	HDD50	42	0	0	0	0	1	15	18	7	1	0	0	0
	HDD65	1439	0	0	6	43	191	345	366	286	139	50	11	2
	CDD50	6448	1002	861	788	525	295	121	118	195	370	578	721	874
	CDD65	2372	538	441	329	118	20	1	1	8	58	164	283	411
	CDH74	33111	7877	6155	4051	1353	199	9	22	143	941	2374	4019	5968
	CDH80	18793	5010	3741	2147	520	39	0	2	28	364	1182	2217	3543
(14) Wind	WSAvg	9.8	11.4	10.5	9.7	8.5	7.8	7.6	8.3	9.3	10.5	11.2	11.1	11.2
(15) Precipitation	PrecAvg	6.8	0.4	0.9	0.3	0.4	0.7	0.6	0.6	0.6	0.7	0.6	0.6	0.5
	PrecMax	17.2	2.6	4.3	2.6	3.3	5.4	2.8	2.2	3.2	3.0	3.5	3.6	3.3
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.4	0.6	1.2	0.5	0.7	0.9	0.6	0.5	0.6	0.7	0.8	0.6	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.3	110.3	104.0	97.2	84.8	75.0	76.8	83.8	94.7	101.6	106.9	110.5
		MCWB	68.7	69.1	65.8	63.7	59.1	55.9	53.9	55.8	59.6	62.4	64.7	67.6
	2%	DB	108.2	106.3	100.1	89.9	79.2	70.0	71.9	77.9	89.0	96.2	101.3	105.4
		MCWB	67.9	67.2	63.9	60.7	57.6	54.2	52.8	53.9	57.5	60.7	64.2	65.4
	5%	DB	104.4	101.9	95.9	86.0	75.2	67.0	68.1	73.7	83.9	91.7	97.1	101.3
		MCWB	67.1	66.7	64.0	59.8	55.9	53.1	51.7	53.1	56.4	59.7	62.8	64.6
	10%	DB	100.1	97.9	91.5	81.7	71.6	64.0	64.7	69.7	79.3	86.8	92.4	96.7
		MCWB	65.8	65.5	63.1	58.9	54.9	52.1	50.8	51.7	55.2	58.5	61.6	63.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.7	76.0	74.2	69.3	62.5	61.7	58.8	60.3	64.3	71.2	75.0	81.4
		MCDB	88.3	88.4	80.6	79.5	72.4	68.5	64.9	70.4	73.1	75.6	83.0	84.2
	2%	WB	72.7	73.0	71.2	65.9	60.4	57.8	55.5	57.0	60.3	64.4	68.0	71.7
		MCDB	92.3	92.5	82.1	75.3	72.0	64.5	65.5	71.3	80.8	83.5	85.0	85.7
	5%	WB	70.6	70.5	68.5	63.3	58.6	55.4	53.7	55.0	58.3	62.3	65.8	68.8
		MCDB	93.2	90.6	82.9	78.7	70.4	62.5	64.7	69.0	79.5	84.4	86.2	88.7
	10%	WB	68.6	68.3	65.9	61.3	57.0	53.7	52.2	53.3	56.4	60.3	64.1	66.4
		MCDB	93.2	89.7	86.4	77.0	67.9	61.4	62.4	66.5	76.3	82.5	87.0	89.3
(35) Mean Daily Temperature Range	5% DB	MDBR	27.6	26.2	24.6	24.2	23.1	21.9	23.3	25.5	27.4	27.6	27.4	27.9
		MCDBR	31.5	30.4	30.1	30.4	27.1	25.5	27.9	30.4	33.8	33.8	32.4	31.7
		MCWBR	10.6	10.0	9.9	11.9	12.2	13.8	14.1	13.7	13.9	12.9	11.8	11.2
	5% WB	MCDBR	25.8	23.1	20.7	21.7	21.3	19.2	23.5	25.8	28.9	27.6	27.4	26.0
		MCWBR	10.8	9.3	8.5	10.8	10.6	11.8	13.2	13.2	13.6	12.6	12.6	12.1
(40) Clear-Sky Solar Irradiance	taub		0.356	0.353	0.334	0.325	0.306	0.291	0.294	0.307	0.336	0.350	0.356	0.346
	taud		2.459	2.490	2.515	2.526	2.548	2.576	2.559	2.500	2.425	2.394	2.421	2.470
	Ebn at Noon		312	307	302	289	280	278	282	291	297	305	310	316
	Edh at Noon		38	36	33	29	25	23	25	29	35	39	39	38
(44) All-Sky Solar Radiation	RadAvg		2544	2314	1969	1489	1134	974	1059	1363	1804	2137	2379	2538
	RadStd		137	132	126	81	72	48	46	59	95	125	95	89

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-4.54	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.58	N/A	N/A	+1.22	N/A	N/A	N/A	N/A	+232	+148

Nomenclature: See separate page